



Tipo Documento: Relazione Tecnica

Codice documento: SFP-CSC-100043-CCGT

Rev. 1

Pagina 1 di 14

Centrale di San Filippo del Mela
Progetto definitivo per l'installazione di un nuovo ciclo combinato a gas
Note di calcolo – Fondazioni minori

APPLICA

A2A/DGE/BGT/GEN/ING

LISTA DI DISTRIBUZIONE

A2A/DGE/BGT/GEN/ING
 AEF/AMD/ISF



LOGO E CODIFICA DEL FORNITORE MILANO

TECHINT
 Engineering & Construction

0421-TITA-C-CA-000-008

EMISSIONE					
1	10/12/2019	FU = Per Uso	C. Bettoni	D. Morgera	P. Coletti
0	27/11/2019	FA = Per Approvazione	L. Agostino	C. Bettoni	G. Ricci
REV	DATA	DESCRIZIONE	REDAZIONE	VERIFICA	APPROVAZIONE

- Il documento approvato e firmato in originale è depositato presso l'archivio tecnico della S.O.-

Questo documento è proprietà del Gruppo A2A: non può essere utilizzato, trasmesso a terzi o riprodotto senza autorizzazione della stessa. Il Gruppo A2A tutela i propri diritti a norma di legge


INDICE

1	SCOPO	3
2	PARAMETRI DI PROGETTAZIONE	4
2.1	DOCUMENTI DI RIFERIMENTO	4
2.2	SOFTWARES	4
2.3	MATERIALI.....	4
2.3.1	<i>ACCIAIO STRUTTURALE</i>	4
2.3.2	<i>CALCESTRUZZO</i>	4
2.3.3	<i>ACCIAIO D'ARMATURA</i>	4
3	POMPE ALIMENTO.....	5
4	VASCHE	11
4.1	VASCA BLOW-DOWN.....	12

1 SCOPO

Lo scopo di applicazione del presente documento consiste nella definizione delle fondazioni relative a:

1. Pompe alimento;
2. Vasche.



Sono state fatte considerazioni di buona pratica in base ad ipotesi ed alcuni standard Techint.

La progettazione di tutti gli elementi in base ai codici e alle norme applicabili rimane a carico del fornitore EPC.

2 PARAMETRI DI PROGETTAZIONE

2.1 DOCUMENTI DI RIFERIMENTO

NORMATIVE

- 1 Decreto ministeriale 17 gennaio 2018 - AGGIORNAMENTO "Norme tecniche per le costruzioni".
- 2 Circolare 21 gennaio 2019, nr. 7 - "Istruzioni per l'applicazione dell'aggiornamento delle Norme tecniche per le costruzioni".
- 3 UNI EN 1992-1: Eurocodice 2 – Progettazione delle strutture di calcestruzzo - Parte 1-1: Regole generali e regole per gli edifici

RELAZIONI E SPECIFICHE TECNICHE

- | | | |
|---|------------------------|----------------------|
| 4 | SFP-RTC-100004-CCGT-00 | Relazione Sismica |
| 5 | SFP-RTC-100005-CCGT-00 | Relazione Geotecnica |

2.2 SOFTWARES

- SAP2000 v19.2.1
- MathCAD v14

2.3 MATERIALI

2.3.1 ACCIAIO STRUTTURALE

S275

- $f_{yk} = 275 \text{ N/mm}^2$
- $f_{tk} = 370-530 \text{ N/mm}^2$
- $E_s = 2.1 \times 10^5 \text{ N/mm}^2$

2.3.2 CALCESTRUZZO

C 35/45

- | | | | | | | | | | | | | | | | | |
|--|--|------------|----|-----|------------|----|-----|------------|----|-----|-------------|------|-----|------------|-------|-----|
| <ul style="list-style-type: none"> • resistenza caratteristica cilindrica • resistenza caratteristica cubica • resistenza media a compressione • resistenza media a trazione • modulo di elasticità secante | <table border="0"> <tr> <td>$f_{ck} =$</td> <td>35</td> <td>MPa</td> </tr> <tr> <td>$R_{ck} =$</td> <td>45</td> <td>MPa</td> </tr> <tr> <td>$f_{cm} =$</td> <td>43</td> <td>MPa</td> </tr> <tr> <td>$f_{ctm} =$</td> <td>3.20</td> <td>MPa</td> </tr> <tr> <td>$E_{cm} =$</td> <td>34077</td> <td>MPa</td> </tr> </table> | $f_{ck} =$ | 35 | MPa | $R_{ck} =$ | 45 | MPa | $f_{cm} =$ | 43 | MPa | $f_{ctm} =$ | 3.20 | MPa | $E_{cm} =$ | 34077 | MPa |
| $f_{ck} =$ | 35 | MPa | | | | | | | | | | | | | | |
| $R_{ck} =$ | 45 | MPa | | | | | | | | | | | | | | |
| $f_{cm} =$ | 43 | MPa | | | | | | | | | | | | | | |
| $f_{ctm} =$ | 3.20 | MPa | | | | | | | | | | | | | | |
| $E_{cm} =$ | 34077 | MPa | | | | | | | | | | | | | | |


2.3.3 ACCIAIO D'ARMATURA

B450C

- $f_{yk} = 450 \text{ N/mm}^2$
- $f_{tk} = 540 \text{ N/mm}^2$
- $E_s = 2.1 \times 10^5 \text{ N/mm}^2$


3 POMPE ALIMENTO

Dato che in questa fase di progetto non sono disponibili i disegni del venditore né i carichi della pompa, sono stati utilizzati i dati del fornitore (i carichi e la geometria) relativi a pompe simili di progetti già realizzati.



SULZER			
Typ	PD 125-330/12		
Ser. No	209721 / 209722	Y	2008
Item No.	GVR-6FW-6501A / B	P	kW 2100
Qm ³ /h	303.4	HAWP	kPa 20000
H m	1214.4	if for MAW	°C 182
n RPM	2980	cas ng test p	kPa 30000
Bearing	Sleeve Bearings		
Dry weight kg	2950	Open weight kg	
Co. PO No.	PD20080394		
Equip. description	Sulzer Feed Water Pumps		
Sulzer Pumpen (tsch and) G			

		Netto Mass [kg]	Netto der rot. Teile Mass of rot. parts [kg]	Rotationsmoment [kgm ²] (Inertia J [kgm ²] - Inertia related to [kgm ²])
I	PUMP	~2950	-	2.650
II	COUPLING	75	56.5	0.584
III	MOTOR	~7000	1300	24
IV	BASEPLATE without grout	~2725	-	-
V	AUTOMATIC RECIRCULATING CHECK VALVE	444	-	-
VI	ACCESSORIES	~270	-	-
VII	STRAINER	-	-	-
VIII	OIL SUPPLY UNIT	~500	-	-
	Transport weight	~13564	-	-
	on site: concrete filled-in baseplate	~5220		
	Total weight	~ 21259		



Inputs

Density of concrete	$\gamma_c := 24.5 \frac{\text{kN}}{\text{m}^3}$	
Top of Foundation,	TFL := 0.05m	
Highest Point of Paving/Finished Grade,	HPP := 0.00m	
Lowest Point of Paving/Finished Grade,	LPP := 0.00m	[Lowest point of Paving = 99.800m]
Embedment depth of foundation from LPP	D := 1.5m	[the remaining shall be covered with structured Fill]
Top of foundation from LPP	h := TFL - LPP	h = 0.05 m
Centrel Line of shaft Elevation,	E _{shaft} := 1.058m	

- For pedestal weight calculation dimension related to pedestal.

Pedestal dimension for Pump & Motor baseframe

Length of pedestal along x axis $L_{ped} := 10m$ $L_{ped} = 10m$

Width of pedestal along y axis $B_{ped} := 3m$ $B_{ped} = 3m$

Height of pedestal $h_{ped} := 0.5m$ $h_{ped} = 0.5m$

Weight of pedestal P1 $P1_{weight} := h_{ped} \cdot B_{ped} \cdot L_{ped} \cdot \gamma_c$ $P1_{weight} = 367.5 \text{ kN}$

- For footing weight calculation dimension related to footing.

Plan dimension of the foundation

Length of foundation along x axis $L_f := 10m$ $L_f = 10m$

Width of foundation along y axis $B_f := 4m$ $B_f = 4m$

Height of footing $h_f := 1m$ $h_f = 1m$

Weight of footing P2 $P2_{weight} := h_f \cdot B_f \cdot L_f \cdot \gamma_c$ $P2_{weight} = 980 \text{ kN}$

$j := 1..2$

$P := \begin{pmatrix} P1_{weight} & P2_{weight} \end{pmatrix}^T$ $P = \begin{pmatrix} 367.5 \\ 980 \end{pmatrix} \text{ kN}$

Check 1 Rocking Stability

Check for Rocking Resistance (as per Section 2.4.3 of PIP REIE 686-1996, Chapter 4)

$B_{min} := 1.5 \cdot (E_{shaft} + h + D)$ $B_{min} = 3.912m$

Check_rock := $\begin{cases} \text{"Width Adequate"} & \text{if } B_{min} \leq B_f \\ \text{"Increase Width"} & \text{otherwise} \end{cases}$ $\text{Check_rock} = \text{"Width Adequate"}$

Check 2 Thickness of the foundation

Check_thick := $\begin{cases} \text{"Depth Adequate"} & \text{if } \left[\left(0.6 + \frac{L_f}{30m} \right) m \leq (h_f + h_{ped}) \right] \wedge \max(L_f, B_f) \leq 10 \cdot (h_f + h_{ped}) \\ \text{"Increase Depth"} & \text{otherwise} \end{cases}$ $\text{Check_thick} = \text{"Depth Adequate"}$

Check 3 Mass Ratio

Check 3 Check for Mass Ratio [(as per Section 2.4.2 of PIP REIE 686-1996, Chapter 4)

The pump-driver-set type is Centrifugal type so weight of block concrete foundation shall be 3 times the weight of machine train. (including weight of machine base plate including piping supported on it.)

Total weight of machine train including piping weight

$$P_{\text{Machinetrain}} := 212.6 \text{ kN} \quad P_{\text{Machinetrain}} = 213 \cdot \text{kN} \quad P_{\text{Machinetrain}} = 21679.16669 \cdot \text{kgf}$$

Weight of concrete foundation and pedestals



$$P_{\text{weightfdnped}} := \sum_{j=1}^2 P_j \quad P_{\text{weightfdnped}} = 1348 \cdot \text{kN}$$

$c :=$ "Centrifugal Machine"

$$\text{Ratio} := \begin{cases} 5 & \text{if } c = \text{"Reciprocating Machine"} \\ 3 & \text{otherwise} \end{cases} \quad \frac{P_{\text{weightfdnped}}}{P_{\text{Machinetrain}}} = 6.338$$

$$\text{Conclusion} := \text{if} \left(\frac{P_{\text{weightfdnped}}}{P_{\text{Machinetrain}}} > \text{Ratio}, \text{"Weight of foundation is ok"}, \text{"Increase the weight of foundation"} \right)$$

Conclusion = "Weight of foundation is ok"



SEZIONE A-A
SCALA 1:50


4 VASCHE

1. Vasca Blow Down (8.8m x 6.3m x 3.7m).
2. Pozzetti pompe estrazione del condensato (profondità di 1,6m).
3. Vasca di lavaggio/risciacquo (5.1m x 4.7m x 4.35m).



Il dimensionamento strutturale delle vasche viene definito in base a diverse verifiche di stabilità e di progettazione (galleggiamento, capacità portante e scorrimento).

Il calcolo riportato è eseguito per la Vasca 1.

4.1 VASCA BLOW-DOWN



PARAMETERS			
STRUCTUTRAL MATERIAL PARAMETERS			
Concrete strength, f'c	=	30.00	MPa
Reinforced concrete density	=	25.00	KN/m ³
Steel grade, fy	=	420.00	MPa
shear strength reduction factor, ϕ	=	0.75	
flexure strength reduction factor, ϕ	=	0.90	
cover	=	50.00	mm
permissible crack width for liquid retaining structure	=	0.10	mm
permissible crack width for conc. In contact with earth	=	0.30	mm
F.O.S. against overturn	=	1.50	For LC #1

SOIL AND WATER PARAMETERS			
Soil density, ρs	=	18.00	KN/m ³
Angle of Internal Friction	=	30°	
Active earth pressure co-eff, Ka	=	0.33	
S.B.C.	=	306.00	KN/m ²
Pressure Diagram For Load case -1			
			
Water Density	=	10.00	KN/m ³
Pressure at bottom of wall due to water	=	30.00	KN/m ²
Moment Due to water pressure = 1/2 x 20 x 2 x 1	=	15.00	KN-m
Reaction due to water pressure = 1/2 x 20 x 2	=	20.00	KN
Pressure Diagram For Load case -2			
			
Pressure at bottom of wall due to soil	=	15.00	KN/m ²
Pressure at bottom of wall due to Soil + submerged soil	=	23.00	KN/m ²
Moment Due to soil pressure = 1/2 x 8.31 x 1.39 x ((1.39/3) + 0.61)	=	27.21	KN-m
+ (8.31 x 0.61 x 0.61/2) + (1/2 x 9.84 x 0.61 x (0.61/3)	=	27.21	
Reaction due to sol pressure = (1/2 x 8.31 x 1.39)	=		
+ (8.31 x 0.61) + (1/2 x 9.84 x 0.61)	=	28.25	KN

LOAD COMBINATIONS			
SERVICE LOAD For Base Pressure (max. pressure & uplift) & Stability Checks			
LC # 1 : 1.0D + 1.0H or 1.0D+1.0F	Dead	1.00	
	Fluid Pr.	1.00	
	Earth Pr.	1.00	
FACTORED LOAD For Concrete (Strength) Design			
LC # 2 : 1.4D + 1.4F	Dead	1.40	
	Fluid Pr.	1.40	
LC # 3 : 1.2D + 1.6H or 1.2D+1.2F	Dead	1.20	
	Fluid Pr.	1.20	
	Earth Pr.	1.60	

LC # 1 : 1.0D + 1.0H or 1.0D+1.0F			
BEARING PRESSURE CHECK			
Self wt of walls	=	858	kN
Self wt of top slab	=	0	kN
Self wt of bottom slab	=	554.4	kN
Weight of Fluid inside	=	1320	kN
Total Vertical Load	=	2732.4	kN
Base Area	=	55.44	m ²
Bearing Pressure	=	49.3	kN/m ²
Allowable Bearing Pressure	<	105.00	kN/m ²
SAFE AGAINST BEARING			
LC # 1 : 1.0D + 1.0H or 1.0D+1.0F			
BUOYANCY CHECK			
Self wt of tank	=	1412.4	kN
Submerged volume of tank	=	49.90	m ³
Force due to buoyancy	=	498.96	kN
Check for Buoyancy	SAFE AGAINST BUOYANCY		