



REGIONE PUGLIA



PROVINCIA di FOGGIA



COMUNE di FOGGIA

Proponente	WIND ENERGY LA ROCCA S.R.L.				
Sede Operativa Via Caravaggio, 125 - 65125 Pescara (PE) P.IVA 02276610686					
Progettazione e Coordinamento	 VEGA sas LANDSCAPE ECOLOGY & URBAN PLANNING Via delle Carrsi, 48 - 71121 Foggia - Tel. 0881.756251 - Fax 1784412324 mail: info@studiovega.org - website: www.studiovega.org				
Paesaggio e beni culturali	Arch. Antonio Demaio Tel. 0881.756251 Fax 1784412324 E-Mail: info@studiovega.org				
Studio Geologico	Studio di Geologia Tecnica & Ambientale Dott.sa Geol. Giovanna Amedei Via Pietro Nenni, 4 - 71012 Rodi Garganico (Fg) Tel./Fax 0884.965793 Cell. 347.6262259 E-Mail: giovannaamedei@tiscali.it				
Studio Idraulico e elettrico	Ing. Antonella Laura Giordano & Ing. Michea Napoli Viale degli Aviatori, 73/F14 - 71122 - Foggia e-mail: micheanapoli@gmail.com				
Studio Archeologico	 ARCHEO LOGICA srl				
Opera	Progetto di un impianto eolico composto da n. 10 Aerogeneratori nel Comune di Foggia (FG) alla località "La Stella - Duanera"				
Oggetto	Folder: PROGETTO - Parte A Nome Elaborato: U5U1VR6_ARCDOC_A10 Descrizione Elaborato: Piano di manutenzione dell'impianto				
00	Gennaio 2020	Progetto definitivo		Vega	Arch. A. Demaio
Rev.	Data	Oggetto della revisione		Elaborazione	Verifica
Scala: Fs		Formato:		Approvazione	
		Codice Pratica		U5U1VR6	


Progetto di un impianto eolico composto da n.10 aerogeneratori nel Comune di Foggia in località "La Stella - Duanera".

INDICE

A. PARTE GENERALE	2
A.1 Componenti dell'impianto.....	2
A.2 Schede Tecniche dei Componenti dell'impianto.....	2
A.3 Schemi di Funzionamento dell'impianto.....	5
B. SISTEMA DI MANUTENZIONE DELL'IMPIANTO.....	5
C. MANUALE D'USO DI TUTTI I COMPONENTI DELL'IMPIANTO	6
D. PROGRAMMA DI MANUTENZIONE	7
E. ALLEGATI.....	7

INDICE FIGURE

<i>Figura 1 - Navicella SG 4.3-145.....</i>	3
---	---



Progetto di un impianto eolico composto da n.10 aerogeneratori nel Comune di Foggia in località "La Stella - Duanera".

A. PARTE GENERALE

A.1 Componenti dell'impianto

L'impianto eolico di progetto presenta i seguenti componenti principali:

- 10 aerogeneratori di grande taglia
- 1 cavidotto interrato di impianto a 30 kV
- 1 cabina di raccolta delle linee di impianto
- 1 cavidotto interrato di collegamento tra la cabina di raccolta e sottostazione costituito da due o più terne da 30 kV
- 1 stallo produttore di trasformazione 30-150 kV
- 1 cavidotto da 150kV per il collegamento tra stallo produttore e sottostazione di Lucera

La gestione e la manutenzione dell'impianto devono contemplare tutti i componenti elencati. Inoltre, per eseguire la corretta manutenzione sull'aerogeneratore, la piazzola deve essere sempre accessibile con i mezzi normalmente necessari (furgoni, cestello, gru,...) e quindi anche le vie di accesso devono essere correttamente manutenute mantenendo il fondo praticabile anche nella stagione avversa e organizzando lo sgombero neve nel caso di precipitazioni di tal tipo.

A.2 Schede Tecniche dei Componenti dell'impianto

AEROGENERATORE

Le macchine proposte hanno le seguenti caratteristiche:


- grande taglia con diametro rotore fino a 145 m;
- altezza mozzo fino a 107,5 m, comunque altezza complessiva, altezza mozzo più pala, non superiore a 180m)

L'aerogeneratore di riferimento è SG. 4.3-145 da 4.3 MW di potenza nominale, con altezza mozzo pari a 107,5 m. Tale turbina descrive e riassume le caratteristiche del gruppo di turbine idonee al sito.

In allegato 1 è riportata la scheda tecnica del Costruttore Siemens-Gamesa con tutte le caratteristiche funzionali principali.

Lo schema costruttivo rimane quello classico, in cui la navicella è progettata con struttura portante saldata. Al suo interno sono alloggiati il sistema di trasmissione con moltiplicatore di giri, il generatore elettrico e i dispositivi ausiliari.

L'avvio della turbina avviene con un vento di 3m/s, a passo massimo.



VEGA sas

LANDSCAPE ECOLOGY
& URBAN PLANNING

Via dell'Arco, 48 - 71121 Foggia - Tel. 0881.756251 - Fax 1784412324
mail: info@studiodvega.org - website: www.studiodevega.org

Protocollo: U5U1VR6
Data emissione: 2020
Committente: Wind Energy La Rocca Srl
N° commessa: 2019-027
File: Doc_PianoManutenzione

Progetto di un impianto eolico composto da n.10 aerogeneratori nel Comune di Foggia in località “La Stella - Duanera”.




Figura 1 - Navicella SG 4.3-145

Al crescere del vento il rotore può aumentare la sua velocità fino a quella nominale, variando il passo delle pale e regolando il generatore.


A velocità del vento alte, oltre quella di raggiungimento della potenza nominale, il sistema di regolazione del passo e quello del generatore mantengono la potenza al valore prefissato, indipendentemente da variazioni di velocità del vento, di carico, di temperatura o di densità dell'aria.

Quando necessario, l'aerogeneratore frena aerodinamicamente mettendo le pale completamente in bandiera.

Tutte le funzioni dell'aerogeneratore sono monitorate e controllate da diverse unità di controllo basate su microprocessori.

Le pale del rotore, aventi forte influenza sull'output della turbina e sull'emissione sonora, sono di materiale a base epossidica rinforzato da fibre di vetro e di carbonio, quindi caratterizzate da durevolezza, resistenza all'abrasione e alta resistenza ai fattori chimici e alle radiazioni solari. Hanno inoltre un rivestimento di protezione contro i fattori atmosferici.

Il profilo alare si estende fino alla navicella, ottimizzando così l'andamento delle linee di corrente per l'intera lunghezza della pala.



Progetto di un impianto eolico composto da n.10 aerogeneratori nel Comune di Foggia in località "La Stella - Duanera".

COMPONENTI PRINCIPALI DELLA TURBINA

Pale:

- Numero: 3
- Lunghezza: 72,5 m
- Materiale: materiale composito a matrice epossidica rinforzata con fibra di vetro e carbonio

Rotore:

- Diametro 145 m
- Area spazzata 16.506 mq

Sistema di controllo del passo (pitch control):

- Sistema idraulico
- massima affidabilità grazie al sistema di gestione della turbina
- Manutenzione meccanica e del software

Mozzo:

- design compatto ideale per la trasmissione dei carichi
- integrazione degli azionamenti delle pale

Generatore e convertitore di frequenza:

- generatore asincrono a doppia alimentazione.
- regime di rotazione variabile per un ottimo rendimento
- temperatura contenuta del generatore anche a temperature ambientali molto elevate; le aree a temperatura più elevata sono costantemente monitorate da numerosi sensori


Sistema di imbardata (yaw control):

- azionamento mediante motoriduttori
- grazie allo scarso attrito del cuscinetto e la completa ventilazione dei freni, lo sforzo dei motoriduttori durante la rotazione è ridotto al minimo

CAVI ELETTRICI

I cavi elettrici unipolari a 30 kV di riferimento sono i Prysmian. La relativa scheda tecnica, "Medium Voltage Systems" – Prysmian Cavi e Sistemi Energia Srl.

Tutti i collegamenti elettrici, tra gli aerogeneratori e alla sottostazione, sono realizzati per mezzo di cavidotti interrati: questa soluzione permette di minimizzare l'emissione elettromagnetica ed elimina del



VEGA sas
LANDSCAPE ECOLOGY
& URBAN PLANNING

Via dell'Carri, 48 - 71121 Foggia - Tel. 0881.756251 - Fax 1784412324
mail: info@studiovega.org - website: www.studiovega.org

Protocollo: U5U1VR6
Data emissione: 2020
Committente: Wind Energy La Rocca Srl
N° commessa: 2019-027
File: Doc_PianoManutenzione

Progetto di un impianto eolico composto da n.10 aerogeneratori nel Comune di Foggia in località “La Stella - Duanera”.

tutto il problema della visibilità delle linee aeree e il relativo impatto sull'avifauna.

SOTTOSTAZIONE MT/AT

Lo schema elettrico dell'impianto è descritto dall'unifilare di tav. U5U1VR6_ARC_TAV_B16_schema unifilare. La produzione elettrica del parco eolico, costituito da 10 aerogeneratori, viene raccolta con due differenti cabine. La sottostazione dell'impianto è nel Comune di Lucera.

I lavori prevedono la presenza di un trasformatore 30/150 kV, la strumentazione di misura e tutti i vari servizi ausiliari. Per la componentistica si veda la Relazione “U5U1VR6_ARC_DOC_A03_RelazioneImpianti”.

La sottostazione verrà collegata con cavo AT a 150kV con la stazione elettrica di Lucera. Per la stazione utente si rimanda alla tav. U5U1VR6_ARC_TAV_B13_SSE_stallo

A.3 Schemi di Funzionamento dell'impianto

I sistemi di controllo per la gestione dell'aerogeneratore sono il *pitch control* e lo *yaw control*.

Il primo, pitch control, di cui è dotata ciascuna pala in modo indipendente, esegue la rotazione delle pale intorno al loro asse principale e permette la riduzione della potenza al suo valore nominale, evitando così l'utilizzo di freni meccanici. Gli angoli aerodinamici e costruttivi sono costantemente monitorati, in modo da permettere veloci regolazioni in funzione del vento. Il vento è misurato in continuo con anemometro di macchina.

Il carico elettrico è costantemente monitorato ed in caso di caduta di rete, ovvero mancanza di carico, si ha un arresto di emergenza del rotore tramite frenatura aerodinamica e stazionamento meccanico. Stessa procedura in caso di grave guasto e incendio.


Il secondo, yaw control detto anche imbardata, modifica l'orientamento della navicella, allineando la macchina rispetto alla direzione del vento e garantendo, indipendentemente dalla direzione del vento, la migliore esposizione del rotore ovvero perpendicolare alla direzione del vento in posizione sopravento rispetto alla torre.

La direzione del vento è costantemente monitorato da apposita bandiera di macchina. Per gli schemi di funzionamento dell'impianto far riferimento alle seguenti tavole di progetto:

- U5U1VR6_ARC_TAV_B16_schema unifilare

B. SISTEMA DI MANUTENZIONE DELL'IMPIANTO

L'aerogeneratore è dotato di un sistema di controllo remoto che permette di monitorarne costantemente lo stato, e in caso di anomalie, opportuni sensori trasmettono gli allarmi relativi consentendo



VEGA sas

LANDSCAPE ECOLOGY
& URBAN PLANNING

Via dell'Arri, 48 - 71121 Foggia - Tel. 0881.756251 - Fax 1784412324
mail: info@studiodvega.org - website: www.studiodevega.org

Protocollo: U5U1VR6
Data emissione: 2020
Committente: Wind Energy La Rocca Srl
N° commessa: 2019-027
File: Doc_PianoManutenzione

Progetto di un impianto eolico composto da n.10 aerogeneratori nel Comune di Foggia in località “La Stella - Duanera”.

tempestivi interventi anche per manutenzione non programmata.

Relativamente alla manutenzione dell'aerogeneratore la progettazione dello stesso ha raccolto le esigenze degli operatori sviluppando una macchina con le seguenti caratteristiche:

- ✓ accesso alla navicella dall'interno della torre con utilizzo di ascensore;
- ✓ montacarichi esterno
- ✓ notevole disponibilità di spazio nella navicella per interventi facili ed ergonomici
- ✓ accesso al mozzo agevole direttamente dalla navicella
- ✓ facilità nel raggiungere tutti i componenti
- ✓ sicurezza durante la manutenzione grazie alla protezione di tutte le parti rotanti
- ✓ in caso di necessità, la macchina consente lo smontaggio di molti componenti

Il programma di manutenzione generale programmata è suddiviso in tre categorie:

- ✓ Manutenzione visiva e con rilevamento di rumori anomali;
- ✓ Manutenzione meccanica con verifica livelli lubrificanti;
- ✓ Manutenzione elettrica.


C. MANUALE D'USO DI TUTTI I COMPONENTI DELL'IMPIANTO

Le turbine eoliche sono macchine nel pieno senso e quindi ricadono nel campo di applicazione della direttiva Macchine UE98/37 con successivi aggiornamenti e norme collegate.

La normativa di riferimento per la progettazione e la sicurezza è la CEI-EN 61400-1 ed.3 “Turbine eoliche – Parte 1: Prescrizioni per la progettazione” del febbraio 2006 (recepimento della IEC 61400-1 ed.3 del novembre 2005 “Wind Turbines – Part 1: Design requirements) e norme collegate.

Le turbine vengono progettate, costruite, collaudate, secondo le normative di cui sopra, e vengono sottoposte nel loro complesso all'esame di enti indipendenti di certificazione, che in caso di esito positivo, emettono differenti certificati. Il più completo, che riassume anche gli altri, è la certificazione di tipo (Type Certificate). Prima di questa vengono verificati il progetto, il sistema e l'organizzazione di costruzione, i materiali.

Per questo motivo il “Manuale d’Uso e Manutenzione” dell'aerogeneratore è un requisito essenziale che raccoglie in dettaglio tutte le operazioni di manutenzione ordinaria e straordinaria di tutti i componenti. La complessità della macchina ed il numero dei vari componenti incorporati rende il documento complessivo così articolato che solo alla consegna del WTG viene fornita la copia specifica per il tipo di macchina.



VEGA sas

LANDSCAPE ECOLOGY
& URBAN PLANNING

Via dell'Carri, 48 - 71121 Foggia - Tel. 0881.756251 - Fax 1784412324
mail: info@studiovega.org - website: www.studiovega.org

Protocollo: U5U1VR6
Data emissione: 2020
Committente: Wind Energy La Rocca Srl
N° commessa: 2019-027
File: Doc_PianoManutenzione

Progetto di un impianto eolico composto da n.10 aerogeneratori nel Comune di Foggia in località "La Stella - Duanera".

D. PROGRAMMA DI MANUTENZIONE

Il programma di manutenzione generale programmato prevede scadenze regolari con intervallo variabile a seconda della tipologia di controllo. Gli intervalli previsti sono:

- ✓ Manutenzione iniziale – ad 1 mese dall'entrata in funzione;
- ✓ Manutenzione semestrale;
- ✓ Manutenzione annuale (o secondo multipli di anno);

In tal modo si ottiene un ottimale livello di efficienza dell'impianto, garantendo costantemente adeguati livelli di sicurezza.

In particolare, le principali azioni riguardanti la torre sono:

- verifica della coppia di serraggio dei bulloni (cadenza annuale);
- controllo visivo dello stato delle lamiere (primo controllo dopo tre anni, successivi con cadenza annuale);
- misura dello spessore della vernice in diverse parti della torre (primo controllo dopo cinque anni e successivi dopo due anni).

Risulta evidente che grazie alla presenza di una squadra di manutenzione sulla macchina ogni semestre, vi sia la possibilità di segnalare eventuali anomalie riscontrate.

Per i collegamenti in AT e le sottostazioni AT/AT e AT/AAT si rimanda al progetto relativo alle Infrastrutture richieste da TERNA tramite STMG.


E. ALLEGATI

[1] SGRE ON SG 4.3-145 Developer Package

Foggia, Gennaio 2020



Il tecnico
Arch. Antonio Demaio



VEGA sas LANDSCAPE ECOLOGY
& URBAN PLANNING
Via dell'Arco, 48 - 71121 Foggia - Tel. 0881.756251 - Fax 1784412324
mail: info@studiodvega.org - website: www.studiouvega.org

Protocollo: U5U1VR6
Data emissione: 2020
Committente: Wind Energy La Rocca Srl
N° commessa: 2019-027
File: Doc_PianoManutenzione

Developer Package SG 4.5-145

Application of the Developer Package

The Developer Package serves the purpose of informing customers about the latest planned product development from Siemens Gamesa Renewable Energy (SGRE). By sharing information about coming developments, SGRE can ensure that customers are provided with necessary information to make decisions.

Furthermore, the Developer Package can assist in guiding prospective customers with the indicated technical footprint of the SG 4.5-145 in cases where financial institutes, governing bodies, or permitting entities require product specific information in their decision processes.

All technical data contained in the Developer Package is subject to change owing to ongoing technical developments. Information contained within the Developer Package may not be treated separately or out of the context of the Developer Package.

The information contained in the Developer Package may not be used as legally binding documentation and cannot be used in contracts between SGRE and any other parties. This Developer Package contains preliminary technical data on SGRE turbines currently under development and can be used in an indicative capacity only.

All technical data is subject to change according to the technical development of the wind turbine.

SGRE and its affiliates reserve the right to change the below specifications without prior notice.

Developer Package

SG 4.5-145

Table of content

Introduction	3
Technical Description	4
Nacelle Arrangement	7
Nacelle Dimensions	8
Elevation Drawing	9
Blade Drawing	10
Design Climatic Conditions	11
Standard Power Curve, Standard power operational mode	13
Standard Ct Curve, Standard power operational mode	15
Power Curve, Air density, Standard power operational mode	16
Ct Curve, Air Density, Standard power operational mode	18
Standard Acoustic Emission	19
Noise Reduction System (NRS) operational modes	20
Electrical Specifications	27
Simplified Single Line Diagram	28
Transformer Specifications ECO	29
Transformer Specifications	29
Preliminary Foundation Loads	31
Tower Dimensions	32
Estimated Foundation Design	34
Preliminary Grid Performance Specification, 50 Hz	37
Preliminary Grid Performance Specification, 60 Hz	40
Reactive Power Capability, 50 Hz	43
Reactive Power Capability, 60 Hz	46
SCADA, System Description	49
Codes and Standards	52
Other Performance Features	53

Introduction

The SG 4.5-145 is the first wind turbine of the new Siemens Gamesa 4.X Platform, the next generation Siemens Gamesa Onshore Geared product series, which builds on the Siemens & Gamesa design and operational experience in the wind energy market.

With a brand new 71m blade, a 4.5 MW generator and a tower portfolio with hub heights ranging from 90m to 157.5m, the SG 4.5-145 aims at becoming a new benchmark in the market for efficiency and profitability.

This Developer Package describes the turbine technical specifications and provides preliminary information for the main components and subsystems.

For further information, please contact your regional SGRE Sales Manager.

Technical Description

Rotor-Nacelle

The rotor is a three-bladed construction, mounted upwind of the tower. The power output is controlled by pitch and torque demand regulation. The rotor speed is variable and is designed to maximize the power output while maintaining loads and noise level.

The nacelle has been designed for safe access to all service points during scheduled service. In addition the nacelle has been designed for safe presence of service technicians in the nacelle during Service Test Runs with the wind turbine in full operation. This allows a high quality service of the wind turbine and provides optimum troubleshooting conditions.

Blades

The SG 4.5–145 Siemens Gamesa blade is made up of fiberglass infusion-molded components. The blade structure uses aerodynamic shells containing embedded spar-caps, bonded to two main epoxy-fiberglass-balsa/foam-core shear webs. The SG 4.5–145 SGRE blade uses a blade design based on SGRE proprietary airfoils.

Rotor Hub

The rotor hub is cast in nodular cast iron and is fitted to the drive train low speed shaft with a flange connection. The hub is sufficiently large to provide room for service technicians during maintenance of blade roots and pitch bearings from inside the structure.

Drive train

The drive train is a 4-points suspension concept: main shaft with two main bearings and the gearbox with two torque arms assembled to the main frame.

The gearbox is in cantilever position; the gearbox planet carrier is assembled to the main shaft by means of a flange bolted joint and supports the gearbox.

Main Shaft

A forged main shaft ensures a comfortable access from the nacelle cover to the hub.

Main Bearings

The low speed shaft of the wind turbine is supported by two spherical roller bearings. The bearings are grease lubricated.

Gearbox

The gearbox is 3 stages high speed type (2 planetary + 1 parallel).

Generator

The generator is a doubly-fed asynchronous three phase generator with a wound rotor, connected to a frequency PWM converter. Generator stator and rotor are both made of stacked magnetic laminations and formed windings. Generator is cooled by air which is cooled with a liquid/air cooling system.

Mechanical Brake

The mechanical brake is fitted to the non-drive end of the gearbox.

Yaw System

A cast bed frame connects the drive train to the tower. The yaw bearing is an externally geared ring with a friction and sliding plain bearing. A series of electric planetary gear motors drives the yawing.

Nacelle Cover

The weather screen and housing around the machinery in the nacelle is made of fiberglass-reinforced laminated panels.

Tower

The wind turbine is as standard mounted on a tapered tubular steel tower. Other tower technologies are available for higher hub heights. The tower has internal ascent and direct access to the yaw system and nacelle. It is equipped with platforms and internal electric lighting.

Controller

The wind turbine controller is a microprocessor-based industrial controller. The controller is complete with switchgear and protection devices. It is self-diagnosing and has a touch panel and display for easy readout of status and for adjustment of settings.

Converter

Connected directly with the Rotor, the Frequency Converter is a back to back 4Q conversion system with 2 VSC in a common DC-link. The Frequency Converter allows generator operation at variable speed and voltage, while supplying power at constant frequency and voltage to the MV transformer. The power conversion system is water cooled and has a modular arrangement for easy maintenance.

SCADA

The wind turbine provides connection to the SGRE SCADA system. This system offers remote control and a variety of status views and useful reports from a standard internet web browser. The status views present information including electrical and mechanical data, operation and fault status, meteorological data and grid station data.

Turbine Condition Monitoring

In addition to the SGRE SCADA system, the wind turbine is equipped with the unique SGRE condition monitoring setup. This system monitors the vibration level of the main components and compares the actual vibration spectra with a set of established reference spectra. Review of results, detailed analysis and reprogramming can all be carried out using a standard web browser.

Operation Systems

The wind turbine operates automatically. It is self-starting when the aerodynamic torque is enough. Below rated wind speed, the wind turbine controller fixes the pitch and torque references for operating in the optimum aerodynamic point (maximum production) taking into account the generator capability. Once rated wind speed is surpassed, the pitch position demand is adjusted to keep a stable power production equal to the nominal value. If high wind derated mode is enabled, the power production is limited once the wind speed exceeds a threshold value defined by design, until cut-out wind speed is reached and the wind turbine stops producing power. If the average wind speed exceeds the maximum operational limit, the wind turbine is shut down by pitching of the blades. When the average wind speed drops back below the restart average wind speed, the systems reset automatically.

Technical Specifications

Rotor

Type	3-bladed, horizontal axis
Position	Upwind
Diameter.....	145 m
Swept area	16,506 m ²
Power regulation	Pitch & torque regulation with variable speed
Rotor tilt	6 degrees

Blade

Type	Self-supporting
Blade length	71.0 m
Root chord.....	2.856 m
Aerodynamic profile	Siemens Gamesa proprietary airfoils
Material	GRE (Glassfiber Reinforced Epoxy)
Surface gloss	Semi-gloss, < 30 / ISO2813
Surface color	Light grey, RAL 7035 or Papyrus White, RAL 9018

Aerodynamic Brake

Type	Full span pitching
Activation.....	Active, hydraulic

Load-Supporting Parts

Hub.....	Nodular cast iron
Main shaft.....	Forged steel
Nacelle bed frame.....	Nodular cast iron

Mechanical Brake

Type	Hydraulic disc brake
Position	Gearbox rear end

Nacelle Cover

Type	Totally enclosed
Surface gloss	Semi-gloss, <30 / ISO2813
Color.....	Papyrus White, RAL 9018

Generator

Type	Asynchronous, DFIG
------------	--------------------

Grid Terminals (LV)

Baseline nominal power	4.5 MW
Voltage	690 V
Frequency.....	50 Hz or 60 Hz

Yaw System

Type	Active
Yaw bearing.....	Externally geared
Yaw drive	Electric gear motors
Yaw brake.....	Active friction brake

Controller

Type	SGRE Wind Turbine Control architecture
SCADA system	SGRE SCADA System

Tower

Type	Tubular steel / Hybrid
------------	------------------------

Hub height	90 - 157 m, site-specific
------------------	---------------------------

Corrosion protection	Painted
Surface gloss	Semi-gloss, <30 / ISO-2813

Color	Papyrus White, RAL 9018
-------------	-------------------------

Operational Data


Cut-in wind speed	3 m/s
Rated wind speed	10.7 m/s (steady wind without turbulence, as defined by IEC61400-1)
Cut-out wind speed	27 m/s
Restart wind speed.....	24 m/s

Weight

Modular approach.....	All modules weight lower than 95 t for transport
-----------------------	--

Nacelle Arrangement



The design and layout of the nacelle are preliminary and may be subject to changes during the development of the product.




- | | | | |
|----------|---------------------|-----------|------------------|
| 1 | Rotor cover | 9 | Yaw system |
| 2 | Pitch system | 10 | High speed shaft |
| 3 | Blade bearings | 11 | Generator |
| 4 | Blades | 12 | Transformer |
| 5 | Low speed shaft | 13 | Nacelle cover |
| 6 | Gearbox | 14 | Cooling system |
| 7 | Electrical cabinets | 15 | Wind sensors |
| 8 | Hydraulic group | 16 | Beacon system |

Nacelle Dimensions

The design and dimensions of the nacelle are preliminary and may be subject to changes during the development phases of the product.




Elevation Drawing



Tip height	162.5m, 180m, 200m, 230m
Hub height	90m, 107.5m, 127.5m, 157.5m
Rotor diameter	145m

Blade Drawing



Dimensions in millimeters.

Design Climatic Conditions

The design climatic conditions are the boundary conditions at which the turbine can be applied without supplementary design review. Applications of the wind turbine in more severe conditions may be possible, depending upon the overall circumstances. A project site-specific review requires the completion by the Client of the “Project Climatic Conditions” form.

Subject	ID	Issue	Unit	Value
Wind, operation	1.1	Wind definitions	-	IEC 61400-1 ¹
	1.2	IEC class	-	IIB
	1.3	Mean air density, ρ	kg/m ³	1.225
	1.4	Mean wind speed, V_{ave}	m/s	8.5
	1.5	Weibull scale parameter, A	m/s	9.59
	1.6	Weibull shape parameter, k	-	2
	1.7	Wind shear exponent, α	-	0.20
	1.8	Reference turbulence intensity at 15 m/s, I_{ref}	-	0.14
	1.9	Standard deviation of wind direction	Deg	8
	1.10	Maximum flow inclination	Deg	8
	1.11	Minimum turbine spacing, in rows	D	3
	1.12	Minimum turbine spacing, between rows	D	5
Wind, extreme	2.1	Wind definitions		IEC 61400-1
	2.2	Air density, ρ	kg/m ³	1.225
	2.3	Reference wind speed average over 10 min at hub height, V_{ref}	m/s	42.5
	2.4	Maximum 3 s gust in hub height, V_{e50}	m/s	59.5
	2.5	Maximum hub height power law index, α	-	0.11
Temperature	3.1	Temperature definitions	-	IEC 61400-1
	3.2	Minimum temperature at 2 m, stand-still, $T_{min, s}$	Deg.C	-30
	3.3	Minimum temperature at 2 m, operation, $T_{min, o}$	Deg.C	-20
	3.4	Maximum temperature at 2 m, nominal operation, $T_{max, o}$	Deg.C	35
	3.5	Maximum temperature at 2 m, stand-still, $T_{max, s}$	Deg.C	50
Corrosion	4.1	Atmospheric-corrosivity category definitions	-	ISO 12944-2
	4.2	Internal nacelle environment (corrosivity category)	-	C3
	4.3	Exterior environment (corrosivity category)	-	C5-M
Lightning	5.1	Lightning definitions	-	IEC61400-24:2010
	5.2	Lightning protection level (LPL)	-	LPL 1
Dust	6.1	Dust definitions	-	IEC 60721-3-4:1995
	6.2	Working environmental conditions	mg/m ³	Average Dust Concentration (95% time) → 0.05 mg/m ³
	6.3	Concentration of particles	mg/m ³	Peak Dust Concentration (95% time) → 0.5 mg/m ³
Hail	7.1	Maximum hail diameter	mm	20
	7.2	Maximum hail falling speed	m/s	20
Ice	8.1	Ice definitions	-	-
	8.2	Ice conditions	Days/yr	7

¹ All mentioning of IEC 61400-1 refers to IEC 61400-1 Ed3.0 2005/A1:2010.

Subject	ID	Issue	Unit	Value
Solar radiation	9.1	Solar radiation definitions	-	IEC 61400-1
	9.2	Solar radiation intensity	W/m ²	1000
Humidity	10.1	Humidity definition	-	IEC 61400-1
	10.2	Relative humidity	%	Up to 95
Obstacles	11.1	If the height of obstacles within 500m of any turbine location height exceeds 1/3 of (H – D/2) where H is the hub height and D is the rotor diameter then restrictions may apply. Please contact Siemens Gamesa Renewable Energy for information on the maximum allowable obstacle height with respect to the site and the turbine type.		

Standard Power Curve, Standard power operational mode

Air density 1.225 kg/m³


Validity range:

Wind Shear (10min average)	≤ 0.3
Turbulence intensity TI [%] for bin i	$5\% \frac{(0.75v_i + 5.6)}{v_i} < TI_i < 12\% \frac{(0.75v_i + 5.6)}{v_i}$
Terrain	Not complex according to IEC 61400-12-1
Upflow β [°]	$-2^\circ \leq \beta \leq +2^\circ$
Grid frequency [Hz]	± 0.5 Hz

Other considerations: Clean rotor blades, undisturbed air flow, turbine operated within nominal limits according to the Electrical Specification.

Next table shows the electrical power [kW] as a function of the wind speed [m/s] horizontal referred to the hub height, averaged in ten minutes, for air density = 1.225 kg/m³. The power curve does not include losses in the transformer and high voltage cables. The power curve is for the standard version of the turbine.


SG 4.5-145	
Wind Speed [m/s]	Power [kW]
3	57
4	243
5	556
6	1010
7	1640
8	2459
9	3376
10	4105
11	4440
12	4491
13	4498
14	4500
15	4500
16	4500
17	4500
18	4499
19	4495
20	4475
21	4423
22	4326
23	4185
24	4020
25	3856
26	3709
27	3593



The annual energy production data for different annual mean wind speeds in hub height are calculated from the above power curve assuming a Weibull wind speed distribution, 100 percent availability, and no reductions due to array losses, grid losses, or other external factors affecting the production.

AEP [MWh]		Annual Average Wind Speed [m/s] at Hub Height										
		5	5.5	6	6.5	7	7.5	8	8.5	9	9.5	
Weibull K	1.5	9251	10993	12659	14222	15667	16985	18171	19225	20149	20948	21628
	2	8447	10533	12605	14605	16496	18256	19874	21346	22672	23854	24894
	2.5	7611	9861	12196	14518	16752	18849	20783	22544	24131	25551	26813

Annual Production [MWh] SG 4.5-145 wind turbine for the standard version, as a function of the annual mean wind speed at hub height, and for different Weibull parameters. Air density 1.225 kg/m3.



Standard Ct Curve, Standard power operational mode

Air density 1.225 kg/m³

Validity range:

Wind Shear (10min average)	≤ 0.3
Turbulence intensity TI [%] for bin i	$5\% \frac{(0.75v_i + 5.6)}{v_j} < TI_i < 12\% \frac{(0.75v_i + 5.6)}{v_j}$
Terrain	Not complex according to IEC 61400-12-1
Upflow β [°]	-2° ≤ β ≤ +2°
Grid frequency [Hz]	± 0.5 Hz

Other considerations: Clean rotor blades, undisturbed air flow, turbine operated within nominal limits according to the Electrical Specification.

The thrust coefficient Ct is used for the calculation of the wind speed deficit in the wake of a wind turbine.

Ct is defined by the following expression:

$$C_t = F / (0.5 * ad * w^2 * A)$$

where


F = Rotor force [N]

ad = Air density [kg/m³]

w = Wind speed [m/s]

A = Swept area of rotor [m²]

SG 4.5-145	
Wind Speed [m/s]	C _T [-]
3	0.8914
4	0.8422
5	0.8214
6	0.8191
7	0.8184
8	0.8023
9	0.7299
10	0.5966
11	0.4521
12	0.3386
13	0.2595
14	0.2044
15	0.1647
16	0.1353
17	0.1128
18	0.0953
19	0.0813
20	0.0699
21	0.0603
22	0.0519
23	0.0446
24	0.0383
25	0.0331
26	0.0289
27	0.0255



Power Curve, Air density, Standard power operational mode

Air density 1.225 kg/m³

Validity range:

Wind Shear (10min average)	≤ 0.3
Turbulence intensity TI [%] for bin i	$5\% \frac{(0.75v_i + 5.6)}{v_i} < TI_i < 12\% \frac{(0.75v_i + 5.6)}{v_i}$
Terrain	Not complex according to IEC 61400-12-1
Upflow β [°]	-2° ≤ β ≤ +2°
Grid frequency [Hz]	± 0.5 Hz

Other considerations: Clean rotor blades, undisturbed air flow, turbine operated within nominal limits according to the Electrical Specification.

Next table shows the electrical power [kW] as a function of the wind speed [m/s] horizontal referred to the hub height, averaged in ten minutes, for different air densities [kg/m³]. The power curve does not include losses in the transformer and high voltage cables. The power curve is for the standard version of the turbine.

P [kW]	Air Density [kg/m ³]								
	Wind Speed [m/s]	1.225	1.06	1.09	1.12	1.15	1.18	1.21	1.24
3	57	42	45	48	50	53	56	58	61
4	243	202	209	217	224	232	239	247	254
5	556	472	488	503	518	533	549	564	579
6	1010	865	891	918	944	970	997	1023	1049
7	1640	1410	1452	1494	1535	1577	1619	1661	1702
8	2459	2121	2182	2244	2306	2367	2429	2490	2551
9	3376	2938	3021	3103	3183	3262	3338	3413	3484
10	4105	3714	3798	3877	3949	4016	4076	4131	4181
11	4440	4251	4304	4348	4383	4412	4432	4448	4459
12	4491	4465	4474	4480	4484	4488	4490	4492	4493
13	4498	4493	4494	4495	4496	4497	4498	4498	4499
14	4500	4498	4499	4499	4499	4499	4499	4500	4500
15	4500	4500	4500	4500	4500	4500	4500	4500	4500
16	4500	4500	4500	4500	4500	4500	4500	4500	4500
17	4500	4500	4500	4500	4500	4500	4500	4500	4500
18	4499	4499	4499	4499	4499	4499	4499	4499	4499
19	4495	4495	4495	4495	4495	4495	4495	4495	4495
20	4475	4475	4475	4475	4475	4475	4475	4475	4475
21	4423	4423	4423	4423	4423	4423	4423	4423	4423
22	4326	4326	4326	4326	4326	4326	4326	4326	4326
23	4185	4185	4185	4185	4185	4185	4185	4185	4185
24	4020	4020	4020	4020	4020	4020	4020	4020	4020
25	3856	3856	3856	3856	3856	3856	3856	3856	3856
26	3709	3709	3709	3709	3709	3709	3709	3709	3709
27	3593	3593	3593	3593	3593	3593	3593	3593	3593

The annual energy production data for different annual mean wind speeds in hub height are calculated from the above power curve assuming a Rayleigh wind speed distribution, 100 percent availability, and no reductions due to array losses, grid losses, or other external factors affecting the production.

AEP [MWh] @ k=2		Annual Average Wind Speed [m/s] at Hub Height										
		5	5.5	6	6.5	7	7.5	8	8.5	9	9.5	10
<i>Density [kg/m3]</i>	1.06	7441	9384	11353	13286	15143	16894	18524	20023	21386	22611	23698
	1.09	7631	9604	11594	13543	15408	17163	18792	20287	21644	22861	23939
	1.12	7818	9818	11830	13792	15665	17422	19049	20540	21890	23100	24169
	1.15	8002	10028	12059	14033	15912	17671	19296	20782	22126	23327	24388
	1.18	8182	10233	12282	14267	16152	17911	19534	21014	22351	23545	24597
	1.21	8359	10434	12499	14494	16383	18143	19763	21238	22568	23753	24797
	1.225	8447	10533	12605	14605	16496	18256	19874	21346	22672	23854	24894
	1.24	8534	10630	12710	14715	16607	18367	19983	21452	22775	23953	24988
	1.27	8705	10822	12916	14929	16824	18583	20195	21659	22975	24145	25172

Annual Production [MWh] SG 4.5-145 wind turbine for the standard version, as a function of the annual mean wind speed at hub height and for different air densities considering a Rayleigh wind speed distribution.

Ct Curve, Air Density, Standard power operational mode

Air density 1.225 kg/m³

Validity range:

Wind Shear (10min average)	≤ 0.3
Turbulence intensity TI [%] for bin i	$5\% \frac{(0.75v_i + 5.6)}{v_i} < TI_i < 12\% \frac{(0.75v_i + 5.6)}{v_i}$
Terrain	Not complex according to IEC 61400-12-1
Upflow β [°]	-2° ≤ β ≤ +2°
Grid frequency [Hz]	± 0.5 Hz

Other considerations: Clean rotor blades, undisturbed air flow, turbine operated within nominal limits according to the Electrical Specification.

The calculated Ct curve data are valid for air densities as stated below, clean rotor blades, substantially horizontal, undisturbed air flow, normal turbulence intensity and normal wind shear.

C _T [-]	Air Density [kg/m ³]									
	1.225	1.06	1.09	1.12	1.15	1.18	1.21	1.24	1.27	
3	0.8914	0.8914	0.8914	0.8914	0.8914	0.8914	0.8914	0.8914	0.8914	0.8914
4	0.8422	0.8422	0.8422	0.8422	0.8422	0.8422	0.8422	0.8422	0.8422	0.8422
5	0.8214	0.8214	0.8214	0.8214	0.8214	0.8214	0.8214	0.8214	0.8214	0.8214
6	0.8191	0.8191	0.8191	0.8191	0.8191	0.8191	0.8191	0.8191	0.8191	0.8191
7	0.8184	0.8184	0.8184	0.8184	0.8184	0.8184	0.8184	0.8184	0.8184	0.8184
8	0.8023	0.8026	0.8026	0.8026	0.8025	0.8025	0.8024	0.8022	0.8019	
9	0.7299	0.7388	0.7381	0.7370	0.7356	0.7338	0.7313	0.7283	0.7247	
10	0.5966	0.6338	0.6288	0.6231	0.6164	0.6091	0.6009	0.5921	0.5829	
11	0.4521	0.5088	0.4991	0.4890	0.4785	0.4680	0.4574	0.4468	0.4364	
12	0.3386	0.3924	0.3819	0.3718	0.3618	0.3523	0.3431	0.3342	0.3258	
13	0.2595	0.3023	0.2936	0.2853	0.2774	0.2700	0.2629	0.2562	0.2498	
14	0.2044	0.2374	0.2306	0.2242	0.2181	0.2124	0.2070	0.2018	0.1970	
15	0.1647	0.1906	0.1853	0.1802	0.1755	0.1710	0.1668	0.1627	0.1589	
16	0.1353	0.1560	0.1517	0.1477	0.1439	0.1403	0.1369	0.1337	0.1306	
17	0.1128	0.1297	0.1262	0.1229	0.1198	0.1169	0.1141	0.1115	0.1090	
18	0.0953	0.1093	0.1064	0.1037	0.1011	0.0987	0.0964	0.0942	0.0921	
19	0.0813	0.0931	0.0907	0.0884	0.0862	0.0842	0.0823	0.0804	0.0787	
20	0.0699	0.0799	0.0779	0.0759	0.0741	0.0724	0.0707	0.0692	0.0677	
21	0.0603	0.0688	0.0670	0.0654	0.0638	0.0624	0.0610	0.0597	0.0584	
22	0.0519	0.0591	0.0576	0.0562	0.0549	0.0537	0.0525	0.0514	0.0503	
23	0.0446	0.0506	0.0494	0.0482	0.0471	0.0461	0.0451	0.0441	0.0432	
24	0.0383	0.0434	0.0424	0.0414	0.0404	0.0396	0.0387	0.0379	0.0372	
25	0.0331	0.0374	0.0365	0.0357	0.0349	0.0342	0.0334	0.0328	0.0321	
26	0.0289	0.0326	0.0318	0.0311	0.0304	0.0298	0.0292	0.0286	0.0280	
27	0.0255	0.0288	0.0281	0.0275	0.0269	0.0263	0.0258	0.0253	0.0248	

Standard Acoustic Emission

Noise Level (LW): Values reported correspond to the average estimated Sound Power Level emitted by the WTG at hub height, called LW in TS IEC-61400-14. LW values are expressed in dB(A). To obtain LWd value, as defined in IEC-61400-14, it must be applied a 2 dB increase to LW.

dB(A): LW is expressed in decibels applying the "A" filter as required by IEC.

Noise generated at standard power operation mode LW is **107.8 dB(A)**.

Noise values included in the present document correspond to the wind turbine configuration equipped with noise reduction add-ons attached to the blade.

SG 4.5-145	
Wind Speed [m/s]	LW [dB(A)]
3	95.1
3.5	95.1
4	95.1
4.5	95.1
5	95.5
5.5	97.6
6	99.7
6.5	101.5
7	103.2
7.5	104.7
8	106.2
8.5	107.6
9	107.8
9.5	107.8
10	107.8
10.5	107.8
11	107.8
11.5	107.8
12	107.8
12.5	107.8
13	107.8
13.5	107.8
14	107.8
14.5	107.8
15	107.8

Noise values included in the present document correspond to the wind turbine configuration equipped with noise reduction add-ons attached to the blade.

Noise Reduction System (NRS) operational modes

The Noise Reduction System NRS is an optional module available with the basic SCADA configuration and it therefore requires the presence of a SGRE SCADA system to work.

The purpose of this system is to limit the noise emitted by any of the functioning turbines and thereby comply with local regulations regarding noise emissions. This allows wind farms to be located close to urban areas, limiting the environmental impact that they imply.

Noise control is achieved through reducing the active power and rotational speed of the wind turbine. This reduction is dependent on the wind speed.

The task of the Noise Reduction System is to control the noise settings of each turbine to the most appropriate level at all times, in order to keep the noise emissions within the limits allowed.

In order to do this, the SCADA control has to consider the wind speed of each turbine, its direction, and a configured schedule/calendar.

There can be up to 8 low noise modes, besides the full operation one. Noise levels corresponding to each mode are the following:

Mode:	FP	N1	N2	N3	N4	N5	N6	N7	N8
Noise Level [dB(A)]	107.8	105.7	105.2	103.7	102.7	101.7	99.9	99	98


Noise values included in the present document correspond to the wind turbine configuration equipped with noise reduction add-ons attached to the blade.

Depending on the type of tower selected, some of the low noise modes defined above may not be compatible. In the following table, feasibility of low noise modes vs tower is presented. Low noise modes feasibility vs other tower designs will be analyzed upon request.

SG 4.5-145	N1	N2	N3	N4	N5	N6	N7	N8
H= 90 m (Steel, baseline design)	Yes							
H= 107.5 m (Steel, baseline design)	Yes							
H= 127.5 m (Steel, baseline design)	No	No	No	No	Yes	Yes	Yes	Yes

Next table presents the power production as a function of the horizontal wind speed measured at hub height for different noise reduction mode settings.

P [kW]	Low Noise Operation Mode							
	Wind Speed [m/s]	N1 105.7 dB(A)	N2 105.2 dB(A)	N3 103.7 dB(A)	N4 102.7 dB(A)	N5 101.7 dB(A)	N6 99.9 dB(A)	N7 99.0 dB(A)
3	57	57	57	57	57	57	57	57
4	243	243	243	243	243	243	243	243
5	556	556	556	556	556	556	556	555
6	1010	1010	1010	1009	1007	995	981	961
7	1638	1636	1623	1604	1574	1490	1432	1366
8	2422	2404	2320	2240	2147	1951	1837	1717
9	3198	3134	2958	2814	2658	2341	2168	1994
10	3700	3581	3378	3207	3029	2647	2424	2202
11	3897	3747	3552	3382	3214	2851	2612	2350
12	3950	3790	3602	3435	3276	2951	2751	2466
13	3961	3798	3612	3447	3292	2987	2854	2554
14	3963	3800	3615	3449	3295	2997	2920	2607
15	3964	3800	3615	3450	3296	2999	2953	2631
16	3964	3800	3615	3450	3296	3000	2967	2641
17	3964	3800	3615	3450	3296	3000	2972	2644
18	3964	3800	3615	3450	3296	3000	2973	2645
19	3963	3800	3615	3450	3296	3000	2974	2645
20	3960	3799	3615	3450	3296	3000	2974	2645
21	3948	3794	3614	3450	3296	3000	2974	2645
22	3919	3779	3609	3449	3296	3000	2974	2645
23	3865	3748	3597	3446	3296	3000	2974	2645
24	3789	3700	3574	3439	3296	3000	2974	2645
25	3702	3638	3542	3429	3296	3000	2974	2645
26	3613	3571	3503	3416	3296	3000	2974	2645
27	3537	3511	3466	3402	3296	3000	2974	2645



Next table presents the C_t as a function of the horizontal wind speed measured at hub height for different noise reduction mode settings. The calculated C_t curve data are valid for clean rotor blades, substantially horizontal, undisturbed air flow, normal turbulence intensity and normal wind shear.

$C_t [-]$	Low Noise Operation Mode							
	Wind Speed [m/s]	N1 105.7 dB(A)	N2 105.2 dB(A)	N3 103.7 dB(A)	N4 102.7 dB(A)	N5 101.7 dB(A)	N6 99.9 dB(A)	N7 99.0 dB(A)
3	0.8920	0.8920	0.8920	0.8920	0.8920	0.8920	0.8920	0.8920
4	0.8431	0.8431	0.8431	0.8431	0.8431	0.8431	0.8431	0.8431
5	0.8197	0.8197	0.8197	0.8197	0.8196	0.8190	0.8173	0.8129
6	0.8194	0.8194	0.8186	0.8160	0.8097	0.7816	0.7564	0.7242
7	0.8160	0.8129	0.7920	0.7675	0.7357	0.6646	0.6234	0.5810
8	0.7705	0.7568	0.7015	0.6587	0.6148	0.5353	0.4945	0.4544
9	0.6648	0.6431	0.5829	0.5409	0.4998	0.4262	0.3892	0.3536
10	0.5228	0.5002	0.4584	0.4276	0.3972	0.3381	0.3067	0.2763
11	0.3906	0.3724	0.3470	0.3267	0.3071	0.2672	0.2429	0.2176
12	0.2931	0.2796	0.2630	0.2491	0.2360	0.2100	0.1943	0.1738
13	0.2258	0.2158	0.2037	0.1935	0.1840	0.1658	0.1574	0.1408
14	0.1787	0.1710	0.1617	0.1538	0.1465	0.1326	0.1286	0.1150
15	0.1445	0.1384	0.1310	0.1247	0.1189	0.1079	0.1059	0.0947
16	0.1190	0.1140	0.1079	0.1028	0.0981	0.0891	0.0879	0.0786
17	0.0994	0.0953	0.0903	0.0860	0.0821	0.0747	0.0738	0.0660
18	0.0841	0.0807	0.0764	0.0729	0.0696	0.0633	0.0626	0.0561
19	0.0719	0.0691	0.0654	0.0624	0.0596	0.0543	0.0537	0.0481
20	0.0621	0.0597	0.0566	0.0540	0.0515	0.0470	0.0464	0.0417
21	0.0540	0.0520	0.0493	0.0471	0.0450	0.0410	0.0405	0.0364
22	0.0472	0.0456	0.0433	0.0414	0.0396	0.0361	0.0357	0.0321
23	0.0413	0.0400	0.0383	0.0366	0.0351	0.0320	0.0316	0.0285
24	0.0361	0.0353	0.0340	0.0327	0.0313	0.0286	0.0282	0.0254
25	0.0318	0.0312	0.0303	0.0293	0.0282	0.0257	0.0254	0.0229
26	0.0281	0.0278	0.0272	0.0265	0.0255	0.0233	0.0230	0.0208
27	0.0251	0.0249	0.0246	0.0241	0.0233	0.0213	0.0210	0.0190

The table below contains the noise levels as a function of the horizontal wind speed measured at hub height for different noise reduction mode settings.

Noise [dB(A)]	Low Noise Operation Mode							
	Wind Speed [m/s]	N1 105.7 dB(A)	N2 105.2 dB(A)	N3 103.7 dB(A)	N4 102.7 dB(A)	N5 101.7 dB(A)	N6 99.9 dB(A)	N7 99.0 dB(A)
3	95.1	95.1	95.1	95.1	95.1	95.1	95.1	95.1
3.5	95.1	95.1	95.1	95.1	95.1	95.1	95.1	95.1
4	95.1	95.1	95.1	95.1	95.1	95.1	95.1	95.1
4.5	95.1	95.1	95.1	95.1	95.1	95.1	95.1	95.1
5	95.5	95.5	95.5	95.5	95.5	95.5	95.5	95.5
5.5	97.6	97.6	97.6	97.6	97.6	97.6	97.6	97.6
6	99.7	99.7	99.7	99.7	99.7	99.7	99.0	98.0
6.5	101.5	101.5	101.5	101.5	101.5	99.9	99.0	98.0
7	103.2	103.2	103.2	102.7	101.7	99.9	99.0	98.0
7.5	104.7	104.7	103.7	102.7	101.7	99.9	99.0	98.0
8	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
8.5	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
9	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
9.5	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
10	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
10.5	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
11	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
11.5	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
12	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
12.5	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
13	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
13.5	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
14	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
14.5	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0
15	105.7	105.2	103.7	102.7	101.7	99.9	99.0	98.0

Noise values included in the present document correspond to the wind turbine configuration equipped with noise reduction add-ons attached to the blade.

The 1/3 octave band noise spectra expressed as A-weighted sound power level for a given frequency band is shown below for 12m/s at hub height, for the standard power operation setting as well as the low noise modes.

1/3 octave band, center frequency [Hz]	Noise [dB(A)]								
	Standard Power 4.5MW	N1	N2	N3	N4	N5	N6	N7	N8
	107.8 dB(A)	105.7 dB(A)	105.2 dB(A)	103.7 dB(A)	102.7 dB(A)	101.7 dB(A)	99.9 dB(A)	99.0 dB(A)	98.0 dB(A)
10	46.1	46.1	46.1	46.1	46.1	46.1	46.1	46.1	46.1
12.5	51.8	51.8	51.8	51.8	51.8	51.8	51.8	51.7	51.7
16	57.5	57.5	57.5	57.4	57.4	57.4	57.3	57.3	57.3
20	62.9	62.8	62.8	62.7	62.6	62.6	62.5	62.4	62.3
25	67.5	67.4	67.3	67.2	67	66.9	66.7	66.6	66.5
31.5	72.2	72	71.9	71.7	71.4	71.3	71	70.8	70.7
40	76.4	76.1	76	75.7	75.3	75.1	74.6	74.4	74.2
50	81	80.5	80.4	80.1	79.5	79.2	78.6	78.3	78
63	85.3	84.7	84.6	84.1	83.3	82.9	82.2	81.8	81.4
80	87.8	87	86.9	86.3	85.3	84.8	83.8	83.4	82.8
100	89.7	88.8	88.5	87.9	86.6	86	84.8	84.2	83.6
125	91.2	90.1	89.8	89	87.5	86.7	85.3	84.6	83.8
160	92.2	90.9	90.5	89.5	87.7	86.8	85.2	84.3	83.4
200	93.4	91.2	90.7	89.1	88.1	87.1	85.2	84.2	83.2
250	94.9	92.7	92.2	90.6	89.6	88.6	86.7	85.7	84.7
315	95.3	93.1	92.6	91	90	89	87.1	86.1	85.1
400	95	92.8	92.3	90.7	89.7	88.7	86.8	85.8	84.8
500	95.1	92.9	92.4	90.8	89.8	88.8	86.9	85.9	84.9
630	96.7	94.5	94	92.4	91.4	90.4	88.5	87.5	86.5
800	96.5	94.3	93.8	92.2	91.2	90.2	88.3	87.3	86.3
1000	97.5	95.3	94.8	93.2	92.2	91.2	89.3	88.3	87.3
1250	98.2	96	95.5	93.9	92.9	91.9	90	89	88
1600	98.1	95.9	95.4	93.8	92.8	91.8	89.9	88.9	87.9
2000	97	94.8	94.3	92.7	91.7	90.7	88.8	87.8	86.8
2500	95.6	93.4	92.9	91.3	90.3	89.3	87.4	86.4	85.4
3150	93.4	91.2	90.7	89.1	88.1	87.1	85.2	84.2	83.2
4000	90.3	88.1	87.6	86	85	84	82.1	81.1	80.1
5000	86	83.8	83.3	81.7	80.7	79.7	77.8	76.8	75.8
6300	80.8	78.6	78.1	76.5	75.5	74.5	72.6	71.6	70.6
8000	75	72.8	72.3	70.7	69.7	68.7	66.8	65.8	64.8
10000	70.4	68.2	67.7	66.1	65.1	64.1	62.2	61.2	60.2

Further information about noise spectra, including other wind speeds, is available upon request.

Noise values included in the present document correspond to the wind turbine configuration equipped with noise reduction add-ons attached to the blade.

Electrical Specifications

Nominal output and grid conditions

Nominal power	4500 kW
Nominal voltage	690 V
Power factor correction	Frequency converter control
Power factor range.....	0.9 capacitive to 0.9 inductive at nominal balanced voltage

Generator

Type	DFIG Asynchronous
Maximum power.....	4650 kW

Nominal speed	1120 rpm-6p (50Hz)
	1344 rpm-6p (60Hz)

Generator Protection

Insulation class.....	Stator F/H Rotor F/H
Winding temperatures	6 Pt 100 sensors
Bearing temperatures.....	2 Pt 100
Slip Rings	1 Pt 100
Grounding brush.....	On side no coupling

Generator Cooling

Cooling system.....	Liquid cooling
Internal ventilation	Air
Control parameter	Winding, Liquid, Bearings temperature

Frequency Converter

Operation	4Q B2B Partial Load
Switching	PWM
Switching freq., grid side	2.5 kHz
Cooling	Liquid/Air

Main Circuit Protection

Short circuit protection.....	Circuit breaker
Surge arrester	varistors

Peak Power Levels

10 min average	Limited to nominal
----------------------	--------------------

Grid Requirements

Nominal grid frequency	50 or 60 Hz
Minimum voltage.....	90 % of nominal
Maximum voltage.....	112 % of nominal
Minimum frequency.....	94 % of nominal
Maximum frequency.....	106 % of nominal
Maximum voltage imbalance (negative sequence of component voltage).	≤5 %
Max short circuit level at controller's grid	
Terminals (690 V)	67 kA

Power Consumption from Grid (approximately)

At stand-by, No yawing	10 kW
At stand-by, yawing.....	41 kW

Controller back-up

UPS Controller system.....	Online UPS, Li battery
Back-up time	1 min
Back-up time Scada.....	24 h

Transformer Requirements


Transformer impedance requirement.....	8.0 % -9.5%
Secondary voltage	690 V
Vector group	Dyn 11 or Dyn 1 (star point earthed)

Earthing Requirements

Earthing system	Acc. to IEC62305-3 ED 1.0:2006
Foundation reinforcement..	Must be connected to earth electrodes
Foundation terminals	Acc. to SGRE Standard
HV connection.....	HV cable shield shall be connected to earthing system

All data are subject to tolerances in accordance with IEC.

Simplified Single Line Diagram



Transformer Specifications ECO 30 kV*

Transformer

Type	Dry type
Nominal power	5350 kVA @nominal voltage +/- 10 %
Nominal voltage	30/0.69 kV
Frequency	50 Hz
Transformer impedance	10.7%
Loss ($P_0 / P_{n120^\circ C}$)	4.8/39 kW
Vector group	Dyn11
Offload tap changer	+/- 2.5% / +/- 5 %
Standard.....	IEC 60076 ECO Design Directive

Transformer Cooling

Cooling system.....	AF
Ventilation	Forced ventilation of the transformer room
Control parameter.....	Winding & Magnetic core temperature

Transformer Monitoring

Winding Temperature.....	PT100 sensor
Mag. Core temperature...	PT100 sensor

Transformer Earthing

Star point	The star point of the transformer must be connected to earth
------------------	--

Transformer Specifications 34.5 kV*

Transformer

Type	Dry type
Nominal power	5500 kVA @nominal voltage +12/-10 %
Nominal voltage	34.5/0.69 kV
Frequency	60 Hz
Transformer impedance	9.5%
Loss ($P_0 / P_{n120^\circ C}$)	8/45 kW
Vector group	Dyn1
Offload tap changer	+/- 2.5% / +/- 5 %
Standard.....	IEEE std C57.12

Transformer Cooling

Cooling system.....	AF
Ventilation	Forced ventilation of the transformer room
Control parameter.....	Winding & Magnetic core temperature

Transformer Monitoring

Winding Temperature.....	PT100 sensor
Mag. Core temperature...	PT100 sensor

Transformer Earthing

Star point	The star point of the transformer must be connected to earth
------------------	--

All data are subject to tolerances in accordance with IEC.

*Example for an ECO 30kV and 34.5kV transformers. For other Medium Voltage transformers, consult with SGRE

Switchgear Specifications

The installation of a switchgear is an option available upon request. The minimum requirements that must be complied with, from the point of view of electrical protection, are:

Switchgear Specification (38 kV)

Technical Data for Switchgear

Switchgear

Type	CGM.3
Rated voltage	38 kV
Operating voltage	30 - 36 kV
Rated current	630 A
Short time withstand current	20 kA/1s
Peak withstand current	50 kA
Power frequency withstand voltage	70 kV
Lightning withstand voltage	170 kV
Insulating medium	SF ₆
Switching medium	vacuum
Consist of	1, 2 or 3 panels
Grid cable feeder	Load break switch or direct cable riser
Circuit breaker feeder	Circuit breaker
Degree of protection, vessel	IPX8
Degree of protection, front cover	IP2XD
Degree of protection, LV Comp.	IP2XD
Internal arc classification IAC:	A FL 20 kA 1s
Pressure relief	Down
Standard	IEC 62271
Temperature range	-30°C to +40°C

Grid Cable feeder

Rated current , cubicle	630 A
Rated current , load breaker	630 A
Short time withstand current	20 kA/1s
Short circuit making current	50 kA/1s
Three position switch	Closed, open, earthed
Switch mechanism	Spring operated
Control	Local
Voltage detection system	Capacitive

Circuit breaker feeder

Rated current , Cubicle	630 A
Rated current , circuit breaker	630 A
Short time withstand current	20 kA/1s
Short circuit making current	50 kA/1s
Short circuit breaking current	20 kA/1s
Three position CB switch	Closed, open, earthed
Switch mechanism	Spring operated
Tripping mechanism	Stored energy
Motor voltage	Under request
Control	Local
Coil for external trip	230 V AC
Voltage detection system	Capacitive

Protection

Over-current relay	Ekor.wtp
Functions	50/51 50N/51N
Power supply	Dual (Self & Aux. powered)
Current transformer	300/1A; 0.18VA, Cl. 5P20

Interface- MV Cables

Grid cable feeder	630A bushings type C M16
Cable entry	Max 2 feeder cables
Cable clamp size (cable outer diameter)	From bottom up to 48mm
Circuit breaker feeder	630 A bushings type C M16
Cable entry	From bottom

Interface to turbine control

Breaker status	1 NO + 1 NC contacts
Insulation supervision	Under request
External trip	230 V AC

All data are subject to tolerances in accordance with IEC.

Example for a 38 kV Switchgear. For other Medium Voltage variants or different grounding systems, contact SGRE.

Preliminary Foundation Loads

Detailed information about foundation loads will be available upon request.

Tower Dimensions

SG 4.5-145 presents a tower portfolio with hub heights ranging from 90m to 157.5m. Information for the baseline towers is included below:

- Tower hub height 90m. Baseline design.

TOWER HH 90 SG 4.5-145				
	Section 1 (bottom)	Section 2	Section 3	Section 4 (top)
External diameter upper flange (m)	4.030	4.023	4.017	3.503
External diameter lower flange (m)	4.278	4.030	4.023	4.017
Section's height (m)	18.040	23.960	21.000	25.000
Section structural weight (kgs)	69105.0	64484.8	40171.5	43050.0
Section total weight (kgs)	70837.1	65563.0	41116.5	44175.0
Total tower height (m)	88.000			
Total tower weight (kg)	221691.6			

- Tower hub height 107.5m. Baseline design.

TOWER HH 107.5 SG 4.5-145					
	Section 1 (bottom)	Section 2	Section 3	Section 4	Section 5 (top)
External diameter upper flange (m)	4.4365	4.4290	4.4215	4.4170	3.5030
External diameter lower flange (m)	4.6780	4.4365	4.4290	4.4215	4.4170
Section's height (m)	13.325	18.180	19.995	27.000	27.000
Section structural weight (kgs)	68911.6	68791.4	56596.8	56356.5	48198.1
Section total weight (kgs)	70694.8	69609.5	57496.6	57571.5	49413.1
Total tower height (m)	105.510				
Total tower weight (kg)	304785.5				

- Tower hub height 127.5m. Baseline design.

TOWER HH 127.5 SG 4.5-145						
	Section 1 (bottom)	Section 2	Section 3	Section 4	Section 5	Section 6 (top)
External diameter upper flange (m)	4.605	4.4325	4.429	4.125	3.819	3.503
External diameter lower flange (m)	4.680	4.605	4.4325	4.429	4.125	3.819
Section's height (m)	13.510	17.595	19.975	22.980	24.440	27.000
Section structural weight (kgs)	74573.9	74376.5	69994.0	65147.9	52271.2	46346.0
Section total weight (kgs)	76523.3	75168.2	70892.9	66182.0	53371.0	47561.0
Total tower height (m)	125.510					
Total tower weight (kg)	389698.5					


Information about other tower heights will be available upon request.

Estimated Foundation Design

Hub height: 107.5 m

Volumes

Concrete volume ~559.61 m³, C35/45 – C45/55 MPa
Reinforcement steel ~52007 kg, B 500 S



FOUNDATION GEOMETRY	
øslab= Slab diameter [m]	20.80
Hout= Outer egde height [m]	0.50
Hin= Inner edge height [m]	3.0
øped= Pedestal diameter [m]	5.50
Hped= Pedestal height [m]	0.50

The estimated foundation design is based on the following assumptions:

- Gravity based flat foundation without buoyancy
- Specific weight of backfill 18.0 kN/m³
- Friction angle 30.0°


Additional factors that may impact the foundation design:

Soil conditions, country, designer practice, national codes and standards.

Hub height: 127.5 m

Volumes

Concrete volume ~635.09 m³, C35/45 – C50/60 MPa
Reinforcement steel ~63240 kg, B 500 S



FOUNDATION GEOMETRY	
øslab= Slab diameter [m]	22.30
Hout= Outer egde height [m]	0.50
Hin= Inner edge height [m]	3.0
øped= Pedestal diameter [m]	5.50
Hped= Pedestal height [m]	0.50

The estimated foundation design is based on the following assumptions:


- Gravity based flat foundation without buoyancy
- Specific weight of backfill 18.0 kN/m³
- Friction angle 30.0°

Additional factors that may impact the foundation design:

Soil conditions, country, designer practice, national codes and standards.

Although the standard and most common foundation concept is the previously shown circular tapered slab, it is also possible to design, based on site specific conditions, the optimized “8 Walls foundation”.

See figure below:



Preliminary Grid Performance Specification, 50 Hz

General

This document describes the grid performance of the SG 4.5-145, 50 Hz wind turbine. Siemens Gamesa Renewable Energy (SGRE) will provide wind turbine technical data for the developer to use in the design of the wind power plant and the evaluation of requirements compliance. The developer will be responsible for the evaluation and ensuring that the requirements are met for the wind power plant.

The capabilities described in this document are based on the assumption that the electrical network is designed to be compatible with operation of the wind turbine. SGRE will provide a document with guidance to perform an assessment of the network's compatibility.

Fault Ride Through (FRT) Capability

The wind turbine is capable of operating when voltage transient events occur on the interconnecting transmission system above and below the standard voltage lower limits and time slot according to Figure 1 and Figure 2.

This performance assumes that the installed amount of wind turbines is in the right proportion to the strength of the grid, which means that the short circuit ratio (Sk/Sn) and the X/R ratio of the grid at the wind turbine transformer terminals must be adequate.

Evaluation of the wind turbine's fault ride through capability in a specific system must be based on simulation studies using the specific network model and a dynamic wind turbine model provided by SGRE in PSS/E. This model is a reduced order model, suitable for balanced simulations with time steps between 4-10 ms.

The standard voltage limits for the SG 4.5-145, 50 Hz wind turbine are presented in Figure 1 between 180 - 1000 seconds and in Figure 2 between 0.4 – 100 seconds.




Figure 1. Lower voltage limits for SG 4.5-145, 50 Hz wind turbine in the range of 0-1000 seconds. The nominal voltage is 690 V (i.e. 1 p.u.).




Figure 2. Upper voltage limits for SG 4.5-145, 50 Hz wind turbine in the range of 0-10 seconds. The nominal voltage is 690 V (i.e. 1 p.u.).

Power Factor (Reactive Power) Capability

The wind turbine is able to operate in a power factor range of 0.9 leading to 0.9 lagging at the low voltage side of the wind turbine transformer, at nominal balanced voltage and nominal frequency. The control mode for the wind turbine is with reactive power set-points.

Supervisory Control and Data Acquisition (SCADA) Capability

The SGRE SCADA system has the capability to transmit and receive instructions from the transmission system provider for system reliability purposes depending on the configuration of the SCADA system. The project specific SCADA requirements must be specified in detail for design purposes.

Frequency Capability

The wind turbine is able to operate in the frequency range between 47 Hz and 53 Hz.

Voltage Capability

The voltage operation range for the wind turbine is between 90% and 112% of nominal voltage at the low voltage side of the wind turbine transformer. The voltage can be up to 130% for 60ms, see Figure 2. The wind turbine's target voltage shall stay between 95% and 105% in order to support the best possible performance by staying within the operation limits.

Flicker and Harmonics

Flicker and Harmonics values will be provided in the power quality measurement report extract in accordance with IEC 61400-21 Edition 2.

Reactive Power -Voltage Control

The power plant controller can operate in four different modes:

- Q Control – In this mode reactive power is controlled at the point of interconnection, according to a reactive power reference
- V Control – Voltage is directly controlled at the point of interconnection, according to a voltage reference
- V-Q static – Voltage is controlled at the point of interconnection, by means of a pre-defined voltage – reactive power characteristic
- Power factor (cosphi) control – Power factor is controlled at the point of interconnection, according to a power factor reference

The SCADA system receives feedback/measured values from the Point Of Interconnection depending on the control mode it is operating. The wind power plant controller then compares the measured values against the target levels and calculates the reactive power reference. Finally, reactive power references are distributed to each individual wind turbine. The wind turbine's controller responds to the latest reference from the SCADA system and will generate the required reactive power accordingly from the wind turbine.

Frequency Control

The frequency control is managed by the SCADA system together with the wind turbine controller. The wind power plant frequency control is carried out by the SCADA system which distributes active power set-points to each individual wind turbine, to the controllers. The wind turbine controller responds to the latest reference from the SCADA system and will maintain this active power locally.

All data are subject to tolerances in accordance with IEC.

Preliminary Grid Performance Specification, 60 Hz

General

This document describes the grid performance of the SG 4.5-145, 60 Hz wind turbine. Siemens Gamesa Renewable Energy (SGRE) will provide wind turbine technical data for the developer to use in the design of the wind power plant and the evaluation of requirements compliance. The developer will be responsible for the evaluation and ensuring that the requirements are met for the wind power plant.

The capabilities described in this document are based on the assumption that the electrical network is designed to be compatible with operation of the wind turbine. SGRE will provide a document with guidance to perform an assessment of the network's compatibility.

Fault Ride Through (FRT) Capability

The wind turbine is capable of operating when voltage transient events occur on the interconnecting transmission system above and below the standard voltage lower limits and time slot according to Figure 3 and Figure 4.

This performance assumes that the installed amount of wind turbines is in the right proportion to the strength of the grid, which means that the short circuit ratio (S_k/S_n) and the X/R ratio of the grid at the wind turbine transformer terminals must be adequate.

Evaluation of the wind turbine's fault ride through capability in a specific system must be based on simulation studies using the specific network model and a dynamic wind turbine model provided by SGRE in PSS/E. This model is a reduced order model, suitable for balanced simulations with time steps between 4-10 ms.

The standard voltage limits for the SG 4.5-145, 60 Hz wind turbine are presented in Figure 3 between 180 - 1000 seconds and in Figure 4 between 0.4 – 100 seconds.




Figure 3. Lower voltage limits for SG 4.5-145, 60 Hz wind turbine in the range of 0-1000 seconds. The nominal voltage is 690 V (i.e. 1 p.u.).




Figure 4. Upper voltage limits for SG 4.5-145, 60 Hz wind turbine in the range of 0-10 seconds. The nominal voltage is 690 V (i.e. 1 p.u.).

Power Factor (Reactive Power) Capability

The wind turbine is able to operate in a power factor range of 0.9 leading to 0.9 lagging at the low voltage side of the wind turbine transformer, at nominal balanced voltage and nominal frequency. The control mode for the wind turbine is with reactive power set-points.

Supervisory Control and Data Acquisition (SCADA) Capability

The SGRE SCADA system has the capability to transmit and receive instructions from the transmission system provider for system reliability purposes depending on the configuration of the SCADA system. The project specific SCADA requirements must be specified in detail for design purposes.

Frequency Capability

The wind turbine is able to operate in the frequency range between 56.4 Hz and 63.6 Hz.

Voltage Capability

The voltage operation range for the wind turbine is between 90% and 112% of nominal voltage at the low voltage side of the wind turbine transformer. The voltage can be up to 130% for 60ms, see Figure 4. The wind turbine's target voltage shall stay between 95% and 105% in order to support the best possible performance by staying within the operation limits

Flicker and Harmonics

Flicker and Harmonics values will be provided in the power quality measurement report extract in accordance with IEC 61400-21 Edition 2.

Reactive Power -Voltage Control

The power plant controller can operate in four different modes:

- Q Control – In this mode reactive power is controlled at the point of interconnection, according to a reactive power reference
- V Control – Voltage is directly controlled at the point of interconnection, according to a voltage reference
- V-Q static – Voltage is controlled at the point of interconnection, by means of a pre-defined voltage – reactive power characteristic
- Power factor (cosphi) control – Power factor is controlled at the point of interconnection, according to a power factor reference

The SCADA system receives feedback/measured values from the Point Of Interconnection depending on the control mode it is operating. The wind power plant controller then compares the measured values against the target levels and calculates the reactive power reference. Finally, reactive power references are distributed to each individual wind turbine. The wind turbine's controller responds to the latest reference from the SCADA system and will generate the required reactive power accordingly from the wind turbine.

Frequency Control

The frequency control is managed by the SCADA system together with the wind turbine controller. The wind power plant frequency control is carried out by the SCADA system which distributes active power set-points to each individual wind turbine, to the controllers. The wind turbine controller responds to the latest reference from the SCADA system and will maintain this active power locally.

All data are subject to tolerances in accordance with IEC.

Reactive Power Capability, 50 Hz

General

This document describes the reactive power capability of SG 4.5-145, 50 Hz wind turbines during active power production. SG 4.5-145 wind turbines are equipped with a B2B Partial load frequency converter which allows the wind turbine to operate in a wide power factor range.

Reactive Power Capability Curves

The reactive power capability for the wind turbine at the LV side of the wind turbine transformer will be presented in the following Figures.

Figure 5 shows the reactive power capability on the LV side of the wind turbine depending on the generated power at LV terminals.

Figure 6 shows the reactive power capability on the LV side of the wind turbine transformer at various voltages between 0.90 p.u. and 1.13 p.u. at the LV terminals.

Figure 7 includes reactive power capability at no wind ($Q_w P_0$).

The SCADA can send voltage references to the wind turbine in the range of 0.92 p.u. to 1.08 p.u. The wind power plant should be designed to maintain the wind turbine voltage references between 0.95 p.u. and 1.05 p.u. during steady state operation.

The tables and figures assume that the phase voltages are balanced, and that the grid operational frequency and component values are nominal. Unbalanced voltages will decrease the reactive power capability. Component tolerances were not considered in determining curve parameters. Instead, the curves and data are subject to an overall tolerance of $\pm 5\%$ of the rated power.

The reactive power capability presented in this document is the net capability and accounts for the contribution from the wind turbine auxiliary system, the reactor and the filter.

The reactive power capability described is valid while operating the wind turbine within the limits specified in the Design Climatic Conditions.




Figure 5: Reactive power capability curves, 50 Hz wind turbine, at LV side of wind turbine transformer.




Figure 6. Reactive power capability versus voltage.




Figure 7. Reactive power capability at no wind (QwP0)

All data are subject to tolerances in accordance with IEC.

Reactive Power Capability, 60 Hz

General

This document describes the reactive power capability of SG 4.5-145, 60 Hz wind turbines during active power production. SG 4.5-145 wind turbines are equipped with a B2B Partial load frequency converter which allows the wind turbine to operate in a wide power factor range.

Reactive Power Capability Curves

The reactive power capability for the wind turbine at the LV side of the wind turbine transformer will be presented in the following Figures.

Figure 8 shows the reactive power capability on the LV side of the wind turbine depending on the generated power at LV terminals.

Figure 9 shows the reactive power capability on the LV side of the wind turbine transformer at various voltages between 0.90 p.u. and 1.13 p.u. at the LV terminals.

Figure 10 includes reactive power capability at no wind (Q_{wP0}).

The SCADA can send voltage references to the wind turbine in the range of 0.92 p.u. to 1.08 p.u. The wind power plant should be designed to maintain the wind turbine voltage references between 0.95 p.u. and 1.05 p.u. during steady state operation.

The tables and figures assume that the phase voltages are balanced, and that the grid operational frequency and component values are nominal. Unbalanced voltages will decrease the reactive power capability. Component tolerances were not considered in determining curve parameters. Instead, the curves and data are subject to an overall tolerance of $\pm 5\%$ of the rated power.

The reactive power capability presented in this document is the net capability and accounts for the contribution from the wind turbine auxiliary system, the reactor and the filter.

The reactive power capability described is valid while operating the wind turbine within the limits specified in the Design Climatic Conditions.




Figure 8. Reactive power capability curves, 60 Hz wind turbine, at LV side of wind turbine transformer




Figure 9. Reactive power capability versus voltage




Figure 10. Reactive power capability at no wind (QwP0).

SCADA, System Description

General

This is a general description of the Siemens Gamesa Renewable Energy (SGRE) SCADA System.

WindNet® PRO SCADA is a wind farm management tool. Overall, the SCADA enables:

- Supervising, monitoring and/or controlling not only wind turbines in a given wind farm, but also other components installed in the wind farm such as meteorological masts, substations, measuring devices, etc.
- Storing and managing information, which provides an advanced capacity to generate reports.
- Connecting to control centers or higher level management systems.
- Wind farm power regulation for both active as well as reactive power.
- Wind farm electricity generation based on environmental conditions.

In short, the SCADA system is an indispensable communications gateway for incoming and outgoing wind farm data.

Main Features

The WindNet® PRO SCADA system has the following main features:

- Wind turbine supervision and control.
- Meteorological mast supervision.
- Supervision and control of the wind farm's feed-in substation.
- Alarms and notifications SGRE management.
- Reporting for technical and economic wind farm exploitation.
- Access security via user and profile management.
- Multiple-wind farm management capacity enabling various wind farms to be managed from a single SCADA installation. Optimized SQL database for data management.
- Integration with the SGRE preventive maintenance system (PMS)
- Integration with SGRE support systems for managing payment features
- Additionally, the SGRE SCADA system has the following optional features:
- Data server for access and/or integration in upper systems: OPC-DA server, OPC-HDA server, MODBUS client/server and DNP3 client/server.
- Integration of the SGRE Power Manager tool, which includes the active power/frequency regulating tools and reactive power/voltage regulation for the wind farm (up to two points of connection for each SCADA installation)
- NRS® (Noise Reduction System) to safeguard the acoustic integrity of the area based on wind direction and time
- Shadow Control System to prevent the undesired effects of shadows in residential areas near the wind farm
- Wake Cancellation System for protecting wind turbines from intense turbulence based on wind direction
- Ice Detection System for protecting the surrounding area against ice thrown from wind turbine blades
- Bat Shield System for protecting bats

- Bird Detection System for protecting birds
- SGRE Messenger application for distributing SMS and/or email messages to operators and maintenance technicians (SIM card not included)
- Communication Manager integration with the cut-off switch feature to prevent remote wind turbine operation while maintaining continuous wind turbine monitoring, in addition to a slow buffer feature to retrieve and send data to the SCADA following an extended period of disconnected communication.
- ODBC access to the database.
- Integration of GUYS, SGRE's yawing interruption system. This system works from installed diesel generators that supply power to the auxiliary circuits in the wind turbines. It has been designed to enable the wind turbine to yaw automatically in conditions of strong gusty winds.

Main System Capabilities

WindNet® PRO has successfully undergone a certification process that enables it to guarantee the following for 5-second sampling periods:

- 99.99% data acquisition reliability.
- 99.99% reliability in the publication of information by OPC-DA (up to 100,000 variables for a single OPC client connected or 10,000 variables for 10 simultaneous clients).
- 99.99% correlation between the information displayed in real time (OPC-DA) and the recovered log (OPC-HDA, ODBC, Trends or through reporting tools).
- 100% correlation of log (historical) data recovered by any of the 4 methods (OPC-HDA, ODBC, Trends and reporting tools).

The WindNet® PRO storage system has a guaranteed 5-year storage of analog, digital, AWES and 10min variables, accessible online, and 15 additional years for recoverable data backup

Wind Farm Management System

SGRE's wind farm management system comprises the central system WindOne®, Service Operations Center (SOC), the SCADAs installed in wind farms and the wide area network (WAN) that links them all together.

During maintenance and/or the warranty period, wind farms with SGRE wind turbines must be integrated in the central system WindOne® under the control of the SOC (Service Operations Center). This system compiles data from all connected wind farms, checking and storing the retrieved data in keeping with the specified storage policy. The centralization of wind farm supervision offers excellent resources for monitoring the product, maintenance planning and reports on operating status and maintenance intended for clients. WindOne® likewise offers the Delegated Dispatch function in communication with the Network Operator with a view to keeping the electricity grid stable.

External access to the wind farm from WindOne® requires both primary and redundant communications lines to guarantee the availability of communications. Both lines and communications equipment are supplied by SGRE. Nonetheless, other communications solutions can be assessed whenever they meet the technical requirements for communications specified by SGRE.

Communication Network in Wind Farm

A wind farm's internal communications infrastructure is a network that links the SGRE SCADA system to the various wind farm devices (e.g., wind turbines, meteorological masts and substations).

Internal wind farm communications are based on a local area network (LAN) with Ethernet communications on ring-configured fiber optics. This is a "logical" round-trip ring through the same fiber optic cable so that the send path runs through two fibers and the return path runs through another two in the same cable. The wind turbines alternate where fibers connect to one another in the routing to prevent long links whenever possible.

The selection of the fiber optics for the wind farm and the overall layout of the ring network must meet SGRE specifications and will always be defined or validated by SGRE.

Likewise, the final configuration of a specific LAN network for a given wind farm will be jointly agreed between SGRE and the wind farm client.

External communication outside the wind farm through external protocols and/or SCADA clients can be based on any type of telecommunications system such as satellite links, ADSL/DSL lines, GPRS links, PSTN modems, GSM modems, etc. The primary criteria for selecting the appropriate means are the bandwidth requirements, need for continuous or on-demand connection, and the amount of data exchanged

Client Interface

Wind farm operators can view all the data in a simple and intuitive user interface based on web browser technology.

All operational aspects and access to SCADA system options are available through a standard web browser, though the latest version of Google Chrome is recommended

Data Analysis

WindNet® PRO includes 3 different wind farm data analysis tools:

- Reports: designed for exploitation reports
- Trending: designed for in-depth analysis of wind turbine variables.
- Comparatives: designed for instantaneously comparing two variables of all the wind turbines in the farm.

Codes and Standards

The wind turbine is designed and certified with an external certification body according to:

- IEC 61400-1:2005 +AMD1:2010 Edition 3 - Wind turbines - Part 1: Design requirements
- IEC 61400-22:2010 Edition 1 - Wind turbines – Part 22: Conformity testing and certification
- ISO 9001:2015 - Quality management systems – Requirements.
- Directive 2006/42/CE - Machinery (MD)

Other Performance Features

Siemens Gamesa Renewable Energy (SGRE) offers the following optional performance features for SG 4.5-145 that can optimize your wind farm by boosting performance, enhancing environmental agility, supporting compliance with legal regulation, and supporting grid stability.

High Wind Derated operational mode

In the case of SG 4.5-145 high wind derated mode, it is enabled as it can be observed on the different power curves included in this document. The power production is limited once wind speed exceeds a threshold value defined by design, until cut-out wind speed is reached and the wind turbine stops producing power. This functionality extends the range of operation in high wind conditions limiting turbine loads dependent of maximum operational wind speed, providing more predictable energy output, minimizing production losses, and improving grid stability by reducing the risk of simultaneous power cut outs.

High Temperature Derated operational mode (also known as Power Derating due to external ambient temperature and altitude)

Ventilation and cooling systems are designed to allow the WTG operation at rated power up to a certain external nominal temperature and a certain altitude. For sites located beyond 1000m above the sea level, the air density reduction affects the turbine components ventilation capacity, reducing the maximum operational temperature at rated power. However, this maximum ambient temperature can be extended by reducing the delivered power.

Considering the individual components requirements in temperatures at different altitude levels, and their dissipated heat at different power limits, several curves power-temperature will be generated. These curves will define the envelopes inside which SG 4.5-145 could operate assuring the integrity of all components.

The control system, considering the defined turbine type and altitude above sea level, will dynamically adjust the maximum allowed power as a function of the ambient temperature.

Ice Detection System

A default IDS is included in SG 4.5-145. This system is required in order to prevent the turbine operating under non desirable ice conditions that could represent an out-of-design situation with risk for the turbine integrity or H&S.

The default IDS can be improved by application of additional features, described as follows:

- Ice on nacelle sensor (optional kit). Additional sensor is installed to detect ice on nacelle.
- Improved ice on blade detection algorithm (optional, only available when blade de-icing system is installed). It requires additional hardware. It is a more complex ice detection algorithm defined based on ice probability calculation, and it is a valuable complement for improving the blade de-icing system performance.

Noise Reduction System

The Noise Reduction System NRS is an optional module available with the basic SCADA configuration and it therefore requires the existence of a SGRE SCADA system to work.

The purpose of this system is to limit the noise emitted by any of the functioning turbines and thereby comply with local regulations regarding noise emissions. This allows wind farms to be located close to urban areas, limiting the environmental impact that they imply.

Bat Protection System

To support the installation of wind turbines in areas that constitute a natural habitat for bats, SGRE has developed a Bat Protection System. Bats are usually more active at certain times of the night and at certain times of the year, depending on the local habitat and/or migration routes. The purpose of the SGRE Bat Protection System is to monitor the local environmental conditions in order to reduce the risk of impact on bats.

Specific environmental conditions can be monitored by means of dedicated additional sensors: temperature, light, humidity and rainfall. If conditions for the existence of bats are met, the Bat Protection System tool will request the wind turbines to be paused. As soon as one of the conditions is no longer met, the affected wind turbine will return to its initial status prior to receiving the pause order from the tool, depending on the configured hysteresis values.

The tool does not require all the sensors associated with the conditions to be installed and, depending on each site, the sensors needed will be configured. If there is no sensor for a specific environmental variable, condition is configured as fulfilled.

Additionally, Bat Protection System can be configured to be triggered depending on calendar (day/time), wind speed range or wind direction.

Bird Detection System

The Bird Detection System is a stand-alone system that monitors the wind farm's surrounding air space and detects flying birds in real time. At the same time, it is capable of handling real-time actions related to bird detection, such as warning and deterring birds at risk of colliding with the wind turbines or automatic shutdown of the selected wind turbines.