

152_FM_MESETG

ENIPOWER - Centrale di Ravenna - Sezione Turbogas n. 1

Sistema di Misura delle Emissioni

Report mensile flussi di massa totali (NOx,CO) - DLGS 152 (70%)

di Ottobre 2013

MESE	TRANSITORI		NORMALE FUNZIONAMENTO	
	CO (KG)	NOX (KG)	CO (KG)	NOX (KG)
1	0.00	0.00	42.61	257.23
2	0.00	0.00	0.00	0.00
3	5006.59	112.72	59.07	181.78
4	0.00	0.00	39.97	610.90
5	0.00	0.00	64.21	589.20
6	0.00	0.00	75.63	547.10
7	0.00	0.00	57.51	551.87
8	0.00	0.00	151.12	515.64
9	0.00	0.00	92.68	546.44
10	0.00	0.00	72.08	528.14
11	0.00	0.00	108.81	569.22
12	0.00	0.00	75.62	566.36
13	0.00	0.00	57.09	588.90
14	0.00	0.00	84.84	553.35
15	0.00	0.00	124.77	503.40
16	0.00	0.00	55.80	553.94
17	0.00	0.00	67.48	571.80
18	0.00	0.00	704.21	559.55
19	0.00	0.00	74.66	511.92
20	0.00	0.00	117.30	496.53
21	0.00	0.00	112.22	509.29
22	0.00	0.00	69.64	510.45
23	0.00	0.00	125.95	478.68