

Wind speed: Average											Power Generation: 42.000 kW					Operation duration 2.763 Hrs					
MV + HV Cable data																					
XLPE Cables		ARE4HIR 18/30 kV - Parameters				Alumium Conductors			Trefoil in ground												
Single core	Cross	R _{90°C}	X _c	Capacit.	Z _c	External	Weigth	Drum	Bending	Refer.	Current	R.c.c.*	R.c.c.*	R.c.c.*	R.c.c.*	R.c.c.*					
Al cables	Section	Ohm/km	Ohm/km	microF/km	Ohm/km	Dia		length	Radius	Price		for 1 circ.	for 2 circ.	for 3 circ.	for 4 circ.	for 5 circ.					
Cu wires	sqmm	km	km	km	km	mm	kg/mt	mt	mm	€/m	A	A	A	A	A	A					
screen																					
1 x	50	0,82	0,15	0,130	0,83	30	0,89	500	450	4,94	173	166	141	125	116	106					
1 x	70	0,57	0,14	0,150	0,58	31	0,97	500	465	5,29	208	200	170	150	140	128					
1 x	95	0,41	0,13	0,170	0,43	33	1,11	500	495	6,11	247	237	202	178	166	152					
1 x	120	0,33	0,13	0,190	0,35	34	1,16	500	510	6,73	281	270	229	202	189	173					
1 x	150	0,26	0,12	0,200	0,29	36	1,38	500	540	7,50	319	306	260	230	214	196					
1 x	185	0,21	0,12	0,210	0,24	38	1,56	500	570	8,46	361	347	295	260	243	222					
1 x	240	0,16	0,12	0,230	0,20	40	1,72	500	600	9,85	417	400	340	300	280	256					
1 x	300	0,13	0,11	0,260	0,18	43	2,05	500	645	11,20	474	455	387	341	319	291					
1 x	400	0,11	0,108	0,270	0,15	46	2,34	500	690	13,67	540	518	441	389	363	332					
1 x	500	0,09	0,100	0,300	0,13	49	2,82	500	735	15,94	618	593	504	445	415	380					
1 x	630	0,07	0,098	0,340	0,12	52	2,92	500	780	18,98	704	676	574	507	473	433					
XLPE Cables		ARE4HIR 64/110 kV - Parameters				Alumium Conductors			Trefoil in ground												
Single core	Cross	R _{90°C}	X _c	Capacit.	Z _c	External	Weigth	Drum	Bending	Refer.	Current	R.c.c.*									
Al cables	Section	Ohm/km	Ohm/km	microF/km	Ohm/km	Dia		length	Radius	Price		for 1 circ.									
Cu wires	sqmm	km	km	km	km	mm	kg/mt	mt	mm	€/m	A	A									
screen																					
1 x	400	0,10	0,43	0,157	0,44	84	6,50	1.000	1.700	35,00	530	509									
Basic Design Data																					
Operation Hypotesis											2 x				Speed	Unit power	Rev. Op.	Unit Gen.		Total Gen.	
											Trafos:		2.500		50.000		[kVA]				
Cos fi:	0,95				sin fi				0,31				V _{1n} =	690	30.000	[V]	m/s	kW/unit	hours	Energy MWh	Energy MWh
Rated Voltage(kV)	30				V _{2n} =	30	150	[kV]	≤3	-	2988,00	-	-								
Generation Power (kW)	2.100				I _N	48	192	[A]	4	55,90	669,77	37,44	748,80								
Generation hours:	2.763 Hrs/year				I	42,54	85,08	[A]	5	191,50	670,08	128,32	2.566,40								
WTG nos.	20				V _{cc} =	7,00	12,00	%	6	381,90	677,25	258,64	5.172,80								
Losses correction factor: Equivalent operation versus effective one						0,76				P _{fe} =	5,50	19,50	kW	7	631,60	659,28	416,40	8.328,00			
Cp = Net Present value of losses: ax'((1+i)^n-1)/((1+i)^n)xi						P _{cu} =	14,1	27,6	kW	8	956,00	611,46	584,56	11.691,20							
where	a =	selling price				0,126				P _{tot} =	23,50	160,50		9	1.350,20	541,85	731,60	14.632,00			
	i =	Net present value interest rate				0,06				Z _n	360,00	450,00	Ohm	10	1.750,80	460,09	805,52	16.110,40			
	n =	number of years for return of investment:				20				Z ₂₀ =	25,20	54,00	Ohm	11	2.004,30	380,74	763,12	15.262,40			
	Cp =	1,4452101 €/kWh				R ₂₀ =	2,59	1,27	Ohm	12	2.083,40	303,93	633,20	12.664,00							
Generation factor	1				X ₂₀ =	25,07	53,99	Ohm	13	2.098,30	230,89	484,48	9.689,60								
					Q _{cosfi=1}	136,094	1.172,419	VAR	14	2.101,20	167,45	351,84	7.036,80								
					Q _{tot}	5.066.722		VAR	15	2.100,40	116,40	244,48	4.889,60								
									16	2.098,70	77,61	162,88	3.257,60								
									17	2.097,70	49,69	104,24	2.084,80								
									18	2.095,50	30,66	64,24	1.284,80								
									19	2.093,90	18,26	38,24	764,80								
									20	2.090,90	6,73	14,08	281,60								
													5.823	116.466							

				Wind speed:	Average					Power Generation:	42.000	kW					Operation duration	2.763	Hrs			
M.V. branches parameters calculation																						
Circuit Line 1 and 2																						
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac. _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{ind.i lost}	Q _{capac.i lost}	Q _{tot.i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _{(i-1)-i}	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	VAR	VAR	V		kWh/year	€	€	
Circuit Line 1.1																						
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	2.100	2.100	42,54	1.626	0,077	403	22.467	-22.064	22,63	0,113	3.414	4.933	8.407	13.341
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	2.100	4.200	85,08	2.867	0,068	1.303	28.260	-26.957	21,20	0,106	6.019	8.699	11.253	19.952
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	2.100	6.300	127,62	2.619	0,042	2.209	29.390	-27.182	14,34	0,072	5.499	7.948	13.446	21.393
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	2.100	8.400	170,17	19.789	0,236	16.688	124.909	-108.222	81,25	0,406	41.550	60.048	57.143	117.192
Circuit Line 1.2																						
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	2.100	2.100	42,54	1.503	0,072	372	20.771	-20.399	20,92	0,105	3.156	4.561	7.773	12.334
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	2.100	4.200	85,08	3.153	0,075	1.433	31.086	-29.653	23,32	0,117	6.621	9.569	12.378	21.947
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	2.100	6.300	127,62	5.369	0,085	4.528	60.250	-55.723	29,39	0,147	11.273	16.293	27.563	43.856
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	2.100	8.400	170,17	4.540	0,054	3.828	28.656	-24.827	18,64	0,093	9.532	13.776	13.109	26.885
Circuit Line 1.3																						
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	2.100	2.100	42,54	3.528	0,168	874	48.749	-47.874	49,10	0,246	7.407	10.705	18.243	28.947
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	2.100	2.100	42,54	1.503	0,072	372	20.771	-20.399	20,92	0,105	3.156	4.561	7.773	12.334
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	2.100	6.300	127,62	13.423	0,213	11.319	150.626	-139.306	73,48	0,367	28.184	40.731	68.908	109.640
										23.100												
Line from Cab. 1 to Cab. 2																						
	L _{Cab1-Cab.2}	3.800	2//3x1x500	593	0,334	0,380	1,140	0,506	2.100	23.100	233,98	109.718	0,475	124.821	644.328	-519.507	176,19	0,881	460.738	665.863	363.334	1.029.197
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac. _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{ind.i lost}	Q _{capac.i lost}	Q _{tot.i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _{(i-1)-i}	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	VAR	VAR	V		kWh/year	€	€	
Circuit Line 2.1																						
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	2.100	2.100	42,54	3.681	0,175	912	50.868	-49.956	51,24	0,256	7.729	11.170	19.036	30.206
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	2.100	4.200	85,08	33.254	0,792	15.115	327.816	-312.701	245,88	1,229	69.821	100.906	130.535	231.441
Circuit Line 2.2																						
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	2.100	2.100	42,54	2.147	0,102	532	29.673	-29.141	29,89	0,149	4.509	6.516	11.104	17.620
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	2.100	4.200	85,08	13.531	0,322	6.150	133.387	-127.237	100,05	0,500	28.410	41.059	53.114	94.173
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	2.100	6.300	127,62	4.191	0,067	3.534	47.025	-43.491	22,94	0,115	8.799	12.716	21.513	34.229
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	2.100	8.400	170,17	2.794	0,033	4.712	35.268	-30.557	11,47	0,057	5.866	8.477	8.067	16.545
Circuit Line 2.3																						
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	2.100	2.100	42,54	1.994	0,095	494	27.554	-27.059	27,75	0,139	4.187	6.050	10.311	16.361
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	2.100	4.200	85,08	26.947	0,642	12.249	265.644	-253.395	199,24	0,996	56.579	81.769	105.778	187.547
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	2.100	6.300	127,62	45.796	0,727	20.816	200.646	-179.830	225,74	1,129	96.155	138.964	79.896	218.860
										18.900												
Circuit line from S/S Utenza to S/S Terna																						
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac. _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{ind.i lost}	Q _{capac.i lost}	Q _{tot.i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _{(i-1)-i}	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	VAR	VAR	V		kWh/year	€	€	
		Alt 1	30 kV cable connection to Terna Substation																			
MV Line	L _{SS-Terna}	18.900	3//3x1x500	593	1,661	1,890	5,670	2,516		42.000	283,61	1.202.647	2,863	1.368.199	4.807.026	-3.438.827	1.064,03	5,320	7.575.423	10.948.077	2.710.663	13.658.739
		Alt 2	150 kV cable connection to Terna Substation																			
HV Line	L _{SS-Terna}	18.900	1 x 400	509	1,890	8,127	2,967	8,344		42.000	170,17	164.183,93	0,391	1.411.982	20.963.975	-19.551.993	1.275,16	0,850	344.729,12	498.206,00	1.984.500	2.482.706

		Wind speed: Average				Power Generation: 42.000 kW		Operation duration 2.763 Hrs		
Optimisation summary tables										
Cable ARE4H1RX - 18/30 kV										
Cables & Cable Accessories Summary						Losses - W	VAR	kWh/year	Losses €	Cable cost €
Line	Lenght	Cable size	Drum Nos	Joints	Terminations					
60	L ₇₋₁	530	3x1x70	1	6	1.626	-22.064	3.414	4.933	8.407
66	L ₁₉₋₃	490	3x1x70	1	6	1.503	-20.399	3.156	4.561	7.773
72	L ₁₀₋₁₂	1150	3x1x70	3	6	3.528	-47.874	7.407	10.705	18.243
73	L ₁₃₋₁₂	490	3x1x70	1	6	1.503	-20.399	3.156	4.561	7.773
83	L ₄₋₁₆	1200	3x1x70	3	6	3.681	-49.956	7.729	11.170	19.036
87	L ₁₁₋₈	700	3x1x70	2	3	2.147	-29.141	4.509	6.516	11.104
93	L ₁₄₋₆	650	3x1x70	2	3	1.994	-27.059	4.187	6.050	10.311
Total	5.210	3x1x70	13	18	42	15.982	-216.892	33.557	48.497	82.647
61	L ₁₋₁₈	500	3x1x150	2	3	2.867	-26.957	6.019	8.699	11.253
67	L ₃₋₂₀	550	3x1x150	2	3	3.153	-29.653	6.621	9.569	12.378
84	L _{16-Cab.2}	5.800	3x1x150	15	42	33.254	-312.701	69.821	100.906	130.535
88	L ₈₋₅	2.360	3x1x150	3	6	13.531	-127.237	28.410	41.059	53.114
94	L ₆₋₂₁	4.700	3x1x150	1	6	26.947	-253.395	56.579	81.769	105.778
95	L _{21-Cab.2}	3.550	3x1x150	13	36	45.796	-179.830	96.155	138.964	79.896
Total	17.460	3x1x150	36	90	36	125.547	-929.772	263.606	380.965	392.955
62	L ₁₈₋₂	1.200	1x300	3	6	2.619	-27.182	5.499	7.948	13.446
63	L _{2-Cab.1}	5.100	1x300	6	3	19.789	-108.222	41.550	60.048	57.143
68	L ₂₀₋₁₇	2.460	1x300	3	6	5.369	-55.723	11.273	16.293	27.563
69	L _{17-Cab.1}	1.170	1x300	1	6	4.540	-24.827	9.532	13.776	13.109
74	L _{12-Cab.1}	6.150	1x300	6	6	13.423	-139.306	28.184	40.731	68.908
89	L ₅₋₉	1.920	1x300			4.191	-43.491	8.799	12.716	21.513
90	L _{9-cab.2}	720	1x300			2.794	-30.557	5.866	8.477	8.067
Total	16.080	3x1x300	19	9	30	52.724	-429.307	110.703	159.989	209.750
77	L _{cab.1-Cab.2}	22.800	1x500	24	18	109.718	-519.507	460.738	665.863	363.334
Total	22.800	1x300	24	18	12	303.972	-2.095.478	868.604	1.255.315	1.048.686
Sub-Total						303.972	-2.095.478	868.604	1.255.315	1.048.686
Alt.2-150	L _{SS-Terna}	56.700	1x400 HV	72	69	164.184	-19.551.993	344.729	498.206	1.984.500
Grand Total Alt.2						468.156	-21.647.471	1.213.333	1.753.521	3.033.186

Specific Losses	kVAR	Perdite kW	% Perdite	Max. % DV
MV Cables	- 2.095	304,0	0,72	1,23
bt/MV TR P _{fe}	2.722	110,0	0,26	
bt/MV TR P _{cu}		281,5	0,67	
MV/AT TR P _{fe}	2.345	39,0	0,09	
MV/AT TR P _{cu}		55,1	0,13	
Alt 2 - 150 kV	- 19.552	164,2	0,39	0,85
Tot. Alt 150 kV	- 16.581	954	2,27	1,23

				Wind speed:	≤ 3	Power Generation:				20	2.988 Hrs					
				Basic Design Data								Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy	
												kW/unit	hours	MWh	MWh	
								2 x				1,00	2987,67	2,99	59,76	
Operation Hypotesis				Trafos:				2.500	50.000	[kVA]						
Cos fi:	0,95		sin fi	0,31			$V_{1n} =$	690	30.000	[V]	55,90	669,77	37,44	748,80		
Rated Voltage(kV)		30					$V_{2n} =$	30	150	[kV]	191,50	670,08	128,32	2.566,40		
Generation Power (kW)		1,0					I_N	48	192	[A]	381,90	677,25	258,64	5.172,84		
Generation hours:		2.987,9	Hrs/year				I	0,02	0,04	[A]	631,60	659,28	416,40	8.328,00		
WTG nos.		20					$V_{cc} =$	7,00	12,00	%	956,00	611,46	584,56	11.691,20		
Losses coorrection factor: Equivalent operation versus effective one				1,00			$P_{cc} =$	5,50	19,50	kW	1.350,20	541,85	731,60	14.632,00		
Cp = Net Present value of losses: $ax'((1+i)^n-1)/((1+i)^n)xi$							$P_{cu} =$	0,0	0,0	kW	1.750,80	460,09	805,52	16.110,40		
where	a =	selling price		0,126			$P_{cu} =$	18,00	141,00	kW	2.004,30	380,74	763,12	15.262,40		
	i =	Net present value interest rate		0,06			$P_{tot} =$	23,50	160,50		2.083,40	303,93	633,20	12.664,00	633.200,00	
	n =	number of years for return of investment:		20			Zn	360,00	450,00	Ohm	2.098,30	230,89	484,48	9.689,60	484.480,00	
							$Z_{20} =$	25,20	54,00	Ohm	2.101,20	167,45	351,84	7.036,80	351.840,00	
	Cp =	1,4452101	€/kWh				$R_{20} =$	2,59	1,27	Ohm	2.100,40	116,40	244,48	4.889,60	244.480,00	
							$X_{20} =$	25,07	53,99	Ohm	2.097,70	49,69	104,24	2.084,80	104.240,00	
Generation factor			1				$Q_{conf=1} =$	0	0	VAR	2.095,50	30,66	64,24	1.284,80	64.240,00	
							$Q_{tot} =$		1	VAR	2.093,90	18,26	38,24	764,80	38.240,00	
											2.090,90	6,73	14,08	281,60	14.080,00	
												8660,00	5.826	116.525	2.097.680	

				Wind speed:	≤3					Power Generation:	20					2.988 Hrs					
M.V. branches parameters calculation																					
Circuit Line 1 and 2																					
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{tot,i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost	
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€	
Circuit Line 1.1																					
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	1	1	0,02	0	0,000	-22.467	0,01	0,000	0	0	8.407	8.407	
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	1	2	0,04	0	0,000	-28.260	0,01	0,000	0	0	11.253	11.253	
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	1	3	0,06	0	0,000	-29.390	0,01	0,000	0	0	13.446	13.446	
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	1	4	0,08	0	0,000	-124.909	0,04	0,000	0	0	57.143	57.143	
Circuit Line 1.2																					
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	1	1	0,02	0	0,000	-20.771	0,01	0,000	0	0	7.773	7.773	
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	1	2	0,04	0	0,000	-31.086	0,01	0,000	0	0	12.378	12.378	
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	1	3	0,06	0	0,000	-60.250	0,01	0,000	0	0	27.563	27.563	
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	1	4	0,08	0	0,000	-28.656	0,01	0,000	0	0	13.109	13.109	
Circuit Line 1.3																					
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	1	1	0,02	0	0,000	-48.748	0,02	0,000	0	0	18.243	18.243	
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	1	1	0,02	0	0,000	-20.771	0,01	0,000	0	0	7.773	7.773	
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	1	3	0,06	0	0,000	-150.626	0,03	0,000	0	0	68.908	68.908	
										11											
Line from Cab. 1 to Cab. 2																					
	L _{Cab1-Cab.2}	3.800	2/3x1x500	593	0,334	0,380	1,140	0,506	1	11	0,11	0	0,000	-644.328	0,08	0,000	0	0	363.334	363.334	
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{tot,i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost	
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€	
Circuit Line 2.1																					
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	1	1	0,02	0	0,000	-50.868	0,02	0,000	0	0	19.036	19.036	
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	1	2	0,04	0	0,000	-327.816	0,12	0,001	0	0	130.535	130.535	
Circuit Line 2.2																					
14	L ₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	1	1	0,02	0	0,000	-29.673	0,01	0,000	0	0	11.104	11.104	
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	1	2	0,04	0	0,000	-133.387	0,05	0,000	0	0	53.114	53.114	
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	1	3	0,06	0	0,000	-47.025	0,01	0,000	0	0	21.513	21.513	
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	1	4	0,08	0	0,000	-35.268	0,01	0,000	0	0	8.067	8.067	
Circuit Line 2.3																					
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	1	1	0,02	0	0,000	-27.553	0,01	0,000	0	0	10.311	10.311	
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	1	2	0,04	0	0,000	-265.644	0,09	0,000	0	0	105.778	105.778	
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	1	3	0,06	0	0,000	-200.646	0,11	0,001	0	0	79.896	79.896	
										9											
Circuit line from S/S Utenza to S/S Terna																					
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{tot,i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost	
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€	
	Alt 1	30 kV cable connection to Terna Substation																			
MV Line	L _{SS-Terna}	18.900	3/3x1x500	593	1,661	1,890	5,670	2,516		20	0,14	0	0,001	-4.807.026	0,51	0,003	2	4	2.710.663	2.710.666	
	Alt 2	150 kV cable connection to Terna Substation																			
HV Line	L _{SS-Terna}	18.900	1 x 400	509	1,890	8,127	2,967	8,344		20	0,08	0,04	0,000	-20.963.974	0,60	0,000	0,11	0,16	1.984.500	1.984.500	

							Wind speed:	≤3	Power Generation:				20	2.988 Hrs			
							Optimisation summary tables										
Cable ARE4H1RX - 18/30 kV																	
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	kVAR	Perdite kW	% Perdite	Max. % DV		
Line	Lenght	Cable size	Drum Nos	Joints	Terminations												
60	L7-1	530	3x1x70	1	6	0	-22.467	0	0	8.407	-2.328	0,0	0,00	0,00			
66	L9-3	490	3x1x70	1	6	0	-20.771	0	0	7.773							
72	L10-12	1150	3x1x70	3	6	0	-48.748	0	0	18.243	0	110,0	550,00				
73	L13-12	490	3x1x70	1	6	0	-20.771	0	0	7.773		0,0	0,00				
83	L4-16	1200	3x1x70	3	6	0	-50.868	0	0	19.036							
87	L1-8	700	3x1x70	2	3	0	-29.673	0	0	11.104	0	39,0	195,00				
93	L14-6	650	3x1x70	2	3	0	-27.553	0	0	10.311	0	0,0	0,00				
	Total	5.210	3x1x70	13	18	0	-220.852	0	0	82.647							
61	L1-18	500	3x1x150	2	3	0	-28.260	0	0	11.253	-20.964	0,0	0,00	0,00			
67	L3-20	550	3x1x150	2	3	0	-31.086	0	0	12.378							
84	L16-Cab.2	5.800	3x1x150	20	57	0	-327.816	0	0	130.535							
88	L8-5	2.360	3x1x150	8	21	0	-133.387	0	0	53.114	-23.292	149	745,00	0,00			
94	L6-21	4.700	3x1x150	16	45	0	-265.644	0	0	105.778							
95	L21-Cab.2	3.550	3x1x150	12	33	0	-200.646	0	0	79.896							
	Total	17.460	3x1x150	60	162	0	-986.839	0	0	392.955							
62	L18-2	1.200	1x300	3	6	0	-29.390	0	0	13.446							
63	L2-Cab.1	5.100	1x300	9	6	0	-124.909	0	0	57.143							
68	L20-17	2.460	1x300	6	3	0	-60.250	0	0	27.563							
69	L17-Cab.1	1.170	1x300	1	6	0	-28.656	0	0	13.109							
74	L12-Cab.1	6.150	1x300	12	9	0	-150.626	0	0	68.908							
89	L5-9	1.920	1x300	3	6	0	-47.025	0	0	21.513							
90	L9-Cab.2	720	1x300	1	6	0	-35.268	0	0	8.067							
	Total	16.080	3x1x300	35	18	0	-476.124	0	0	209.750							
77	Lcab.1-Cab.2	22.800	1x500	36	30	0	-644.328	0	0	363.334							
	Total	22.800	1x500	36	30	0	-2.328.144	0	0	1.048.686							
Alt.2-150	LSS-Terms	56.700	1x400 HV	72	69	0	-20.963.974	0	0	1.984.500							
	Grand Total Alt.2					0	-23.292.118	0	1	3.033.186							

				Wind speed:	4	Power Generation:				1.118	670 Hrs				
				Basic Design Data								Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy
								2 x				kW/unit	hours	MWh	MWh
Operation Hypotesis				Trafos:				2.500	50.000	[kVA]		1,00	2987,87	2,99	59,76
Cos fi:	0,95		sin fi	0,31		V _{1n} =	690	30.000	[V]		55,90	669,77	37,44	748,80	
Rated Voltage(kV)			30			V _{2n} =	30	150	[kV]		191,50	670,08	128,32	2.566,40	
Generation Power (kW)			55,9			I _N	48	192	[A]		381,90	677,25	258,64	5.172,84	
Generation hours:			669,8	Hrs/year		I	1,13	2,26	[A]		631,60	659,28	416,40	8.328,00	
WTG nos.			20			V _{cc} =	7,00	12,00	%		956,00	611,46	584,56	11.691,20	
Losses coorrection factor: Equivalent operation versus effective one				1,00		P _{fe} =	5,50	19,50	kW		1.350,20	541,85	731,60	14.632,00	
Cp = Net Present value of losses: $a \times ((1+i)^n - 1) / ((1+i)^n \times i)$						P _{cu}	0,0	0,0	kW		1.750,80	460,09	805,52	16.110,40	
						P _{cu} =	18,00	141,00	kW		2.004,30	380,74	763,12	15.262,40	
where	a =	selling price		0,126		P _{tot} =	23,50	160,50			2.083,40	303,93	633,20	12.664,00	
	i =	Net present value interest rate		0,06		Z _n	360,00	450,00	Ohm		2.098,30	230,89	484,48	9.689,60	
	n =	number of years for return of investment:		20		Z _{n20} =	25,20	54,00	Ohm		2.101,20	167,45	351,84	7.036,80	
											2.100,40	116,40	244,48	4.889,60	
											2.098,70	77,61	162,88	3.257,60	
											2.097,70	49,69	104,24	2.084,80	
	Cp =	1,4452101	€/kWh			R _{t20} =	2,59	1,27	Ohm		2.095,50	30,66	64,24	1.284,80	
						X _{t20} =	25,07	53,99	Ohm		2.093,90	18,26	38,24	764,80	
Generation factor			1			Q _{cosfi=1}	96	831	VAR		2.090,90	6,73	14,08	281,60	
						Q _{tot}		3.590	VAR			8660,00	5.826	116.525	
														2.097.680	

				Wind speed:	4	Power Generation:						1.118	670 Hrs							
				M.V. branches parameters calculation																
Circuit Line 1 and 2																				
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac. _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{tot,i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€
Circuit Line 1.1																				
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	56	56	1,13	1	0,002	-22.466	0,60	0,003	1	1	8.407	8.409
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	56	112	2,26	2	0,002	-28.259	0,56	0,003	1	2	11.253	11.255
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	56	168	3,40	2	0,001	-29.389	0,38	0,002	1	2	13.446	13.447
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	56	224	4,53	14	0,006	-124.897	2,16	0,011	9	14	57.143	57.157
Circuit Line 1.2																				
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	56	56	1,13	1	0,002	-20.771	0,56	0,003	1	1	7.773	7.774
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	56	112	2,26	2	0,002	-31.085	0,62	0,003	1	2	12.378	12.380
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	56	168	3,40	4	0,002	-60.247	0,78	0,004	3	4	27.563	27.567
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	56	224	4,53	3	0,001	-28.653	0,50	0,002	2	3	13.109	13.112
Circuit Line 1.3																				
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	56	56	1,13	2	0,004	-48.748	1,31	0,007	2	2	18.243	18.245
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	56	56	1,13	1	0,002	-20.771	0,56	0,003	1	1	7.773	7.774
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	56	168	3,40	10	0,006	-150.618	1,96	0,010	6	9	68.908	68.917
Line from Cab. 1 to Cab .2																				
	L _{cab1-Cab.2}	3.800	2//3x1x500	593	0,334	0,380	1,140	0,506	56	615	6,23	78	0,013	-644.240	4,69	0,023	104	151	363.334	363.484
Circuit Line 2.1																				
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	56	56	1,13	3	0,005	-50.867	1,36	0,007	2	3	19.036	19.038
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	56	112	2,26	24	0,021	-327.805	6,54	0,033	16	23	130.535	130.558
Circuit Line 2.2																				
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	56	56	1,13	2	0,003	-29.673	0,80	0,004	1	1	11.104	11.106
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	56	112	2,26	10	0,009	-133.383	2,66	0,013	6	9	53.114	53.123
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	56	168	3,40	3	0,002	-47.022	0,61	0,003	2	3	21.513	21.516
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	56	224	4,53	2	0,001	-35.265	0,31	0,002	1	2	8.067	8.069
Circuit Line 2.3																				
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	56	56	1,13	1	0,003	-27.553	0,74	0,004	1	1	10.311	10.312
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	56	112	2,26	19	0,017	-265.635	5,30	0,027	13	18	105.778	105.797
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	56	168	3,40	32	0,019	-200.631	6,01	0,030	22	31	79.896	79.928
				503																
				Circuit line from S/S Utenza to S/S Terna																
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac. _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{tot,i}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€
Alt 1				30 kV cable connection to Terna Substation																
MV Line	L _{SS-Terna}	18.900	3//3x1x500	593	1,661	1,890	5,670	2,516		1.118	7,55	852	0,076	-4.806.057	28,27	0,141	1.712	2.475	2.710.663	2.713.137
Alt 2				150 kV cable connection to Terna Substation																

							Wind speed:	4	Power Generation:					1.118	670 Hrs					
HV Line	L _{SS-Terna}	18.900	1 x 400	509	1,890	8,127	2,967	8,344	1.118	4,53	116,34	0,010	-20.962.974	33,82	0,023	77,92	112,61	1.984.500	1.984.613	
									Optimisation summary tables											
Cable ARE4HIRX - 18/30 kV																				
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	kVAR	Perdite kW	% Perdite	Max. % DV					
Line	Lenght	Cable size	Drum Nos	Joints	Terminations															
60	L ₇₋₁	530	3x1x70	1		6	1	-22.466	1	1	8.407	-	2.328	0,2	0,02	0,03				
66	L ₁₉₋₃	490	3x1x70	1		6	1	-20.771	1	1	7.773									
72	L ₁₀₋₁₂	1150	3x1x70	3	6	6	2	-48.748	2	2	18.243			110,0	9,84					
73	L ₁₃₋₁₂	490	3x1x70	1		6	1	-20.771	1	1	7.773	2		0,2	0,02					
83	L ₄₋₁₆	1200	3x1x70	3	6	6	3	-50.867	2	3	19.036									
87	L ₁₁₋₈	700	3x1x70	2	3	6	2	-29.673	1	1	11.104			39,0	3,49					
93	L ₁₄₋₆	650	3x1x70	2	3	6	1	-27.553	1	1	10.311	2		0,0	0,00					
	Total	5.210	3x1x70	13	18	42	11	-220.849	8	11	82.647									
61	L ₁₋₁₈	500	3x1x150	2	3	6	2	-28.259	1	2	11.253	-	20.963	0,1	0,01	0,02				
67	L ₃₋₂₀	550	3x1x150	2	3	6	2	-31.085	1	2	12.378									
84	L _{16-Cab.2}	5.800	3x1x150	20	57	6	24	-327.805	16	23	130.535									
88	L ₈₋₅	2.360	3x1x150	8	21	6	10	-133.383	6	9	53.114	-	23.287	150	13,38	0,03				
94	L ₆₋₂₁	4.700	3x1x150	16	45	6	19	-265.635	13	18	105.778									
95	L _{21-Cab.2}	3.550	3x1x150	12	33	6	32	-200.631	22	31	79.896									
	Total	17.460	3x1x150	60	162	36	89	-986.799	60	86	392.955									
62	L ₁₈₋₂	1.200	1x300	3		6	2	-29.389	1	2	13.446									
63	L _{2-Cab.1}	5.100	1x300	9	6	6	14	-124.897	9	14	57.143									
68	L ₂₀₋₁₇	2.460	1x300	6	3	6	4	-60.247	3	4	27.563									
69	L _{17-Cab.1}	1.170	1x300	1		6	3	-28.653	2	3	13.109									
74	L _{12-Cab.1}	6.150	1x300	12	9	6	10	-150.618	6	9	68.908									
89	L ₅₋₉	1.920	1x300	3		6	3	-47.022	2	3	21.513									
90	L _{9-cab.2}	720	1x300	1		6	2	-35.265	1	2	8.067									
	Total	16.080	3x1x300	35	18	42	37	-476.091	25	36	209.750									
77	L _{Cab.1-Cab.2}	22.800	1x500	36	30	12	78	-644.240	104	151	363.334									
	Total	22.800	1x500	36	30	12	Sub-Total	215	-2.327.979	196	284	1.048.686								
Alt.2-150	L _{SS-Terna}	56.700	1x400 HV	72	69	6	116	-20.962.974	78	113	1.984.500									
							Grand Total Alt.2	332	-23.290.953	274	396	3.033.186								

Wind speed:		5		Power Generation:		3.830		670 Hrs					
Basic Design Data				Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy						
				kW/unit	hours	MWh	MWh						
Operation Hypotesis				Trafos:	2.500	50.000	[kVA]						
					2 x								
					1,00	2987,87	2,99	59,76					
					55,90	669,77	37,44	748,80					
					191,50	670,08	128,32	2.566,40					
Cos fi:	0,95		sin fi	0,31	$V_{1n} =$	690	30.000	[V]	381,90	677,25	258,64	5.172,84	
Rated Voltage(kV)		30			$V_{2n} =$	30	150	[kV]	631,60	659,28	416,40	8.328,00	
Generation Power (kW)		191,5			$I_N =$	48	192	[A]	956,00	611,46	584,56	11.691,20	
Generation hours:		670,1	Hrs/year		$I =$	3,88	7,76	[A]	1.350,20	541,85	731,60	14.632,00	
WTG nos.		20			$V_{cc} =$	7,00	12,00	%	1.750,80	460,09	805,52	16.110,40	
Losses coorrection factor: Equivalent operation versus effective one				1,00	$P_{fe} =$	5,50	19,50	kW	2.004,30	380,74	763,12	15.262,40	
Cp = Net Present value of losses: $ax((1+i)^n-1)/((1+i)^n)xi$					$P_{cu} =$	0,1	0,2	kW	2.083,40	303,93	633,20	12.664,00	633.200,00
					$P_{tot} =$	18,00	141,00	kW	2.098,30	230,89	484,48	9.689,60	484.480,00
where	a =	selling price		0,126	$Z_n =$	23,50	160,50	Ohm	2.101,20	167,45	351,84	7.036,80	351.840,00
	i =	Net present value interest rate		0,06	$Z_{20} =$	360,00	450,00	Ohm	2.100,40	116,40	244,48	4.889,60	244.480,00
	n =	number of years for return of investment:		20		25,20	54,00	Ohm	2.098,70	77,61	162,88	3.257,60	162.880,00
									2.097,70	49,69	104,24	2.084,80	104.240,00
	Cp =	1,4452101	€/kWh		$R_{20} =$	2,59	1,27	Ohm	2.095,50	30,66	64,24	1.284,80	64.240,00
					$X_{20} =$	25,07	53,99	Ohm	2.093,90	18,26	38,24	764,80	38.240,00
Generation factor			1		$Q_{coff=1} =$	1.132	9.749	VAR	2.090,90	6,73	14,08	281,60	14.080,00
					$Q_{tot} =$		42.133	VAR		8660,00	5.826	116.525	2.097.680

Wind speed: 5																			Power Generation: 3.830				670 Hrs			
M.V. branches parameters calculation																										
Circuit Line 1 and 2																										
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost						
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€						
Circuit Line 1.1																										
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	192	192	3,88	14	0,007	-22.463	2,06	0,010	9	13	8.407	8.421						
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	192	383	7,76	24	0,006	-28.249	1,93	0,010	16	23	11.253	11.276						
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	192	575	11,64	22	0,004	-29.372	1,31	0,007	15	21	13.446	13.467						
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	192	766	15,52	165	0,021	-124.770	7,41	0,037	110	159	57.143	57.303						
Circuit Line 1.2																										
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	192	192	3,88	12	0,007	-20.768	1,91	0,010	8	12	7.773	7.785						
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	192	383	7,76	26	0,007	-31.074	2,13	0,011	18	25	12.378	12.404						
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	192	575	11,64	45	0,008	-60.213	2,68	0,013	30	43	27.563	27.607						
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	192	766	15,52	38	0,005	-28.624	1,70	0,008	25	37	13.109	13.146						
Circuit Line 1.3																										
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	192	192	3,88	29	0,015	-48.741	4,48	0,022	20	28	18.243	18.271						
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	192	192	3,88	12	0,007	-20.768	1,91	0,010	8	12	7.773	7.785						
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	192	575	11,64	112	0,019	-150.532	6,70	0,034	75	108	68.908	69.016						
										2.107																
Line from Cab. 1 to Cab. 2																										
	L _{Cab1-Cab.2}	3.800	2/3x1x500	593	0,334	0,380	1,140	0,506	192	2.107	21,34	912	0,043	-643.290	16,06	0,080	1.223	1.767	363.334	365.101						
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost						
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€						
Circuit Line 2.1																										
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	192	192	3,88	31	0,016	-50.860	4,67	0,023	21	30	19.036	19.065						
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	192	383	7,76	277	0,072	-327.690	22,42	0,112	185	268	130.535	130.803						
Circuit Line 2.2																										
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	192	192	3,88	18	0,009	-29.669	2,73	0,014	12	17	11.104	11.121						
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	192	383	7,76	113	0,029	-133.336	9,12	0,046	75	109	53.114	53.223						
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	192	575	11,64	35	0,006	-46.995	2,09	0,010	23	34	21.513	21.547						
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	192	766	15,52	23	0,003	-35.229	1,05	0,005	16	22	8.067	8.090						
Circuit Line 2.3																										
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	192	192	3,88	17	0,009	-27.549	2,53	0,013	11	16	10.311	10.327						
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	192	383	7,76	224	0,059	-265.542	18,17	0,091	150	217	105.778	105.995						
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	192	575	11,64	381	0,066	-200.473	20,59	0,103	255	369	79.896	80.265						
										1.724																
Circuit line from S/S Utenza to S/S Terna																										
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost						
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€						
	Alt 1	30 kV cable connection to Terna Substation																								
MV Line	L _{SS-Terna}	18.900	3/3x1x500	593	1,661	1,890	5,670	2,516		3.830	25,86	10.001	0,261	-4.795.648	96,85	0,484	20.104	29.055	2.710.663	2.739.717						
	Alt 2	150 kV cable connection to Terna Substation																								

							Wind speed:	5	Power Generation:					3.830	670 Hrs				
HV Line	L-SS-Terna	18.900	1 x 400	509	1,890	8,127	2,967	8,344	3.830	15,52	1.365,30	0,036	-20.952.233	115,88	0,077	914,86	1.322,17	1.984.500	1.985.822
Optimisation summary tables																			
Cable ARE4HIRX - 18/30 kV																			
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	KVAR	Perdite kW	% Perdite	Max. % DV				
Line	Lenght	Cable size	Drum Nos	Joints	Terminations														
60	L7-1	530	3x1x70	1	6		14	-22.463	9	13	8.407	-	2.326	2,5	0,07	0,11			
66	L19-3	490	3x1x70	1	6		12	-20.768	8	12	7.773								
72	L10-12	1150	3x1x70	3	6		29	-48.741	20	28	18.243			110,0	2,87				
73	L13-12	490	3x1x70	1	6		12	-20.768	8	12	7.773	23		2,3	0,06				
83	L4-16	1200	3x1x70	3	6		31	-50.860	21	30	19.036								
87	L1-8	700	3x1x70	2	3	6	18	-29.669	12	17	11.104	19		39,0	1,02				
93	L14-6	650	3x1x70	2	3	6	17	-27.549	11	16	10.311			0,5	0,01				
	Total	5.210	3x1x70	13	18	42	133	-220.819	89	129	82.647								
61	L1-18	500	3x1x150	2	3	6	24	-28.249	16	23	11.253	-	20.952	1,4	0,04	0,08			
67	L3-20	550	3x1x150	2	3	6	26	-31.074	18	25	12.378								
84	L16-Cab.2	5.800	3x1x150	20	57	6	277	-327.690	185	268	130.535								
88	L8-5	2.360	3x1x150	8	21	6	113	-133.336	75	109	53.114	-	23.236	156	4,07	0,11			
94	L6-21	4.700	3x1x150	16	45	6	224	-265.542	150	217	105.778								
95	L21-Cab.2	3.550	3x1x150	12	33	6	381	-200.473	255	369	79.896								
	Total	17.460	3x1x150	60	162	36	1.044	-986.365	700	1.011	392.955								
62	L18-2	1.200	1x300	3	6		22	-29.372	15	21	13.446								
63	L2-Cab.1	5.100	1x300	9	6	6	165	-124.770	110	159	57.143								
68	L20-17	2.460	1x300	6	3	6	45	-60.213	30	43	27.563								
69	L17-Cab.1	1.170	1x300	1	6		38	-28.624	25	37	13.109								
74	L12-Cab.1	6.150	1x300	12	9	6	112	-150.532	75	108	68.908								
89	L5-9	1.920	1x300	3	6		35	-46.995	23	34	21.513								
90	L9-cab.2	720	1x300	1	6		23	-35.229	16	22	8.067								
	Total	16.080	3x1x300	35	18	42	438	-475.735	294	425	209.750								
77	Lcab1-Cab.2	22.800	1x500	36	30	12													
	Total	22.800	1x500	36	30	12	912	-643.290	1.223	1.767	363.334								
	Sub-Total						2.528	-2.326.209	2.305	3.331	1.048.686								
Alt.2-150	L-SS-Terna	56.700	1x400 HV	72	69	6													
	Grand Total Alt.2						3.893	-23.278.442	3.220	4.654	3.033.186								

Wind speed:		6	Power Generation:		7.638	677 Hrs		
Basic Design Data					Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy
					kW/unit	hours	MWh	MWh
Operation Hypotesis					Trafos:	2.500	50.000	[kVA]
					2 x			
					1,00	2987,87	2,99	59,76
					55,90	669,77	37,44	748,80
					191,50	670,08	128,32	2.566,40
Cos fi:	0,95		sin fi	0,31	V _{1n} =	690	30.000	[V]
Rated Voltage(kV)		30			V _{2n} =	30	150	[kV]
Generation Power (kW)		381,9			I _N	48	192	[A]
Generation hours:		677,3	Hrs/year		I	7,74	15,47	[A]
WTG nos.		20			V _{cc} =	7,00	12,00	%
Losses coorrection factor: Equivalent operation versus effective one					P _{fe} =	5,50	19,50	kW
Cp = Net Present value of losses: $ax^i((1+i)^n-1)/((1+i)^n)xi$					P _{cu} =	0,5	0,9	kW
					P _{cu} =	18,00	141,00	kW
where	a =	selling price		0,126	P _{tot} =	23,50	160,50	
	i =	Net present value interest rate		0,06	Zn	360,00	450,00	Ohm
	n =	number of years for return of investment:		20	Z ₂₀ =	25,20	54,00	Ohm
	Cp =	1,4452101	€/kWh		R ₂₀ =	2,59	1,27	Ohm
					X ₂₀ =	25,07	53,99	Ohm
Generation factor			1		Q _{cosfi=1}	4,501	38,774	VAR
					Q _{tot}		167,567	VAR
							8660,00	5,826
								116,525
								2,097,680

Wind speed: 6 Power Generation: 7.638 677 Hrs																				
M.V. branches parameters calculation																				
Circuit Line 1 and 2																				
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€
Circuit Line 1.1																				
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	382	382	7,74	54	0,014	-22.453	4,12	0,021	36	53	8.407	8.460
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	382	764	15,47	95	0,012	-28.217	3,85	0,019	64	93	11.253	11.346
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	382	1.146	23,21	87	0,008	-29.317	2,61	0,013	59	85	13.446	13.530
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	382	1.528	30,95	654	0,043	-124.357	14,77	0,074	443	641	57.143	57.784
Circuit Line 1.2																				
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	382	382	7,74	50	0,013	-20.759	3,80	0,019	34	49	7.773	7.822
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	382	764	15,47	104	0,014	-31.039	4,24	0,021	71	102	12.378	12.480
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	382	1.146	23,21	178	0,015	-60.101	5,34	0,027	120	174	27.563	27.737
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	382	1.528	30,95	150	0,010	-28.529	3,39	0,017	102	147	13.109	13.256
Circuit Line 1.3																				
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	382	382	7,74	117	0,031	-48.720	8,93	0,045	79	114	18.243	18.357
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	382	382	7,74	50	0,013	-20.759	3,80	0,019	34	49	7.773	7.822
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	382	1.146	23,21	444	0,039	-150.251	13,36	0,067	301	435	68.908	69.343
										4.201										
Line from Cab. 1 to Cab. 2																				
	L _{Cab1-Cab.2}	3.800	2/3x1x500	593	0,334	0,380	1,140	0,506	382	4.201	42,55	3.629	0,086	-640.200	32,03	0,160	4.915	7.103	363.334	370.437
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€
Circuit Line 2.1																				
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	382	382	7,74	122	0,032	-50.838	9,32	0,047	82	119	19.036	19.155
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	382	764	15,47	1.100	0,144	-327.316	44,71	0,224	745	1.076	130.535	131.611
Circuit Line 2.2																				
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	382	382	7,74	71	0,019	-29.655	5,44	0,027	48	70	11.104	11.174
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	382	764	15,47	447	0,059	-133.184	18,19	0,091	303	438	53.114	53.552
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	382	1.146	23,21	139	0,012	-46.908	4,17	0,021	94	136	21.513	21.648
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	382	1.528	30,95	92	0,006	-35.113	2,09	0,010	63	90	8.067	8.158
Circuit Line 2.3																				
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	382	382	7,74	66	0,017	-27.537	5,05	0,025	45	65	10.311	10.376
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	382	764	15,47	891	0,117	-265.239	36,23	0,181	604	872	105.778	106.650
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	382	1.146	23,21	1.515	0,132	-199.958	41,05	0,205	1.026	1.482	79.896	81.379
										3.437										
Circuit line from S/S Utenza to S/S Terna																				
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€
Alt 1 30 kV cable connection to Terna Substation																				
MV Line	L _{SS-Terna}	18.900	3//3x1x500	593	1,661	1,890	5,670	2,516		7.638	51,58	39.774	0,521	-4.761.777	193,17	0,966	80.811	116.789	2.710.663	2.827.451
Alt 2 150 kV cable connection to Terna Substation																				

							Wind speed: 6		Power Generation: 7.638					677 Hrs					
HV Line	L _{SS-Terna}	18.900	1 x 400	509	1,890	8,127	2,967	8,344	7.638	30,95	5,429,89	0,071	-20.917.277	231,17	0,154	3.677,40	5.314,61	1.984.500	1.989.815
Optimisation summary tables																			
Cable ARE4HIRX - 18/30 kV																			
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	KVAR	Perdite kW	% Perdite	Max. % DV				
Line	Lenght	Cable size	Drum Nos	Joints	Terminations														
60	L ₇₋₁	530	3x1x70	1	6		54	-22.453	36	53	8.407	-	2.320	10,1	0,13	0,22			
66	L ₁₉₋₃	490	3x1x70	1	6		50	-20.759	34	49	7.773								
72	L ₁₀₋₁₂	1150	3x1x70	3	6		117	-48.720	79	114	18.243								
73	L ₁₃₋₁₂	490	3x1x70	1	6		50	-20.759	34	49	7.773		90	110,0	1,44				
83	L ₄₋₁₆	1200	3x1x70	3	6		122	-50.838	82	119	19.036			9,3	0,12				
87	L ₁₋₈	700	3x1x70	2	3	6	71	-29.655	48	70	11.104		78	39,0	0,51				
93	L ₁₄₋₆	650	3x1x70	2	3	6	66	-27.537	45	65	10.311			1,8	0,02				
	Total	5.210	3x1x70	13	18	42	529	-220.721	358	517	82.647								
61	L ₁₋₁₈	500	3x1x150	2	3	6	95	-28.217	64	93	11.253	-	20.917	5,4	0,07	0,15			
67	L ₃₋₂₀	550	3x1x150	2	3	6	104	-31.039	71	102	12.378								
84	L _{16-Cab.2}	5.800	3x1x150	20	57	6	1.100	-327.316	745	1.076	130.535								
88	L ₈₋₅	2.360	3x1x150	8	21	6	447	-133.184	303	438	53.114	-	23.070	176	2,30	0,22			
94	L ₆₋₂₁	4.700	3x1x150	16	45	6	891	-265.239	604	872	105.778								
95	L _{21-Cab.2}	3.550	3x1x150	12	33	6	1.515	-199.958	1.026	1.482	79.896								
	Total	17.460	3x1x150	60	162	36	4.152	-984.952	2.812	4.064	392.955								
62	L ₁₈₋₂	1.200	1x300	3	6		87	-29.317	59	85	13.446								
63	L _{2-Cab.1}	5.100	1x300	9	6	6	654	-124.357	443	641	57.143								
68	L ₂₀₋₁₇	2.460	1x300	6	3	6	178	-60.101	120	174	27.563								
69	L _{17-Cab.1}	1.170	1x300	1	6		150	-28.529	102	147	13.109								
74	L _{12-Cab.1}	6.150	1x300	12	9	6	444	-150.251	301	435	68.908								
89	L ₅₋₉	1.920	1x300	3	6		139	-46.908	94	136	21.513								
90	L _{9-Cab.2}	720	1x300	1	6		92	-35.113	63	90	8.067								
	Total	16.080	3x1x300	35	18	42	1.744	-474.576	1.181	1.707	209.750								
77	L _{Cab.1-Cab.2}	22.800	1x500	36	30	12													
	Total	22.800	1x500	36	30	12	Sub-Total	10.053	-2.320.449	9.266	13.391	1.048.686							
Alt.2-150	L _{SS-Terna}	56.700	1x400 HV	72	69	6													
							Grand Total Alt.2	15.483	-23.237.726	12.943	18.706	3.033.186							

Wind speed:		7	Power Generation:		12.632	659 Hrs					
Basic Design Data				Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy				
				kW/unit	hours	MWh	MWh				
				2 x	1,00	2987,87	2,99	59,76			
Operation Hypotesis				Trafos:	2.500	50.000	[kVA]				
					55,90	669,77	37,44	748,80			
					191,50	670,08	128,32	2.566,40			
Cos fi:	0,95	sin fi	0,31	V _{ln} =	690	30.000	[V]	381,90	677,25	258,64	5.172,84
Rated Voltage(kV)	30	V _{zn} =	30	150	[kV]	631,60	659,28	416,40	8.328,00		
Generation Power (kW)	631,6	I _N	48	192	[A]	956,00	611,46	584,56	11.691,20		
Generation hours:	659,3	Hrs/year	I	12,79	25,59	[A]	1.350,20	541,85	731,60	14.632,00	
WTG nos.	20	V _{sc} =	7,00	12,00	%	1.750,80	460,09	805,52	16.110,40		
Losses correction factor: Equivalent operation versus effective one				P _{fe} =	5,50	19,50	kW	2.004,30	380,74	763,12	15.262,40
Cp = Net Present value of losses: $ax((1+i)^n-1)/((1+i)^n)xi$				P _{cu}	1,3	2,5	kW	2.083,40	303,93	633,20	12.664,00
				P _{cu} =	18,00	141,00	kW	2.098,30	230,89	484,48	9.689,60
where	a =	selling price	0,126	P _{tot} =	23,50	160,50		2.101,20	167,45	351,84	7.036,80
	i =	Net present value interest rate	0,06	Z _n	360,00	450,00	Ohm	2.100,40	116,40	244,48	4.889,60
	n =	number of years for return of investment:	20	Z ₂₀ =	25,20	54,00	Ohm	2.098,70	77,61	162,88	3.257,60
								2.097,70	49,69	104,24	2.084,80
	Cp =	1,4452101	€/kWh	R ₂₀ =	2,59	1,27	Ohm	2.095,50	30,66	64,24	1.284,80
				X ₂₀ =	25,07	53,99	Ohm	2.093,90	18,26	38,24	764,80
Generation factor			1	Q _{cosfi=1}	12,311	106,054	VAR	2.090,90	6,73	14,08	281,60
				Q _{tot}		458,324	VAR		8660,00	5,826	116,525
											2.097.680

																			Wind speed:	7	Power Generation:					12.632	659 Hrs				
																			M.V. branches parameters calculation												
Circuit Line 1 and 2																															
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost											
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€											
Circuit Line 1.1																															
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	632	632	12,79	147	0,023	-22.430	6,81	0,034	97	140	8.407	8.548											
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	632	1.263	25,59	259	0,021	-28.142	6,37	0,032	171	247	11.253	11.500											
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	632	1.895	38,38	237	0,013	-29.191	4,31	0,022	156	226	13.446	13.671											
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	632	2.526	51,18	1.790	0,071	-123.400	24,43	0,122	1.180	1.706	57.143	58.849											
Circuit Line 1.2																															
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	632	632	12,79	136	0,022	-20.737	6,29	0,031	90	130	7.773	7.902											
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	632	1.263	25,59	285	0,023	-30.956	7,01	0,035	188	272	12.378	12.650											
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	632	1.895	38,38	486	0,026	-59.841	8,84	0,044	320	463	27.563	28.026											
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	632	2.526	51,18	411	0,016	-28.309	5,61	0,028	271	391	13.109	13.501											
Circuit Line 1.3																															
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	632	632	12,79	319	0,051	-48.669	14,77	0,074	210	304	18.243	18.547											
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	632	632	12,79	136	0,022	-20.737	6,29	0,031	90	130	7.773	7.902											
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	632	1.895	38,38	1.214	0,064	-149.602	22,10	0,110	801	1.157	68.908	70.065											
										6.948																					
Line from Cab. 1 to Cab. 2																															
	L _{Cab1-Cab.2}	3.800	2/3x1x500	593	0,334	0,380	1,140	0,506	632	6.948	70,37	9.925	0,143	-633.037	52,98	0,265	13.086	18.913	363.334	382.247											
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost											
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€											
Circuit Line 2.1																															
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	632	632	12,79	333	0,053	-50.785	15,41	0,077	220	317	19.036	19.353											
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	632	1.263	25,59	3.008	0,238	-326.449	73,95	0,370	1.983	2.866	130.535	133.401											
Circuit Line 2.2																															
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	632	632	12,79	194	0,031	-29.625	8,99	0,045	128	185	11.104	11.289											
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	632	1.263	25,59	1.224	0,097	-132.831	30,09	0,150	807	1.166	53.114	54.280											
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	632	1.895	38,38	379	0,020	-46.705	6,90	0,034	250	361	21.513	21.874											
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	632	2.526	51,18	253	0,010	-34.842	3,45	0,017	167	241	8.067	8.308											
Circuit Line 2.3																															
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	632	632	12,79	180	0,029	-27.509	8,35	0,042	119	172	10.311	10.483											
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	632	1.263	25,59	2.438	0,193	-264.536	59,92	0,300	1.607	2.323	105.778	108.101											
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	632	1.895	38,38	4.143	0,219	-198.763	67,89	0,339	2.731	3.947	79.896	83.843											
										5.684																					
Circuit line from S/S Utenza to S/S Terna																															
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost											
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€	€											
	Alt 1	30 kV cable connection to Terna Substation																													
MV Line	L _{SS-Terna}	18.900	3//3x1x500	593	1,661	1,890	5,670	2,516		12.632	85,30	108.789	0,861	-4.683.262	319,56	1,598	215.166	310.960	2.710.663	3.021.623											
	Alt 2	150 kV cable connection to Terna Substation																													

							Wind speed:	7	Power Generation:					12.632	659 Hrs				
HV Line	L _{SS-Terna}	18.900	1 x 400	509	1,890	8,127	2,967	8,344	12.632	51,18	14.851,70	0,118	-20.836,250	382,49	0,255	9.791,40	14.150,63	1.984.500	1.998.651
Optimisation summary tables																			
Cable ARE4HIRX - 18/30 kV																			
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	KVAR	Perdite kW	% Perdite	Max. % DV				
Line	Lenght	Cable size	Drum Nos	Joints	Terminations														
60	L ₇₋₁	530	3x1x70	1	6		147	-22.430	97	140	8.407	-	2.307	27,5	0,22	0,37			
66	L ₁₉₋₃	490	3x1x70	1	6		136	-20.737	90	130	7.773								
72	L ₁₀₋₁₂	1150	3x1x70	3	6		319	-48.669	210	304	18.243			110,0	0,87				
73	L ₁₃₋₁₂	490	3x1x70	1	6		136	-20.737	90	130	7.773	246		25,5	0,20				
83	L ₄₋₁₆	1200	3x1x70	3	6		333	-50.785	220	317	19.036								
87	L ₁₋₈	700	3x1x70	2	3	6	194	-29.625	128	185	11.104	212		39,0	0,31				
93	L ₁₄₋₆	650	3x1x70	2	3	6	180	-27.509	119	172	10.311			5,0	0,04				
	Total	5.210	3x1x70	13	18	42	1.446	-220.494	953	1.377	82.647								
61	L ₁₋₁₈	500	3x1x150	2	3	6	259	-28.142	171	247	11.253	-	20.836	14,9	0,12	0,25			
67	L ₃₋₂₀	550	3x1x150	2	3	6	285	-30.956	188	272	12.378								
84	L _{16-Cab.2}	5.800	3x1x150	20	57	6	3.008	-326.449	1.983	2.866	130.535								
88	L ₈₋₅	2.360	3x1x150	8	21	6	1.224	-132.831	807	1.166	53.114	-	22.685	222	1,76	0,37			
94	L ₆₋₂₁	4.700	3x1x150	16	45	6	2.438	-264.536	1.607	2.323	105.778								
95	L _{21-Cab.2}	3.550	3x1x150	12	33	6	4.143	-198.763	2.731	3.947	79.896								
	Total	17.460	3x1x150	60	162	36	11.357	-981.677	7.487	10.821	392.955								
62	L ₁₈₋₂	1.200	1x300	3	6		237	-29.191	156	226	13.446								
63	L _{2-Cab.1}	5.100	1x300	9	6	6	1.790	-123.400	1.180	1.706	57.143								
68	L ₂₀₋₁₇	2.460	1x300	6	3	6	486	-59.841	320	463	27.563								
69	L _{17-Cab.1}	1.170	1x300	1	6		411	-28.309	271	391	13.109								
74	L _{12-Cab.1}	6.150	1x300	12	9	6	1.214	-149.602	801	1.157	68.908								
89	L ₅₋₉	1.920	1x300	3	6		379	-46.705	250	361	21.513								
90	L _{9-Cab.2}	720	1x300	1	6		253	-34.842	167	241	8.067								
	Total	16.080	3x1x300	35	18	42	4.769	-471.889	3.144	4.544	209.750								
77	L _{Cab.1-Cab.2}	22.800	1x500	36	30	12	9.925	-633.037	13.086	18.913	363.334								
	Total	22.800	1x500	36	30	12	27.497	-2.307.097	24.671	35.655	1.048.686								
Alt.2-150	L _{SS-Terna}	56.700	1x400 HV	72	69	6	14.852	-20.836.250	9.791	14.151	1.984.500								
							Grand Total Alt.2	42.348	-23.143.347	34.463	49.806	3.033.186							

Wind speed:		8		Power Generation:		19.120		611 Hrs			
Basic Design Data				Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy				
				kW/unit	hours	MWh	MWh				
Operation Hypotesis				Trafos:	2.500	50.000	2 x	[kVA]			
Cos fi:	0,95	sin fi	0,31	V _{1n} =	690	30.000	[V]	1,00	2987,87	2,99	59,76
Rated Voltage(kV)	30			V _{2n} =	30	150	[kV]	55,90	669,77	37,44	748,80
Generation Power (kW)	956,0			I _N	48	192	[A]	191,50	670,08	128,32	2.566,40
Generation hours:	611,5	Hrs/year		I	19,37	38,73	[A]	381,90	677,25	258,64	5.172,84
WTG nos.	20			V _{cc} =	7,00	12,00	%	631,60	659,28	416,40	8.328,00
Losses coorrection factor: Equivalent operation versus effective one				1,00				1.350,20	541,85	731,60	14.632,00
Cp = Net Present value of losses: $ax^i / ((1+i)^n - 1) / ((1+i)^n - 1)xi$								1.750,80	460,09	805,52	16.110,40
				P _{fe} =	5,50	19,50	kW	2.004,30	380,74	763,12	15.262,40
				P _{cu} =	18,00	141,00	kW	2.083,40	303,93	633,20	12.664,00
where	a =	selling price	0,126	P _{tot} =	23,50	160,50		2.098,30	230,89	484,48	9.689,60
	i =	Net present value interest rate	0,06	Zn	360,00	450,00	Ohm	2.101,20	167,45	351,84	7.036,80
	n =	number of years for return of investment:	20	Z ₂₀ =	25,20	54,00	Ohm	2.100,40	116,40	244,48	4.889,60
								2.098,70	77,61	162,88	3.257,60
	Cp =	1,4452101	€/kWh					2.097,70	49,69	104,24	2.084,80
				R ₂₀ =	2,59	1,27	Ohm	2.095,50	30,66	64,24	1.284,80
				X ₂₀ =	25,07	53,99	Ohm	2.093,90	18,26	38,24	764,80
Generation factor			1	Q _{cosfi=1}	28.204	242.974	VAR	2.090,90	6,73	14,08	281,60
				Q _{tot}		1.050.036	VAR		8660,00	5.826	116.525
											2.097.680

Wind speed: 8 Power Generation: 19.120 611 Hrs																				
M.V. branches parameters calculation																				
Circuit Line 1 and 2																				
Node No.	Param. L _(i-1,i)	Lenght mts	Cable Al mm ²	R.c.c. A	R _{cable} ohm	X _{cable} ohm	Capac _{cable} microF	Z _{cable} ohm	PG _i kW	PG _{0-i} kW	I _{0-i} A	P _{Li} W	Losses %	Q _{toLi} VAR	DV _i V	Dvi%	En. Lost kWh/year	Losses Cost €	Cable Cost €	Total Cost
Circuit Line 1.1																				
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	956	956	19,37	337	0,035	-22.383	10,30	0,052	206	298	8.407	8.705
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	956	1.912	38,73	594	0,031	-27.990	9,65	0,048	363	525	11.253	11.778
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	956	2.868	58,10	543	0,019	-28.933	6,53	0,033	332	480	13.446	13.925
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	956	3.824	77,47	4.101	0,107	-121.451	36,98	0,185	2.508	3.624	57.143	60.768
Circuit Line 1.2																				
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	956	956	19,37	312	0,033	-20.694	9,52	0,048	190	275	7.773	8.048
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	956	1.912	38,73	654	0,034	-30.789	10,61	0,053	400	578	12.378	12.956
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	956	2.868	58,10	1.113	0,039	-59.312	13,38	0,067	680	983	27.563	28.547
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	956	3.824	77,47	941	0,025	-27.862	8,48	0,042	575	831	13.109	13.941
Circuit Line 1.3																				
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	956	956	19,37	731	0,076	-48.567	22,35	0,112	447	646	18.243	18.889
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	956	956	19,37	312	0,033	-20.694	9,52	0,048	190	275	7.773	8.048
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	956	2.868	58,10	2.782	0,097	-148.280	33,45	0,167	1.701	2.458	68.908	71.367
										10.516										
Line from Cab. 1 to Cab. 2																				
	L _{Cab1-Cab.2}	3.800	2/3x1x500	593	0,334	0,380	1,140	0,506	956	10.516	106,52	22.738	0,216	-618.460	80,19	0,401	27.807	40.187	363.334	403.521
Circuit Line 2.1																				
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	956	956	19,37	763	0,080	-50.679	23,32	0,117	466	674	19.036	19.710
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	956	1.912	38,73	6.892	0,360	-324.683	111,93	0,560	4.214	6.090	130.535	136.625
Circuit Line 2.2																				
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	956	956	19,37	445	0,047	-29.563	13,61	0,068	272	393	11.104	11.497
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	956	1.912	38,73	2.804	0,147	-132.113	45,54	0,228	1.715	2.478	53.114	55.592
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	956	2.868	58,10	868	0,030	-46.292	10,44	0,052	531	767	21.513	22.280
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	956	3.824	77,47	579	0,015	-34.292	5,22	0,026	354	512	8.067	8.579
Circuit Line 2.3																				
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	956	956	19,37	413	0,043	-27.451	12,63	0,063	253	365	10.311	10.676
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	956	1.912	38,73	5.585	0,292	-263.106	90,70	0,454	3.415	4.935	105.778	110.713
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	956	2.868	58,10	9.491	0,331	-196.332	102,76	0,514	5.803	8.387	79.896	88.283
										8.604										
Circuit line from S/S Utenza to S/S Terna																				
Node No.	Param. L _(i-1,i)	Lenght mts	Cable Al mm ²	R.c.c. A	R _{cable} ohm	X _{cable} ohm	Capac _{cable} microF	Z _{cable} ohm	PG _i kW	PG _{0-i} kW	I _{0-i} A	P _{Li} W	Losses %	Q _{toLi} VAR	DV _i V	Dvi%	En. Lost kWh/year	Losses Cost €	Cable Cost €	Total Cost
Alt 1 30 kV cable connection to Terna Substation																				
MV Line	L _{SS-Terna}	18.900	3/3x1x500	593	1,661	1,890	5,670	2,516		19.120	129,11	249.239	1,304	-4.523.478	483,84	2,419	457.202	660.753	2.710.663	3.371.415
Alt 2 150 kV cable connection to Terna Substation																				

							Wind speed:	8	Power Generation:				19.120	611 Hrs					
HV Line	L _{SS-Terms}	18.900	1 x 400	509	1,890	8,127	2,967	8,344	19.120	77,47	34.025,76	0,178	-20.671.353	579,28	0,386	20.805,54	30.068,38	1.984.500	2.014.568
Optimisation summary tables																			
Cable ARE4HIRX - 18/30 kV																			
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	KVAR	Perdite kW	% Perdite	Max. % DV				
Line	Length	Cable size	Drum Nos	Joints	Terminations														
60	L ₇₋₁	530	3x1x70	1	6		337	-22.383	206	298	8.407	-	2.280	63,0	0,33	0,56			
66	L ₁₉₋₃	490	3x1x70	1	6		312	-20.694	190	275	7.773								
72	L ₁₀₋₁₂	1150	3x1x70	3	6	6	731	-48.567	447	646	18.243			110,0	0,58				
73	L ₁₃₋₁₂	490	3x1x70	1	6		312	-20.694	190	275	7.773	564		58,3	0,31				
83	L ₄₋₁₆	1200	3x1x70	3	6	6	763	-50.679	466	674	19.036								
87	L ₁₋₈	700	3x1x70	2	3	6	445	-29.563	272	393	11.104	486		39,0	0,20				
93	L ₁₄₋₆	650	3x1x70	2	3	6	413	-27.451	253	365	10.311			11,4	0,06				
	Total	5.210	3x1x70	13	18	42	3.312	-220.031	2.025	2.927	82.647								
61	L ₁₋₁₈	500	3x1x150	2	3	6	594	-27.990	363	525	11.253	-	20.671	34,0	0,18	0,39			
67	L ₃₋₂₀	550	3x1x150	2	3	6	654	-30.789	400	578	12.378								
84	L _{16-Cab.2}	5.800	3x1x150	20	57	6	6.892	-324.683	4.214	6.090	130.535								
88	L ₈₋₅	2.360	3x1x150	8	21	6	2.804	-132.113	1.715	2.478	53.114	-	21.901	316	1,65	0,56			
94	L ₆₋₂₁	4.700	3x1x150	16	45	6	5.585	-263.106	3.415	4.935	105.778								
95	L _{21-Cab.2}	3.550	3x1x150	12	33	6	9.491	-196.332	5.803	8.387	79.896								
	Total	17.460	3x1x150	60	162	36	26.019	-975.013	15.909	22.993	392.955								
62	L ₁₈₋₂	1.200	1x300	3	6		543	-28.933	332	480	13.446								
63	L _{2-Cab.1}	5.100	1x300	9	6	6	4.101	-121.451	2.508	3.624	57.143								
68	L ₂₀₋₁₇	2.460	1x300	6	3	6	1.113	-59.312	680	983	27.563								
69	L _{17-Cab.1}	1.170	1x300	1	6		941	-27.862	575	831	13.109								
74	L _{12-Cab.1}	6.150	1x300	12	9	6	2.782	-148.280	1.701	2.458	68.908								
89	L ₅₋₉	1.920	1x300	3	6		868	-46.292	531	767	21.513								
90	L _{9-Cab.2}	720	1x300	1	6		579	-34.292	354	512	8.067								
	Total	16.080	3x1x300	35	18	42	10.927	-466.422	6.681	9.656	209.750								
77	L _{Cab.1-Cab.2}	22.800	1x500	36	30	12	22.738	-618.460	27.807	40.187	363.334								
	Total	22.800	1x500	36	30	12	62.996	-2.279.926	52.423	75.762	1.048.686								
Alt.2-150	L _{SS-Terms}	56.700	1x400 HV	72	69	6	34.026	-20.671.353	20.806	30.068	1.984.500								
							Grand Total Alt.2	97.021	-22.951.278	73.229	105.831	3.033.186							

				Wind speed:	10					Power Generation:	35.016					460 Hrs				
				Basic Design Data							Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy						
											kW/unit	hours	MWh	MWh						
Operation Hypotesis				Trafos:			2 x					1,00	2987,87	2,99	59,76					
							2.500	50.000	[kVA]					55,90	669,77	37,44	748,80			
											191,50	670,08	128,32	2.566,40						
Cos fi:	0,95			sin fi	0,31					381,90	677,25	258,64	5.172,84							
Rated Voltage(kV)				30					V _{1n} =	690	30.000	[V]	631,60	659,28	416,40	8.328,00				
Generation Power (kW)				1.750,8					V _{2n} =	30	150	[kV]	956,00	611,46	584,56	11.691,20				
Generation hours:				460,1	Hrs/year					I _N	48	192	[A]	1.350,20	541,85	731,60	14.632,00			
WTG nos.				20					I	35,47	70,94	[A]	1.750,80	460,09	805,52	16.110,40				
Losses coorrection factor: Equivalent operation versus effective one				1,00							V _{cc} =	7,00	12,00	%	2.004,30	380,74	763,12	15.262,40		
Cp = Net Present value of losses: $ax^i((1+i)^n-1)/((1+i)^n)xi$											P _{te} =	5,50	19,50	kW	2.083,40	303,93	633,20	12.664,00	633.200,00	
											P _{cu} =	9,8	19,2	kW	2.098,30	230,89	484,48	9.689,60	484.480,00	
where	a =	selling price		0,126							P _{tot} =	18,00	141,00	kW	2.101,20	167,45	351,84	7.036,80	351.840,00	
	i =	Net present value interest rate		0,06							Z _n	23,50	160,50	Ohm	2.100,40	116,40	244,48	4.889,60	244.480,00	
	n =	number of years for return of investment:		20							Z ₂₀ =	360,00	450,00	Ohm	2.098,70	77,61	162,88	3.257,60	162.880,00	
	Cp =	1,4452101	€/kWh									25,20	54,00	Ohm	2.097,70	49,69	104,24	2.084,80	104.240,00	
											R ₂₀ =	2,59	1,27	Ohm	2.095,50	30,66	64,24	1.284,80	64.240,00	
											X ₂₀ =	25,07	53,99	Ohm	2.093,90	18,26	38,24	764,80	38.240,00	
Generation factor				1							Q _{coeff=1}	94,596	814,924	VAR	2.090,90	6,73	14,08	281,60	14.080,00	
											Q _{tot}	3.521.775		VAR	8660,00		5.826	116.525	2.097.680	

Wind speed: 10																			Power Generation: 35.016				460 Hrs			
M.V. branches parameters calculation																										
Circuit Line 1 and 2																										
Node No.	Param. L _{(i-1)-i}	Lenght mts	Cable Al mm ²	R.c.c. A	R _{cable} ohm	X _{cable} ohm	Capac _{cable} microF	Z _{cable} ohm	PG _i kW	PG _{0-i} kW	I _{0-i} A	P _{Li} W	Losses %	Q _{toLi} VAR	DV _i V	Dvi%	En. Lost kWh/year	Losses Cost €	Cable Cost €	Total Cost						
Circuit Line 1.1																										
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	1.751	1.751	35,47	1.130	0,065	-22.187	18,87	0,094	520	751	8.407	9.159						
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	1.751	3.502	70,94	1.993	0,057	-27.354	17,67	0,088	917	1.325	11.253	12.578						
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	1.751	5.252	106,40	1.820	0,035	-27.855	11,95	0,060	838	1.210	13.446	14.656						
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	1.751	7.003	141,87	13.755	0,196	-113.310	67,73	0,339	6.328	9.146	57.143	66.289						
Circuit Line 1.2																										
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	1.751	1.751	35,47	1.045	0,060	-20.512	17,44	0,087	481	695	7.773	8.468						
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	1.751	3.502	70,94	2.192	0,063	-30.090	19,44	0,097	1.008	1.457	12.378	13.836						
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	1.751	5.252	106,40	3.732	0,071	-57.103	24,50	0,123	1.717	2.482	27.563	30.045						
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	1.751	7.003	141,87	3.156	0,045	-25.995	15,54	0,078	1.452	2.098	13.109	15.208						
Circuit Line 1.3																										
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	1.751	1.751	35,47	2.452	0,140	-48.141	40,94	0,205	1.128	1.630	18.243	19.873						
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	1.751	1.751	35,47	1.045	0,060	-20.512	17,44	0,087	481	695	7.773	8.468						
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	1.751	5.252	106,40	9.330	0,178	-142.758	61,26	0,306	4.293	6.204	68.908	75.112						
										19.259																
Line from Cab. 1 to Cab. 2																										
	L _{Cab1-Cab.2}	3.800	2//3x1x500	593	0,334	0,380	1,140	0,506	1.751	19.259	195,07	76.263	0,396	-557.567	146,88	0,734	70.175	101.417	363.334	464.751						
Node No.	Param. L _{(i-1)-i}	Lenght mts	Cable Al mm ²	R.c.c. A	R _{cable} ohm	X _{cable} ohm	Capac _{cable} microF	Z _{cable} ohm	PG _i kW	PG _{0-i} kW	I _{0-i} A	P _{Li} W	Losses %	Q _{toLi} VAR	DV _i V	Dvi%	En. Lost kWh/year	Losses Cost €	Cable Cost €	Total Cost						
Circuit Line 2.1																										
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	1.751	1.751	35,47	2.559	0,146	-50.234	42,72	0,214	1.177	1.701	19.036	20.737						
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	1.751	3.502	70,94	23.114	0,660	-317.310	204,99	1,025	10.634	15.369	130.535	145.904						
Circuit Line 2.2																										
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	1.751	1.751	35,47	1.493	0,085	-29.303	24,92	0,125	687	992	11.104	12.097						
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	1.751	3.502	70,94	9.405	0,269	-129.112	83,41	0,417	4.327	6.254	53.114	59.368						
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	1.751	5.252	106,40	2.913	0,055	-44.568	19,12	0,096	1.340	1.937	21.513	23.450						
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	1.751	7.003	141,87	1.942	0,028	-31.993	9,56	0,048	893	1.291	8.067	9.359						
Circuit Line 2.3																										
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	1.751	1.751	35,47	1.386	0,079	-27.210	23,14	0,116	638	922	10.311	11.233						
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	1.751	3.502	70,94	18.730	0,535	-257.130	166,11	0,831	8.618	12.454	105.778	118.232						
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	1.751	5.252	106,40	31.832	0,606	-186.177	188,20	0,941	14.645	21.166	79.896	101.062						
										15.757																
Circuit line from S/S Utenza to S/S Terna																										
Node No.	Param. L _{(i-1)-i}	Lenght mts	Cable Al mm ²	R.c.c. A	R _{cable} ohm	X _{cable} ohm	Capac _{cable} microF	Z _{cable} ohm	PG _i kW	PG _{0-i} kW	I _{0-i} A	P _{Li} W	Losses %	Q _{toLi} VAR	DV _i V	Dvi%	En. Lost kWh/year	Losses Cost €	Cable Cost €	Total Cost						
Alt 1 30 kV cable connection to Terna Substation																										
MV Line	L _{SS-Terna}	18.900	3//3x1x500	593	1,661	1,890	5,670	2,516		35.016	236,45	835.936	2,387	-3.856.019	886,79	4,434	1.153.809	1.667.496	2.710.663	4.378.159						
Alt 2 150 kV cable connection to Terna Substation																										

							Wind speed:	10	Power Generation:				35.016	460 Hrs					
HV Line	L _{SS-Terna}	18.900	1 x 400	509	1,890	8,127	2,967	8,344	35.016	141,87	114.120,89	0,326	-19.982.535	1.062,44	0,708	52.505,52	75.881,50	1.984.500	2.060.382
									Optimisation summary tables										
Cable ARE4HIRX - 18/30 kV																			
Cables & Cable Accessories Summary									Losses - W	VAR	kWh/year	Losses €	Cable cost €	KVAR	Perdite kW	% Perdite	Max. % DV		
	Line	Length	Cable size	Drum Nos	Joints	Terminations													
60	L ₇₋₁	530	3x1x70	1		6	1.130	-22.187	520	751	8.407	-	2.166	211,3	0,60	1,02			
66	L ₁₉₋₃	490	3x1x70	1		6	1.045	-20.512	481	695	7.773								
72	L ₁₀₋₁₂	1150	3x1x70	3	6	6	2.452	-48.141	1.128	1.630	18.243			110,0	0,31				
73	L ₁₃₋₁₂	490	3x1x70	1		6	1.045	-20.512	481	695	7.773	1.892		195,6	0,56				
83	L ₄₋₁₆	1200	3x1x70	3	6	6	2.559	-50.234	1.177	1.701	19.036								
87	L ₁₋₈	700	3x1x70	2	3	6	1.493	-29.303	687	992	11.104	1.630		39,0	0,11				
93	L ₁₄₋₆	650	3x1x70	2	3	6	1.386	-27.210	638	922	10.311			38,3	0,11				
	Total	5.210	3x1x70	13	18	42	11.109	-218.099	5.111	7.387	82.647								
61	L ₁₋₁₈	500	3x1x150	2	3	6	1.993	-27.354	917	1.325	11.253	-	19.983	114,1	0,33	0,71			
67	L ₃₋₂₀	550	3x1x150	2	3	6	2.192	-30.090	1.008	1.457	12.378								
84	L _{16-Cab.2}	5.800	3x1x150	20	57	6	23.114	-317.310	10.634	15.369	130.535								
88	L ₈₋₅	2.360	3x1x150	8	21	6	9.405	-129.112	4.327	6.254	53.114	-	18.627	708	2,02	1,02			
94	L ₆₋₂₁	4.700	3x1x150	16	45	6	18.730	-257.130	8.618	12.454	105.778								
95	L _{21-Cab.2}	3.550	3x1x150	12	33	6	31.832	-186.177	14.645	21.166	79.896								
	Total	17.460	3x1x150	60	162	36	87.265	-947.173	40.150	58.025	392.955								
62	L ₁₈₋₂	1.200	1x300	3		6	1.820	-27.855	838	1.210	13.446								
63	L _{2-Cab.1}	5.100	1x300	9	6	6	13.755	-113.310	6.328	9.146	57.143								
68	L ₂₀₋₁₇	2.460	1x300	6	3	6	3.732	-57.103	1.717	2.482	27.563								
69	L _{17-Cab.1}	1.170	1x300	1		6	3.156	-25.995	1.452	2.098	13.109								
74	L _{12-Cab.1}	6.150	1x300	12	9	6	9.330	-142.758	4.293	6.204	68.908								
89	L ₅₋₉	1.920	1x300	3		6	2.913	-44.568	1.340	1.937	21.513								
90	L _{9-Cab.2}	720	1x300	1		6	1.942	-31.993	893	1.291	8.067								
	Total	16.080	3x1x300	35	18	42	36.648	-443.583	16.861	24.368	209.750								
77	L _{Cab.1-Cab.2}	22.800	1x500	36	30	12	76.263	-557.567	70.175	101.417	363.334								
	Total	22.800	1x500	36	30	12	211.284	-2.166.422	132.297	191.196	1.048.686								
Alt.2-150	L _{SS-Terna}	56.700	1x400 HV	72	69	6	114.121	-19.982.535	52.506	75.882	1.984.500								
							Grand Total Alt.2	325.405	-22.148.957	184.802	267.078	3.033.186							

Wind speed:		11		Power Generation:		40.086		381 Hrs			
Basic Design Data				Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy				
				kW/unit	hours	MWh	MWh				
				2 x	1,00	2987,87	2,99	59,76			
Operation Hypotesis				Trafos:	2.500	50.000	[kVA]				
Cos fi:	0,95	sin fi	0,31	V _{ln} =	690	30.000	[V]	55,90	669,77	37,44	748,80
Rated Voltage(kV)	30	V _{zn} =	30	150	[kV]	631,60	659,28	416,40	8.328,00		
Generation Power (kW)	2.004,3	I _N	48	192	[A]	956,00	611,46	584,56	11.691,20		
Generation hours:	380,7	I	40,60	81,21	[A]	1.350,20	541,85	731,60	14.632,00		
WTG nos.	20	V _{sc} =	7,00	12,00	%	1.750,80	460,09	805,52	16.110,40		
Losses correction factor: Equivalent operation versus effective one				P _{fe} =	5,50	19,50	kW	2.004,30	380,74	763,12	15.262,40
Cp = Net Present value of losses: $ax((1+i)^n-1)/((1+i)^n)xi$				P _{cu}	12,8	25,1	kW	2.083,40	303,93	633,20	12.664,00
where	a =	selling price	0,126	P _{cu} =	18,00	141,00	kW	2.098,30	230,89	484,48	9.689,60
	i =	Net present value interest rate	0,06	P _{tot} =	23,50	160,50		2.101,20	167,45	351,84	7.036,80
	n =	number of years for return of investment:	20	Z _n	360,00	450,00	Ohm	2.100,40	116,40	244,48	4.889,60
				Z ₂₀ =	25,20	54,00	Ohm	2.098,70	77,61	162,88	3.257,60
								2.097,70	49,69	104,24	2.084,80
	Cp =	1,4452101	€/kWh	R ₂₀ =	2,59	1,27	Ohm	2.095,50	30,66	64,24	1.284,80
				X ₂₀ =	25,07	53,99	Ohm	2.093,90	18,26	38,24	764,80
Generation factor			1	Q _{cosfi=1}	123.973	1.067.996	VAR	2.090,90	6,73	14,08	281,60
				Q _{tot}		4.615.449	VAR		8660,00	5.826	116.525
											2.097.680

Wind speed: 11 Power Generation: 40.086 381 Hrs																				
M.V. branches parameters calculation																				
Circuit Line 1 and 2																				
Node No.	Param. L _{(i-1)-i}	Lenght mts	Cable Al mm ²	R.c.c. A	R _{cable} ohm	X _{cable} ohm	Capac _{cable} microF	Z _{cable} ohm	PG _i kW	PG _{0-i} kW	I _{0-i} A	P _{Li} W	Losses %	Q _{totLi} VAR	DV _i V	Dvi%	En. Lost kWh/year	Losses Cost €	Cable Cost €	Total Cost
Circuit Line 1.1																				
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	2,004	2,004	40,60	1,481	0,074	-22,100	21,60	0,108	564	815	8,407	9,222
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	2,004	4,009	81,21	2,611	0,065	-27,073	20,23	0,101	994	1,437	11,253	12,690
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	2,004	6,013	121,81	2,386	0,040	-27,378	13,68	0,068	908	1,313	13,446	14,758
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	2,004	8,017	162,41	18,026	0,225	-109,708	77,54	0,388	6,863	9,919	57,143	67,063
Circuit Line 1.2																				
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	2,004	2,004	40,60	1,369	0,068	-20,432	19,97	0,100	521	753	7,773	8,526
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	2,004	4,009	81,21	2,873	0,072	-29,780	22,25	0,111	1,094	1,581	12,378	13,959
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	2,004	6,013	121,81	4,891	0,081	-56,126	28,05	0,140	1,862	2,691	27,563	30,255
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	2,004	8,017	162,41	4,135	0,052	-25,168	17,79	0,089	1,575	2,276	13,109	15,385
Circuit Line 1.3																				
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	2,004	2,004	40,60	3,214	0,160	-47,952	46,86	0,234	1,224	1,768	18,243	20,011
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	2,004	2,004	40,60	1,369	0,068	-20,432	19,97	0,100	521	753	7,773	8,526
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	2,004	6,013	121,81	12,227	0,203	-140,315	70,13	0,351	4,656	6,728	68,908	75,636
										22,047										
Line from Cab. 1 to Cab. 2																				
	L _{Cab1-Cab.2}	3.800	2/3x1x500	593	0,334	0,380	1,140	0,506	2,004	22,047	223,32	99,946	0,453	-530,624	168,16	0,841	76,107	109,990	363,334	473,324
Circuit Line 2.1																				
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	2,004	2,004	40,60	3,353	0,167	-50,037	48,90	0,245	1,277	1,845	19,036	20,881
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	2,004	4,009	81,21	30,292	0,756	-314,047	234,67	1,173	11,533	16,668	130,535	147,203
Circuit Line 2.2																				
14	L ₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	2,004	2,004	40,60	1,956	0,098	-29,188	28,53	0,143	745	1,076	11,104	12,180
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	2,004	4,009	81,21	12,326	0,307	-127,785	95,49	0,477	4,693	6,782	53,114	59,896
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	2,004	6,013	121,81	3,817	0,063	-43,806	21,89	0,109	1,453	2,101	21,513	23,613
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	2,004	8,017	162,41	2,545	0,032	-30,976	10,95	0,055	969	1,400	8,067	9,468
Circuit Line 2.3																				
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	2,004	2,004	40,60	1,816	0,091	-27,103	26,49	0,132	692	999	10,311	11,310
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	2,004	4,009	81,21	24,547	0,612	-254,486	190,16	0,951	9,346	13,507	105,778	119,285
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	2,004	6,013	121,81	41,717	0,694	-181,684	215,45	1,077	15,883	22,955	79,896	102,851
										18,039										
Circuit line from S/S Utenza to S/S Terna																				
Node No.	Param. L _{(i-1)-i}	Lenght mts	Cable Al mm ²	R.c.c. A	R _{cable} ohm	X _{cable} ohm	Capac _{cable} microF	Z _{cable} ohm	PG _i kW	PG _{0-i} kW	I _{0-i} A	P _{Li} W	Losses %	Q _{totLi} VAR	DV _i V	Dvi%	En. Lost kWh/year	Losses Cost €	Cable Cost €	Total Cost
Alt 1 30 kV cable connection to Terna Substation																				
MV Line	L _{SS-Terna}	18.900	3/3x1x500	593	1,661	1,890	5,670	2,516	40,086		270,69	1,095,532	2,733	-3,560,687	1,015,44	5,077	1,251,343	1,808,454	2,710,663	4,519,117
Alt 2 150 kV cable connection to Terna Substation																				

							Wind speed:		11	Power Generation:			40.086	381 Hrs						
HV Line	L _{SS-Terna}	18.900	1 x 400	509	1,890	8,127	2,967	8,344		40.086	162,41	149.560,71	0,373	-19.677.752	1.216,83	0,811	56.943,96	82.295,98	1.984.500	2.066.796
Optimisation summary tables																				
Cable ARE4HIRX - 18/30 kV																				
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	kVAR	Perdite kW	% Perdite	Max. % DV					
Line	Lenght	Cable size	Drum Nos	Joints	Terminations															
60	L ₇₋₁	530	3x1x70	1	6		1.481	-22.100	564	815	8.407	-	2.116	276,9	0,69	1,17				
66	L ₁₉₋₃	490	3x1x70	1	6		1.369	-20.432	521	753	7.773									
72	L ₁₀₋₁₂	1150	3x1x70	3	6		3.214	-47.952	1.224	1.768	18.243			110,0	0,27					
73	L ₁₃₋₁₂	490	3x1x70	1	6		1.369	-20.432	521	753	7.773	2.479		256,4	0,64					
83	L ₄₋₁₆	1200	3x1x70	3	6		3.353	-50.037	1.277	1.845	19.036									
87	L ₁₋₈	700	3x1x70	2	3	6	1.956	-29.188	745	1.076	11.104	2.136		39,0	0,10					
93	L ₁₄₋₆	650	3x1x70	2	3	6	1.816	-27.103	692	999	10.311			50,2	0,13					
	Total	5.210	3x1x70	13	18	42	14.559	-217.244	5.543	8.011	82.647									
61	L ₁₋₁₈	500	3x1x150	2	3	6	2.611	-27.073	994	1.437	11.253	-	19.678	149,6	0,37	0,81				
67	L ₃₋₂₀	550	3x1x150	2	3	6	2.873	-29.780	1.094	1.581	12.378									
84	L _{16-Cab.2}	5.800	3x1x150	20	57	6	30.292	-314.047	11.533	16.668	130.535									
88	L ₈₋₅	2.360	3x1x150	8	21	6	12.326	-127.785	4.693	6.782	53.114	-	17.179	882	2,20	1,17				
94	L ₆₋₂₁	4.700	3x1x150	16	45	6	24.547	-254.486	9.346	13.507	105.778									
95	L _{21-Cab.2}	3.550	3x1x150	12	33	6	41.717	-181.684	15.883	22.955	79.896									
	Total	17.460	3x1x150	60	162	36	114.365	-934.855	43.544	62.930	392.955									
62	L ₁₈₋₂	1.200	1x300	3	6		2.386	-27.378	908	1.313	13.446									
63	L _{2-Cab.1}	5.100	1x300	9	6	6	18.026	-109.708	6.863	9.919	57.143									
68	L ₂₀₋₁₇	2.460	1x300	6	3	6	4.891	-56.126	1.862	2.691	27.563									
69	L _{17-Cab.1}	1.170	1x300	1	6		4.135	-25.168	1.575	2.276	13.109									
74	L _{12-Cab.1}	6.150	1x300	12	9	6	12.227	-140.315	4.656	6.728	68.908									
89	L ₅₋₉	1.920	1x300	3	6		3.817	-43.806	1.453	2.101	21.513									
90	L _{9-cab.2}	720	1x300	1	6		2.545	-30.976	969	1.400	8.067									
	Total	16.080	3x1x300	35	18	42	48.028	-433.477	18.286	26.428	209.750									
77	L _{cab.1-Cab.2}	22.800	1x500	36	30	12	99.946	-530.624	76.107	109.990	363.334									
	Total	22.800	1x500	36	30	12	276.898	-2.116.200	143.480	207.359	1.048.686									
Alt.2-150	L _{SS-Terna}	56.700	1x400 HV	72	69	6	149.561	-19.677.752	56.944	82.296	1.984.500									
							Grand Total Alt.2	426.459	-21.793.953	200.424	289.655	3.033.186								

				Wind speed:	≥ 12					Power Generation:	41.940					1.002	Hrs			
				Basic Design Data								Unit power	Rev. Op. Hours	Unit Gen. Energy	Total Gen. Energy					
												kW/unit	hours	MWh	MWh					
Operation Hypotesis				Trafos:				2 x				1,00	2987,87	2,99	59,76					
												55,90	669,77	37,44	748,80					
												191,50	670,08	128,32	2.566,40					
Cos fi:	0,95			sin fi	0,31			V _{1n} =	690	30.000	[V]	381,90	677,25	258,64	5.172,84					
Rated Voltage(kV)				30				V _{2n} =	30	150	[kV]	631,60	659,28	416,40	8.328,00					
Generation Power (kW)				2.097,0				I _N	48	192	[A]	956,00	611,46	584,56	11.691,20					
Generation hours:				1.001,6	Hrs/year				I	42,48	84,96	[A]	1.350,20	541,85	731,60	14.632,00				
WTG nos.				20				V _{cc} =	7,00	12,00	%	1.750,80	460,09	805,52	16.110,40	MWh/Unit				
Losses coorrection factor: Equivalent operation versus effective one				1,00								2.004,30	380,74	763,12	15.262,40					
Cp = Net Present value of losses: $ax'((1+i)^n-1)/((1+i)^n)xi$												P _{cu}	14,0	27,5	kW	2.083,40	303,93	633,20	12.664,00	633.200,00
												P _{cu}	18,00	141,00	kW	2.098,30	230,89	484,48	9.689,60	484.480,00
where	a =	selling price			0,126				P _{tot} =	23,50	160,50			2.101,20	167,45	351,84	7.036,80	351.840,00		
	i =	Net present value interest rate			0,06				Zn	360,00	450,00	Ohm			2.100,40	116,40	244,48	4.889,60	244.480,00	
	n =	number of years for return of investment:			20				Z ₂₀ =	25,20	54,00	Ohm			2.098,70	77,61	162,88	3.257,60	162.880,00	
														2.097,70	49,69	104,24	2.084,80	104.240,00		
	Cp =	1,4452101	€/kWh					R ₂₀ =	2,59	1,27	Ohm			2.095,50	30,66	64,24	1.284,80	64.240,00		
									X ₂₀ =	25,07	53,99	Ohm			2.093,90	18,26	38,24	764,80	38.240,00	
Generation factor				1							Q _{cosfi=1}	135.706	1.169.071	VAR	2.090,90	6,73	14,08	281,60	14.080,00	
												Q _{tot}		5.052.256	VAR		8660,00	5,826	116,525	2.097.680

Wind speed: ≥ 12																				Power Generation: 41.940				1.002 Hrs	
M.V. branches parameters calculation										2.097,0		1.001,62													
Circuit Line 1 and 2																									
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost					
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€						
Circuit Line 1.1																									
1	L ₇₋₁	530	1 x 70	200	0,299	0,074	0,080	0,309	2,097	2,097	42,48	1,621	0,077	-22,065	22,60	0,113	1,624	2,347	8,407	10,754					
2	L ₁₋₁₈	500	1 x 150	306	0,132	0,060	0,100	0,145	2,097	4,194	84,96	2,859	0,068	-26,961	21,17	0,106	2,863	4,138	11,253	15,391					
3	L ₁₈₋₂	400	1 x 300	455	0,054	0,045	0,104	0,070	2,097	6,291	127,44	2,612	0,042	-27,188	14,32	0,072	2,616	3,780	13,446	17,226					
4	L _{2-Cab.1}	1.700	1 x 300	455	0,228	0,192	0,442	0,298	2,097	8,388	169,92	19,732	0,235	-108,269	81,13	0,406	19,764	28,564	57,143	85,707					
Circuit Line 1.2																									
5	L ₁₉₋₃	490	1 x 70	200	0,277	0,069	0,074	0,285	2,097	2,097	42,48	1,499	0,071	-20,400	20,89	0,104	1,501	2,170	7,773	9,943					
6	L ₃₋₂₀	550	1 x 150	306	0,145	0,066	0,110	0,159	2,097	4,194	84,96	3,144	0,075	-29,657	23,28	0,116	3,149	4,552	12,378	16,930					
7	L ₂₀₋₁₇	820	1 x 300	455	0,110	0,093	0,213	0,144	2,097	6,291	127,44	5,354	0,085	-55,735	29,35	0,147	5,363	7,750	27,563	35,313					
8	L _{17-Cab.1}	390	1 x 300	455	0,052	0,044	0,101	0,068	2,097	8,388	169,92	4,527	0,054	-24,838	18,61	0,093	4,534	6,553	13,109	19,662					
Circuit Line 1.3																									
9	L ₁₀₋₁₂	1.150	1 x 70	200	0,650	0,161	0,173	0,669	2,097	2,097	42,48	3,518	0,168	-47,877	49,03	0,245	3,523	5,092	18,243	23,335					
10	L ₁₃₋₁₂	490	1 x 70	200	0,277	0,069	0,074	0,285	2,097	2,097	42,48	1,499	0,071	-20,400	20,89	0,104	1,501	2,170	7,773	9,943					
11	L _{12-Cab.1}	2.050	1 x 300	455	0,275	0,232	0,533	0,359	2,097	6,291	127,44	13,385	0,213	-139,339	73,37	0,367	13,406	19,375	68,908	88,283					
										23,067										245,997					
Line from Cab. 1 to Cab. 2																									
	L _{Cab1-Cab.2}	3.800	2/3x1x500	593	0,334	0,380	1,140	0,506	2,097	23,067	233,64	109,404	0,474	-519,863	175,94	0,880	219,163	316,736	363,334	680,070					
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost					
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€						
Circuit Line 2.1																									
12	L ₄₋₁₆	1.200	1 x 70	200	0,678	0,168	0,180	0,699	2,097	2,097	42,48	3,671	0,175	-49,958	51,16	0,256	3,677	5,313	19,036	24,349					
13	L _{16-Cab.2}	5.800	1 x 150	306	1,531	0,696	1,160	1,682	2,097	4,194	84,96	33,159	0,791	-312,744	245,53	1,228	33,212	47,999	130,535	178,534					
Circuit Line 2.2																									
14	L ₁₁₋₈	700	1 x 70	200	0,396	0,098	0,105	0,407	2,097	2,097	42,48	2,141	0,102	-29,142	29,85	0,149	2,145	3,099	11,104	14,204					
15	L ₈₋₅	2.360	1 x 150	306	0,623	0,283	0,472	0,684	2,097	4,194	84,96	13,492	0,322	-127,254	99,90	0,500	13,514	19,531	53,114	72,645					
16	L ₅₋₉	640	1 x 300	455	0,086	0,072	0,166	0,112	2,097	6,291	127,44	4,179	0,066	-43,501	22,91	0,115	4,185	6,049	21,513	27,562					
17	L _{9-Cab.2}	240	1 x 300	455	0,032	0,027	0,062	0,042	2,097	8,388	169,92	2,786	0,033	-30,570	11,45	0,057	2,790	4,033	8,067	12,100					
Circuit Line 2.3																									
18	L ₁₄₋₆	650	1 x 70	200	0,367	0,091	0,098	0,378	2,097	2,097	42,48	1,988	0,095	-27,061	27,71	0,139	1,991	2,878	10,311	13,189					
19	L ₆₋₂₁	4.700	1 x 150	306	1,241	0,564	0,940	1,363	2,097	4,194	84,96	26,870	0,641	-253,430	198,96	0,995	26,914	38,896	105,778	144,674					
20	L _{21-Cab.2}	3.550	1 x 150	306	0,937	0,426	0,710	1,029	2,097	6,291	127,44	45,665	0,726	-179,889	225,42	1,127	45,739	66,102	79,896	145,998					
										18,873										439,355					
Circuit line from S/S Utenza to S/S Terna																									
										41,940		283,21		1,199,214		2,859		-3,442,733		1,062,50		5,313			
Node	Param.	Lenght	Cable Al	R.c.c.	R _{cable}	X _{cable}	Capac _{cable}	Z _{cable}	PG _i	PG _{0-i}	I _{0-i}	P _{Li}	Losses	Q _{toLi}	DV _i	Dvi%	En. Lost	Losses Cost	Cable Cost	Total Cost					
No.	L _(i-1-i)	mts	mm ²	A	ohm	ohm	microF	ohm	kW	kW	A	W	%	VAR	V		kWh/year	€	€						
Alt 1																									
30 kV cable connection to Terna Substation																									
MV Line	L _{SS-Terna}	18.900	3/3x1x500	593	1,661	1,890	5,670	2,516																	
Alt 2																									
150 kV cable connection to Terna Substation																									

							Wind speed: ≥ 12		Power Generation:			41.940			1.002 Hrs				
HV Line	L-SS-Terna	18.900	1 x 400	509	1,890	8,127	2,967	8,344	41.940	169,92	163.715,17	0,390	-19.556.024	1.273,33	0,849	163.979,92	236.985,44	1.984.500	2.221.485
Optimisation summary tables																			
Cable ARE4HIRX - 18/30 kV																			
Cables & Cable Accessories Summary							Losses - W	VAR	kWh/year	Losses €	Cable cost €	kVAR	Perdite kW	% Perdite	Max. % DV				
Line	Lenght	Cable size	Drum Nos	Joints	Terminations														
60	L ₇₋₁	530	3x1x70	1		6	1.621	-22.065	1.624	2.347	8.407	-	2.096	303,1	0,72	1,23			
66	L ₁₉₋₃	490	3x1x70	1		6	1.499	-20.400	1.501	2.170	7.773								
72	L ₁₀₋₁₂	1150	3x1x70	3	6	6	3.518	-47.877	3.523	5.092	18.243								
73	L ₁₃₋₁₂	490	3x1x70	1		6	1.499	-20.400	1.501	2.170	7.773	2.714		110,0	0,26				
83	L ₄₋₁₆	1200	3x1x70	3	6	6	3.671	-49.958	3.677	5.313	19.036								
87	L ₁₁₋₈	700	3x1x70	2	3	6	2.141	-29.142	2.145	3.099	11.104	2.338		39,0	0,09				
93	L ₁₄₋₆	650	3x1x70	2	3	6	1.988	-27.061	1.991	2.878	10.311			55,0	0,13				
	Total	5.210	3x1x70	13	18	42	15.937	-216.903	15.962	23.069	82.647								
61	L ₁₋₁₈	500	3x1x150	2	3	6	2.859	-26.961	2.863	4.138	11.253	-	19.556	163,7	0,39	0,85			
67	L ₃₋₂₀	550	3x1x150	2	3	6	3.144	-29.657	3.149	4.552	12.378								
84	L _{16-Cab.2}	5.800	3x1x150	20	57	6	33.159	-312.744	33.212	47.999	130.535								
88	L ₈₋₅	2.360	3x1x150	8	21	6	13.492	-127.254	13.514	19.531	53.114	-	16.600	951	2,27	1,23			
94	L ₆₋₂₁	4.700	3x1x150	16	45	6	26.870	-253.430	26.914	38.896	105.778								
95	L _{21-Cab.2}	3.550	3x1x150	12	33	6	45.665	-179.889	45.739	66.102	79.896								
	Total	17.460	3x1x150	60	162	36	125.189	-929.935	125.391	181.217	392.955								
62	L ₁₈₋₂	1.200	1x300	3		6	2.612	-27.188	2.616	3.780	13.446								
63	L _{2-Cab.1}	5.100	1x300	9	6	6	19.732	-108.269	19.764	28.564	57.143								
68	L ₂₀₋₁₇	2.460	1x300	6	3	6	5.354	-55.735	5.363	7.750	27.563								
69	L _{17-Cab.1}	1.170	1x300	1		6	4.527	-24.838	4.534	6.553	13.109								
74	L _{12-Cab.1}	6.150	1x300	12	9	6	13.385	-139.339	13.406	19.375	68.908								
89	L ₅₋₉	1.920	1x300	3		6	4.179	-43.501	4.185	6.049	21.513								
90	L _{9-cab.2}	720	1x300	1		6	2.786	-30.570	2.790	4.033	8.067								
	Total	16.080	3x1x300	35	18	42	52.574	-429.441	52.659	76.103	209.750								
77	L _{cab.1-Cab.2}	22.800	1x500	36	30	12	109.404	-519.863	219.163	316.736	363.334								
	Total	22.800	1x500	36	30	12	303.104	-2.096.142	413.175	597.125	1.048.686								
Alt.2-150	L-SS-Terna	56.700	1x400 HV	72	69	6	163.715	-19.556.024	163.980	236.985	1.984.500								
							Grand Total Alt.2	466.819	-21.652.166	577.155	834.110	3.033.186							