


O5HA001A
Scambiatore gas / olio diatermico


O5FA001
Caldaia ad olio diatermico

NOTES:
BD/HP BLOW DOWN HIGH PRESSURE

EXAMPLE OF FLANGE ZONING WITH GAS PRESSURE 260Bar (CEI 31-35 Art. GB.3)



EXAMPLE OF FLANGE ZONING WITH GAS PRESSURE 80Bar (CEI 31-35 Art. GB.3)



- GAS - VAPOURS MISTS ZONA 0
- ZONA 1
- ZONA 2

5

Hazardous area D.lgs.81/08
gas heating and pressure reduction
P&I
DRAFT

CUSTOMER: **GAS PLUS STORAGE**
San Benedetto gas storage Plant

SCALE -/- by SG
DATE 26/07/2010 CHECKED by IB - MC

Documento riservato a termini di Legge con divieto di riproduzione e di divulgazione senza esplicita autorizzazione.
This document is reserved as by law enacted, and cannot be used by others for any purpose, without prior written consent.



Via Monviso n.27
12037 SALUZZO (CN) - ITALY
tel./fax +39.0175.41146/0175.217556
e-mail: info@eteasicurezza.it