PARTICOLARE DI SCAVO 4 TUBI Ø160mm ATTRAVERSAMENTO BINARI



PARTICOLARE 4 TUBI Ø160mm SU MARCIAPIEDE



PARTICOLARE 2 TUBI Ø100mm SU MARCIAPIEDE

Le canalizzazione nei marciapiedi sono totalmente da verificare e confermare, a cura del progettista delle opere civili.

PARTICOLARE DI SCAVO 2 TUBI Ø160mm



PARTICOLARE DI SCAVO 3TUBI Ø160mm



PARTICOLARE POZZETTO DI DERIVAZIONE 80x80cm

PARTICOLARE POZZETTO DI DERIVAZIONE 45x45cm



PARTICOLARE DI SCAVO 4TUBI Ø160mm



PARTICOLARE POZZETTO DI DERIVAZIONE 100x100cm

PARTICOLARE DI SCAVO 2 TUBI Ø100mm



PARTICOLARE PALINA LUCE MARCIAPIEDE



PARTICOLARE MORSETTIERA INCASSO PALO


Cross parallel to tender direction of the road, with a minimum distance of 0.5 m from the road surface. Cable entry from the road side or from the opposite side. Cable entry from the side of the footpath is forbidden. Tender, inspection cover preferred to be placed on the footpath, perpendicular to the road. Installation of the cable connection box in the tender is forbidden. Installation of the cable connection box in the footpath is allowed only if the footpath is at least 2.5 m wide.
Cable connection box in the tender
Cable connection box in the footpath
Cable connection box in the footpath
Tender
Footpath
Road
Cable connection box in the tender
Cable connection box in the footpath
Cable connection box in the footpath
Footpath
Road
Tender
Footpath
Road
Tender
Footpath
Road
Tender