



TABELLA CONVERSIONE VALORI EMISSIONI DA mg/Nm3 a ppm

MASERA

TC-1 02/11/2021

Ora inizio	O2 %	CO mg/Nm3	CO ppm	CO mg/Nm3 al 15% di O2	CO ppm al 15% di O2	NOx mg/Nm3	NOx ppm	NOx mg/Nm3 al 15% di O2	NOx ppm al 15% di O2	Fuel gas Nm3/h
13:50	16,91	0,57	0,46	0,84	0,67	30,00	14,63	44,00	21,46	2.119
14:40	15,88	1,70	1,36	2,00	1,60	58,50	28,54	68,50	33,41	3.090
15:44	16,08	1,50	1,20	1,83	1,46	37,00	18,05	45,10	22,00	2.844
16:35	16,39	1,60	1,28	2,10	1,68	33,50	16,34	43,50	21,22	2.512

TC-2 03/11/2021

Ora inizio	O2 %	CO mg/Nm3	CO ppm	CO mg/Nm3 al 15% di O2	CO ppm al 15% di O2	NOx mg/Nm3	NOx ppm	NOx mg/Nm3 al 15% di O2	NOx ppm al 15% di O2	Fuel gas Nm3/h
11:10	17,14	8,20	6,56	12,80	10,24	29,80	14,54	46,30	22,59	2.180
12:00	16,81	2,20	1,76	3,20	2,56	28,90	14,10	41,40	20,20	2.522
14:25	16,37	0,54	0,43	0,70	0,56	27,30	13,32	35,40	17,27	2.891
15:40	15,89	0,54	0,43	0,63	0,50	37,60	18,34	44,20	21,56	3.280
16:35	16,50	0,59	0,47	0,79	0,63	29,40	14,34	39,20	19,12	2.740

TC-3 04/11/2021

Ora inizio	O2 %	CO mg/Nm3	CO ppm	CO mg/Nm3 al 15% di O2	CO ppm al 15% di O2	NOx mg/Nm3	NOx ppm	NOx mg/Nm3 al 15% di O2	NOx ppm al 15% di O2	Fuel gas Nm3/h
11:15	15,66	1,70	1,36	2,00	1,60	54,10	26,39	60,80	29,66	3.413
11:59	16,38	1,19	0,95	1,54	1,23	33,10	16,15	43,00	20,98	2.891
14:50	16,62	0,60	0,48	0,82	0,66	36,10	17,61	49,50	24,15	2.512
14:45	16,96	0,65	0,52	0,96	0,77	34,70	16,93	51,50	25,12	2.199
16:35	15,71	1,55	1,24	1,76	1,41	51,60	25,17	58,60	28,59	3.365