



DISTANZA PROGRESSIVA	0.00	240.67	517.95	767.63	1027.32	1238.45	1446.64	1671.67	1884.06	2099.36	2263.93	2563.36	2757.11	2971.91	3256.50	3429.55																
QUOTA DEL TERRENO	41.49	36.80	33.27	28.85	24.74	21.39	15.09	9.90	3.55	1.96	3.81	1.96	1.12	2.52	3.11	5.37																
NUMERO DEL SOSTEGNO	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	Portale Arbatax																
ALTEZZA UTILE/ALTEZZA TOTALE	15.00/27.40	18.00/31.30	28.40/38.80	21.00/34.30	15.00/28.30	12.00/25.30	18.00/31.30	18.00/34.40	18.00/34.40	18.00/34.40	15.00/34.00	21.00/37.40	15.00/34.00	21.00/37.40	15.00/31.40	15.00/18.50																
DISTANZA CAMPATA		240.67		277.28		249.68		259.68		211.14		208.18		225.04		212.39		215.29		164.57		299.43		193.75		214.80		284.60		173.05		PORTALE
TIPO PALO	E	V	E	L	L	L	L	L	L	C	C	E	L	E	L	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	

1	2	3	4	5	6
I					
H					
G					
F					
E					
D					
C					
B					
00		Gennaio 2022		Emissione	
Revisione	Data	DESCRIZIONE		3E	Sardeglica Srl
A		Commissa		Scala	
		Attivazione Linea a 150kV 23318B2 "Flumendosa DD - Arbatax"		Formato	Foglio
		Tratta dal Sostegno n. 29 alla CP Arbatax		A3	1 di 1
		Titolo		Id.	027.20.01.W08
		3E Ingegneria S.r.l.			
1	2	3	4	5	6

