



Enel Green Power and Thermal Generation Italy  
Power Plant Center  
Centrale Turbogas di Pietrafitta

Componente	2020			2021			2022		
	kg emessi (come COV)	Max componenti monitorati mensili	Kg emessi per componente	kg emessi (come COV)	Max componenti monitorati mensili	Kg emessi per componente	kg emessi (come COV)	Max componenti monitorati mensili	Kg emessi per componente
END	0	0	0,000	0,00	0	0,000	15,87	13	1,221
FLG	349,33	639	0,547	547,53	639	0,857	321,04	647	0,496
PSV	1,39	6	0,232	2,63	6	0,438	2,60	6	0,433
VLV	159,8	188	0,850	110,33	188	0,587	38,95	188	0,207

LEGENDA	
Fine linea	END
Flangia	FLG
Valvola di sicurezza	PSV
Valvola	VLV

