



QUOTA TERRENO DEL SOSTEGNO	61.67	67.33	99.67	98.05	97.79	102.41	105.41	116.16	127.18
NUMERO DEL SOSTEGNO	1A	2A	3A	PA	PB	1B	3B	4B	5B
ALTEZZA PILE E TORNELLI DEL SOSTEGNO	21.00/28.00	33.00/40.00	30.00/37.00	16.00/18.20	16.00/18.20	24.00/31.00	21.00/28.00	24.00/31.00	27.00/34.00
DISTANZA CAMPATA		512.91	418.78	61.84	100.00	225.93	385.15	167.81	329.12
DISTANZA PROGRESSIVA	0.00	512.91	931.67	993.51	1093.51	1319.44	1704.59	1872.39	2201.51



REV	DATE	DESCRIPTION	PREPARED	CHECKED	APPROVED
0	Dic/2021	first issue	3E	3E	EGP

**CONTRACTORS LOGO**

**PROJECT:**  
 Nuova SE RTN a 220kV di Gonnese e raccordi alla RTN

**FILE NAME:**  
 GRE.EEC.D.24.IT.W.15012.16.022.00

CLASSIFICATION:	FORMAT:	SCALE:	PLOT SCALE:	SHEET:
	A1	-	1:1	1 di 1

**UTILIZATION SCOPE:**  
 Profilo Longitudinale con distribuzione sostegni

**Engineering & Construction**  
**GRE VALIDATION**

VALIDATED BY	GRE CODE									
VERIFIED BY	GROUP	FUNCTION	TYPE	ISSUER	COUNTRY	TEC.	PLANT	SYSTEM	PROGRESSIVE	REVISION
COLLABORATORS	GRE	EEC	D	24	IT	W	15012	16	022	00

This document is property of Enel Green Power SpA. It is strictly forbidden to reproduce this document, in whole or in part, and to provide to others any related information without the previous written consent by Enel Green Power SpA.