



Nota: Le dimensioni riportate sono relative ad un modello generico di turbina di grande taglia. In base al modello di aerogeneratore selezionato in fase esecutiva, tali dimensioni potranno variare rispettando comunque l'altezza complessiva massima di 200 m (diametro del rotore, massimo 170 m; altezza al mozzo, massimo 115 m).

01	01/09/2023	Integrazioni MASE	G. Allano	G. Allano	P. Polinelli
00	04.03.2022	Prima emissione	S. Birzi	N. Novati	P. Polinelli
REV.	DATE	DESCRIPTION	PREPARED	CHECKED	APPROVED
			<b>INTEGRALE RICOSTRUZIONE DELL'IMPIANTO EOLICO DI GANGI</b>		
<b>EGP VALIDATION</b>					
VALIDATED BY: <b>L. Iacifono</b>		PROJECT: <b>INTEGRALE RICOSTRUZIONE DELL'IMPIANTO EOLICO DI GANGI</b>			
VERIFIED BY: <b>L. Iacifono</b>		FILE NAME: <b>GRE.EEC.D.99.IT.W.09317.03.001.01 - Tipico aerogeneratore</b>			
COLLABORATORS:		CLASSIFICATION: <b>PUBLIC</b>	FORMAT: <b>A1</b>	SCALE: <b>1:500</b>	PLOT SCALE: <b>1:1</b>
		UTILIZATION SCOPE: <b>BASIC DESIGN</b>	TITLE: <b>Tipico aerogeneratore Pianta e prospetti</b>		
		EGP CODE			
		GROUP: <b>GRE</b>	FUNCTION: <b>EEC</b>	TYPE: <b>D</b>	ISSUER: <b>99</b>
		COUNTRY: <b>IT</b>	TEC.: <b>W</b>	PLANT: <b>09317</b>	SYSTEM: <b>03</b>
		PROGRESSIVE: <b>001</b>	REVISION: <b>01</b>	<b>10101</b>	
<small>This document is property of Enel Green Power SpA. It is strictly forbidden to reproduce this document, in whole or in part, and to provide to others any related information without the previous written consent by Enel Green Power SpA.</small>					

Rotor	
Type	3-bladed, horizontal axis
Position	Upwind
Diameter	170 m
Swept area	22,698 m <sup>2</sup>
Power regulation	Pitch & torque regulation with variable speed
Rotor tilt	6 degrees

Blade	
Type	Self-supporting
Blade length	83.5 m
Max chord	4.5 m
Aerodynamic profile	
Material	G (Glassfiber) - CRP (Carbon Reinforced Plastic)
Surface gloss	Semi-gloss, < 30 / ISO2813
Surface color	Light grey, RAL 7035 or

Aerodynamic Brake	
Type	Full span pitching
Activation	Active, hydraulic

Load-Supporting Parts	
Hub	Nodular cast iron
Main shaft	Nodular cast iron
Nacelle bed frame	Nodular cast iron

Nacelle Cover	
Type	Totally enclosed
Surface gloss	Semi-gloss, <30 / ISO2813
Color	Light Grey, RAL 7035 or White, RAL 9018

Generator	
Type	Asynchronous, DFIG

Grid Terminals (LV)	
Baseline nominal power	6.0MW/6.2 MW
Voltage	690 V
Frequency	50 Hz or 60 Hz

Yaw System	
Type	Active
Yaw bearing	Externally geared
Yaw drive	Electric gear motors
Yaw brake	Active friction brake

Controller	
Type	Siemens Integrated Control System (SICS)
SCADA system	MySite360

Tower	
Type	Tubular steel / Hybrid
Hub height	100m to 165 m and site-specific
Corrosion protection	
Surface gloss	Painted
Color	Semi-gloss, <30 / ISO-2813 Light grey, RAL 7035 or White, RAL 9018

Operational Data	
Cut-in wind speed	3 m/s
Rated wind speed	11.0 m/s (steady wind without turbulence, as defined by IEC61400-1)
Cut-out wind speed	25 m/s
Restart wind speed	22 m/s

Weight	
Modular approach	Different modules depending on restriction

**Typical Sound Power Levels**  
The sound power levels are presented with reference to the code IEC 61400-11 ed. 3.0 (2012). The sound power levels (L<sub>wa</sub>) presented are valid for the corresponding wind speeds referenced to the hub height.

Wind speed [m/s]	3	4	5	6	7	8	9	10	11	12	Up to 16.0
AM-0	92.0	92.0	94.5	98.4	101.8	104.7	106.0	106.0	106.0	106.0	106.0
AM-1	92.0	92.0	94.5	98.4	101.8	104.7	106.0	106.0	106.0	106.0	106.0
AM-2	92.0	92.0	94.5	98.4	101.8	104.7	106.0	106.0	106.0	106.0	106.0
AM-3	92.0	92.0	94.5	98.4	101.8	104.7	106.0	106.0	106.0	106.0	106.0
AM-4	92.0	92.0	94.5	98.4	101.8	104.7	106.0	106.0	106.0	106.0	106.0
AM-5	92.0	92.0	94.5	98.4	101.8	104.7	106.0	106.0	106.0	106.0	106.0
AM-6	92.0	92.0	94.5	98.4	101.8	104.7	106.0	106.0	106.0	106.0	106.0
N1	92.0	92.0	94.5	98.4	101.8	105.5	105.5	105.5	105.5	105.5	105.5
N2	92.0	92.0	94.5	98.4	101.8	104.5	104.5	104.5	104.5	104.5	104.5
N3	92.0	92.0	94.5	98.4	101.8	103.0	103.0	103.0	103.0	103.0	103.0
N4	92.0	92.0	94.5	98.4	101.8	102.0	102.0	102.0	102.0	102.0	102.0
N5	92.0	92.0	94.5	98.4	101.8	101.0	101.0	101.0	101.0	101.0	101.0
N6	92.0	92.0	94.5	98.4	100.0	100.0	100.0	100.0	100.0	100.0	100.0
N7	92.0	92.0	94.5	98.4	99.0	99.0	99.0	99.0	99.0	99.0	99.0

Table 1: Acoustic emission, L<sub>wa</sub>(dB(A) re 1 pW)(10 Hz to 10kHz)

Wind speed [m/s]	6	8
AM-0	87.6	93.9
AM-1	87.6	93.9
AM-2	87.6	93.9
AM-3	87.6	93.9
AM-4	87.6	93.9
AM-5	87.6	93.9
AM-6	87.6	93.9
N1	87.6	93.9
N2	87.6	93.9
N3	87.6	92.7
N4	87.6	91.9
N5	87.6	91.0
N6	87.6	90.2
N7	87.6	89.3

Table 2: Acoustic emission, L<sub>wa</sub>(dB(A) re 1 pW)(10 Hz to 160 Hz)

**Low Noise Operations**  
The lower sound power level is also available and can be achieved by adjusting the turbines controller settings, i.e. an optimization of rpm and pitch. The noise settings are not static and can be applied to optimize the operational output of the turbine. Noise settings can be tailored to time of day as well as wind direction to offer the most suitable solution for a specific location. This functionality is controlled via the SCADA system and is described further in the white paper on Noise Reduction Operations. Furthermore, tailored power curves can be provided which take wind speed into consideration allowing for management of the turbine output power and noise emission level to comply with site specific noise requirements. Tailored power curves are project and turbine specific and will therefore require Siemens Gamesa Sting involvement to provide the optimal solutions. The lower sound power levels may not be applicable to all tower variants. Please contact Siemens Gamesa for further information.

**Typical Sound Power Frequency Distribution**  
Typical spectra for L<sub>wa</sub> in dB(A) re 1 pW for the corresponding centre frequencies are tabulated below for 6 and 8 m/s referenced to hub height.

1/1 oct. band center freq.	63	125	250	500	1000	2000	4000	8000
AM-0	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
AM-1	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
AM-2	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
AM-3	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
AM-4	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
AM-5	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
AM-6	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
N1	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
N2	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
N3	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
N4	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
N5	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
N6	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5
N7	79.9	86.7	88.9	89.9	93.1	92.8	88.3	76.5

Table 3: Typical 1/1 octave band spectrum for 63 Hz to 8 kHz at 6 m/s

1/1 oct. band center freq.	63	125	250	500	1000	2000	4000	8000
AM-0	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
AM-1	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
AM-2	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
AM-3	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
AM-4	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
AM-5	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
AM-6	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
N1	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
N2	86.2	93.0	95.2	96.2	99.4	99.1	94.6	82.8
N3	84.6	91.9	94.1	93.6	97.0	97.8	93.0	81.8
N4	84.1	91.0	93.1	92.6	96.0	96.8	92.0	80.8
N5	83.5	90.1	92.1	91.6	95.0	95.8	91.0	79.8
N6	83.0	89.2	91.1	90.6	94.0	94.8	90.0	78.8
N7	82.4	88.2	90.1	89.6	93.0	93.8	89.0	77.8

Table 4: Typical 1/1 octave band spectrum for 63 Hz to 8 kHz at 8 m/s

1/3 oct. band center freq.	10	12.5	16	20	25	31.5	40	50	63	80	100	125	160
AM-0	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
AM-1	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
AM-2	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
AM-3	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
AM-4	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
AM-5	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
AM-6	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
N1	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
N2	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
N3	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
N4	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
N5	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
N6	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2
N7	43.3	46.3	49.6	52.7	55.7	60.9	63.9	70.1	74.3	77.8	80.1	82.0	83.2

Table 5: Typical 1/3 octave band spectrum for 10 Hz to 160 Hz at 6 m/s

1/3 oct. band center freq.	10	12.5	16	20	25	31.5	40	50	63	80	100	125	160
AM-0	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
AM-1	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
AM-2	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
AM-3	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
AM-4	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
AM-5	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
AM-6	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
N1	49.6	52.6	55.9	59.0	62.0	67.2	70.2	76.4	80.6	84.1	86.4	88.3	89.5
N2	50.6	53.6	56.9	60.0	63.0	66.6	71.4	75.7	79.5	83.4	87.2	88.1	89.7
N3	50.6	53.6	56.9	59.9	62.8	66.3	71.1	75.2	78.8	82.5	86.1	86.8	88.2
N4	50.6	53.6	56.8	59.8	62.7	66.1	70.9	74.9	78.4	81.9	85.4	86.0	87.1
N5	50.6	53.6	56.8	59.8	62.6	65.9	70.5	74.5	77.9	81.3	84.6	85.1	86.1
N6	50.6	53.6	56.8	59.7	62.5	65.7	70.3	74.1	77.4	80.7	83.9	84.2	85.0
N7	50.6	53.6	56.7	59.6	62.3	65.6	70.0	73.8	76.9	80.1	83.1	83.3	83.9

Table 6: Typical 1/3 octave band spectrum for 10 Hz to 160 Hz at 8 m/s

For a detailed description of all modes, please refer to Flexible Rating Specification (D2316244).

La tabella riporta i livelli sonori dell'aerogeneratore tipo impiegato nel progetto in oggetto utile al calcolo delle emissioni acustiche. Si veda a tal proposito l'elaborato GRE.EEC.K.26.IT.W.09317.05.006 - Relazione impatto acustico

La tabella riporta le caratteristiche generali dell'aerogeneratore tipo impiegato nel progetto in oggetto, tra cui le velocità di funzionamento utili al calcolo dello yaw flickering, gittata e visibilità (per la visibilità riferirsi anche alle caratteristiche dimensionali indicate a pag. 1 del presente elaborato).

Si vedano a tal proposito gli elaborati:

- GRE.EEC.R.25.IT.W.09317.00.010 - Relazione tecnica descrittiva del progetto
- GRE.EEC.C.24.IT.W.09317.10.004 - Relazione di calcolo elettrico
- GRE.EEC.C.73.IT.W.09317.00.028 - Relazione gittata massima elementi rotanti per rottura accidentale
- GRE.EEC.R.26.IT.W.09317.05.015 - Relazione sugli effetti shadow-flickering
- GRE.EEC.R.26.IT.W.09317.00.022 - Carte intervisibilità

Wind Speed [m/s]	Power [kW]
3.0	89
3.5	178
4.0	328
4.5	522
5.0	758
5.5	1040
6.0	1376
6.5	1771
7.0	2230
7.5	2758
8.0	3351
8.5	3988
9.0	4617
9.5	5166
10.0	5584
10.5	5862
11.0	6028
11.5	6117
12.0	6161
12.5	6183
13.0	6192
13.5	6197
14.0	6199
14.5	6199
15	