



Regione
Molise




Comune di
San Giovanni in Galdo



Comune di
Campolioto



Comune di
Morrone del Sannio



Provincia di
Campobasso

**PROGETTO PER LA REALIZZAZIONE
DI UN PARCO EOLICO PER LA PRODUZIONE DI ENERGIA ELETTRICA
della potenza di 33 MW alla località Fiego dei Comuni di San Giovanni in Galdo e
Campolioto (aerogeneratori)
e DELLE OPERE CONNESSE E DELLE INFRASTRUTTURE INDISPENSABILI
nei Comuni di San Giovanni in Galdo, Campolioto e Morrone del Sannio.**

PROGETTO DEFINITIVO

GAL_GITT.01

Analisi degli effetti di rottura
degli organi rotanti

Proponente




Rinnovabili Sud Tre srl
Via Della Chimica, 103 - 85100 Potenza (PZ)

Formato
A4

Scala
-

Progettista

Ing. Gaetano Cirone



Revisione	Descrizione	Data	Preparato	Controllato	Approvato
00	Prima emissione	10/11/2023	Ing. G. D'Agrosa Grieco	Ing. G. Cirone	Ing. G. Cirone

SOMMARIO

1.	PREMessa	2
2.	IPOTESI DI CALCOLO	2
3.	CALCOLO DELLA GITTATA NEL CASO DI DISTACCO NEL PUNTO DI ATTACCO DEL MOZZO	2
3.1	DATI GEOMETRICI E CINEMATICI DELL'AEROGENERATORE	2
3.2	SCHEMA CONCETTUALE.....	3
3.3	CALCOLO DEL BARICENTRO.....	4
3.4	CALCOLO DELLA VELOCITÀ PERIFERICA.....	4
3.5	CALCOLO H_G	5
3.6	CALCOLO DELLA GITTATA MASSIMA ED EFFETTIVA	5
4.	APPLICAZIONE DELLO STUDIO AL PROGETTO IN ESAME.....	12
5.	CONCLUSIONI	14

INDICE DELLE FIGURE

Figura 1 – Schema adottato per il calcolo della gittata per angolo compreso tra 0° e 90°	4
Figura 2 - Ortofoto con opere di impianto, fabbricati individuati (recettori) e buffer di sicurezza degli aerogeneratori	13

INDICE DELLE TABELLE

Tabella 1 – Calcolo della gittata massima ed effettiva per angolo α compreso tra 0° e 90°	11
--	----

1. PREMESSA

Il progetto in oggetto consiste nella realizzazione di un Parco Eolico per la produzione di energia elettrica da fonte rinnovabile (vento) da ubicarsi alla Località ‘Fiego’ dei Comuni di **San Giovanni in Galdo (CB)** e **Campolieto (CB)** con opere di connessione nei comuni di **San Giovanni in Galdo (CB)**, **Campolieto (CB)** e **Morrone del Sannio (CB)** proposto dalla società Rinnovabili Sud Tre S.r.l.

L'impianto eolico in oggetto prevede l'installazione di n. 5 aerogeneratori (modello NORDEX N163 da 6,6 MW, diametro rotore 163 m e altezza torre 118 m) aventi una potenza massima unitaria pari a 6,6 MW. La potenza installata massima dell'impianto risulta pertanto pari a 33,00 MW.

La presente relazione si riferisce al calcolo della gittata massima di una pala di un aerogeneratore del modello NORDEX, diametro rotore 163 m, altezza torre 118 m e potenza 6,6 MW, in caso di rottura; tale calcolo è stato eseguito al fine di prevedere possibili problemi che una simile eventualità, per quanto improbabile, possa procurare danno a cose e/o persone. Nel calcolo si ipotizza il distacco della pala nel punto di serraggio sul mozzo, punto di maggiore sollecitazione, per effetto di intaglio dovuto al collegamento.

Lo studio riporta inoltre il calcolo della gittata nell'ipotesi di una *rottura dell'intera pala*.

2. IPOTESI DI CALCOLO

Le condizioni al contorno considerate per il calcolo sono le più gravose e consentono di giungere a risultati cautelativi; si vuole precisare, inoltre, che le probabilità di accadimento di rotture per aerogeneratori industriali di grande taglia sono molto basse.

Per il calcolo si effettuano le seguenti ipotesi:

- il moto del sistema considerato è quello di un sistema rigido non vincolato (modello che approssima la pala nel momento del distacco);
- tutte le forze di resistenza generate dal mezzo (aria) in cui avviene il moto in grado di ridurre la gittata effettiva non vengono considerate;
- il calcolo della gittata è stato determinato per diversi valori dell'angolo α ;
- la velocità massima del rotore sarà limitata elettronicamente.

3. CALCOLO DELLA GITTATA NEL CASO DI DISTACCO NEL PUNTO DI ATTACCO DEL MOZZO

3.1 Dati geometrici e cinematici dell'aerogeneratore

Il presente studio è stato condotto prendendo in esame i dati geometrici e cinematici dell'aerogeneratore e della pala (Figura 1) previsti nel progetto del parco eolico cui fa riferimento il presente lavoro. In particolare, è stato considerato l'aerogeneratore di progetto



a avente le seguenti caratteristiche dimensionali (Come consultabili all'interno della scheda tecnica dell'aerogeneratore modello NORDEX N163 da 6,6 MW allegata alla presente relazione):

- Altezza della torre $H = 118$ m
- Diametro del rotore $D = 163$ m
- Lunghezza della pala $L = 79,7$ m
- Altezza massima dell'aerogeneratore $H+L = 197,7$ m
- Velocità di rotazione $n = 11,6$ giri/min.

ed avente una potenza nominale unitaria di 6600 kW.

3.2 Schema concettuale

Lo schema adottato per il calcolo della gittata per un angolo compreso tra 0° e 90° è il seguente:

α : Angolo della pala rispetto all'orizzontale

D : Diametro del rotore

L : Lunghezza della pala

r_g : Posizione del baricentro

X_g : Posizione del baricentro della pala rispetto all'asse della torre

Y_g : Proiezione di r_g sulla verticale

$\frac{2}{3} L$: Frazione della pala che supera la gittata teorica



Rinnovabili Sud Tre

Via della Chimica 103, Potenza (PZ)
rinnovabilisudtre@pec.it
Tel: 0971 281981




Figura 1 – Schema adottato per il calcolo della gittata per angolo compreso tra 0° e 90°

3.3 Calcolo del baricentro

Date le caratteristiche geometriche della pala, e considerata la distribuzione dei pesi lungo il profilo della stessa, si può ritenere con buona approssimazione che il baricentro sia posizionato ad un terzo rispetto alla lunghezza della pala (L) più il raggio del rotore (D).

$$r_g = \frac{D}{2} - L + \frac{L}{3} = 28,37 \text{ m}$$

3.4 Calcolo della velocità periferica

La velocità angolare media ω è l'angolo descritto dal corpo in movimento nell'unità di tempo. Indicando con n il numero di giri al minuto primo compiuti dal corpo in movimento circolare e tenuto conto che ad ogni giro l'angolo descritto dal corpo in movimento è pari a 2π radianti, per n giri avremo $2\pi n$ radianti/minuto, ovvero la velocità angolare ω del corpo in movimento. Il dato di partenza è $n = 11,6$ giri/min che corrisponde ad una velocità angolare:

$$\omega = \frac{2 \cdot \pi \cdot n}{60} = 1,21 \text{ rad/s}$$

Nel moto circolare uniforme, la velocità periferica è direttamente proporzionale al raggio. Ad ogni giro il punto G di raggio R percorre la circonferenza $2 \cdot \pi \cdot R$; dopo n giri al minuto lo spazio percorso sarà $2 \cdot \pi \cdot R \cdot n$ metri/minuto. Questo sarà lo spazio percorso da tutti i punti situati sulla periferia del corpo in movimento circolare.

Dunque, la velocità periferica in metri al secondo di un corpo rotante (considerando la velocità massima del rotore pari a 11,6 giri al minuto), corrisponde a:

$$v_0 = \omega \cdot r_g = \frac{2\pi n}{60} \cdot r_g = 34,46 \text{ m/s}$$

3.5 Calcolo H_g

Date le caratteristiche geometriche della pala, e considerata la distribuzione dei pesi lungo il profilo della stessa, si ritiene con buona approssimazione che il baricentro sia posizionato ad un terzo rispetto alla lunghezza della pala più il raggio del rotore, ossia $r_g = 28,37 \text{ m}$, essendo la lunghezza di ciascuna pala uguale a 79,7 m e il diametro del rotore uguale 163 m.

Di conseguenza l'altezza di lancio (H_g) sarà uguale all'altezza del mozzo più il valore della proiezione di r_g (posizione del baricentro) sulla verticale ossia:

$$H_g = H_{hub} + Y_g$$

Con

$$Y_g = (r_g \cdot \sin \alpha)$$

Dove H_{hub} è l'altezza del mozzo.

Il calcolo della proiezione del baricentro sull'asse verticale viene valutato per i diversi valori dell'angolo α .

3.6 Calcolo della gittata massima ed effettiva

Per il calcolo della gittata massima ed effettiva vengono riportate ed utilizzate le seguenti formule:

G: Gittata massima

$$G = \frac{v_{x0} \left(v_{y0} + \sqrt{v_{y0}^2 + 2 \cdot g \cdot H_g} \right)}{g} - X_g$$

Dove g rappresenta l'effetto della forza gravitazionale della Terra pari a $9,81 \text{ m/s}^2$, mentre v_{x0} e v_{y0} rappresentano la velocità nelle due direzioni x e y in funzione dell'angolo α , che vengono calcolate come:



$$v_{x0} = v_0 \cdot \cos(90 - \alpha) = v_0 \cdot \sin \alpha$$

$$v_{y0} = v_0 \cdot \sin(90 - \alpha) = v_0 \cdot \cos \alpha$$

X_g , come già menzionato, rappresenta la posizione del baricentro della pala rispetto all'asse della torre e che viene calcolata come:

$$X_g = r_g \cdot \cos \alpha$$

G_{eff} : *Gittata effettiva*

$$G_{eff} = G + L_g$$

L_g rappresenta la frazione della pala che, nella casistica peggiore, supera la gittata massima qualora venga raggiunto dal baricentro (r_g) e che viene calcolato come:

$$L_g = \frac{2}{3} L$$

Il calcolo della gittata è stato eseguito considerando diversi valori dell'angolo α . La Tabella 1 mostra i valori ottenuti della gittata:



Rinnovabili Sud Tre

Via della Chimica 103, Potenza (PZ)
rinnovabilisudtre@pec.it
 Tel: 0971 281981

Angolo α	n	L	H_{torre}	v₀	v_{x0}	v_{y0}	H_g	D	r_g	g	Gittata teorica	X_g	L_g	Gittata Effettiva
0	11,60	79,70	118,00	34,46	0,00	34,46	118,00	163	28,37	9,81	-28,37	28,37	53,13	24,77
1	11,60	79,70	118,00	34,46	0,60	34,45	118,50	163	28,37	9,81	-22,62	28,36	53,13	30,52
2	11,60	79,70	118,00	34,46	1,20	34,44	118,99	163	28,37	9,81	-16,85	28,35	53,13	36,28
3	11,60	79,70	118,00	34,46	1,80	34,41	119,48	163	28,37	9,81	-11,08	28,33	53,13	42,05
4	11,60	79,70	118,00	34,46	2,40	34,37	119,98	163	28,37	9,81	-5,31	28,30	53,13	47,83
5	11,60	79,70	118,00	34,46	3,00	34,33	120,47	163	28,37	9,81	0,47	28,26	53,13	53,60
6	11,60	79,70	118,00	34,46	3,60	34,27	120,97	163	28,37	9,81	6,24	28,21	53,13	59,37
7	11,60	79,70	118,00	34,46	4,20	34,20	121,46	163	28,37	9,81	12,00	28,16	53,13	65,13
8	11,60	79,70	118,00	34,46	4,80	34,12	121,95	163	28,37	9,81	17,75	28,09	53,13	70,88
9	11,60	79,70	118,00	34,46	5,39	34,03	122,44	163	28,37	9,81	23,47	28,02	53,13	76,61
10	11,60	79,70	118,00	34,46	5,98	33,93	122,93	163	28,37	9,81	29,17	27,94	53,13	82,31
11	11,60	79,70	118,00	34,46	6,57	33,83	123,41	163	28,37	9,81	34,85	27,85	53,13	87,98
12	11,60	79,70	118,00	34,46	7,16	33,71	123,90	163	28,37	9,81	40,49	27,75	53,13	93,62
13	11,60	79,70	118,00	34,46	7,75	33,58	124,38	163	28,37	9,81	46,09	27,64	53,13	99,22
14	11,60	79,70	118,00	34,46	8,34	33,43	124,86	163	28,37	9,81	51,64	27,52	53,13	104,78
15	11,60	79,70	118,00	34,46	8,92	33,28	125,34	163	28,37	9,81	57,16	27,40	53,13	110,29
16	11,60	79,70	118,00	34,46	9,50	33,12	125,82	163	28,37	9,81	62,62	27,27	53,13	115,75
17	11,60	79,70	118,00	34,46	10,07	32,95	126,29	163	28,37	9,81	68,02	27,13	53,13	121,16
Angolo α	n	L	H_{torre}	v₀	v_{x0}	v_{y0}	H_g	D	r_g	g	Gittata teorica	X_g	L_g	Gittata Effettiva



Impianto Eolico San Giovanni in Galdo

Analisi degli effetti di rottura degli organi rotanti

18	11,60	79,70	118,00	34,46	10,65	32,77	126,77	163	28,37	9,81	73,37	26,98	53,13	126,50
19	11,60	79,70	118,00	34,46	11,22	32,58	127,24	163	28,37	9,81	78,65	26,82	53,13	131,78
20	11,60	79,70	118,00	34,46	11,79	32,38	127,70	163	28,37	9,81	83,87	26,66	53,13	137,00
21	11,60	79,70	118,00	34,46	12,35	32,17	128,17	163	28,37	9,81	89,01	26,48	53,13	142,14
22	11,60	79,70	118,00	34,46	12,91	31,95	128,63	163	28,37	9,81	94,08	26,30	53,13	147,21
23	11,60	79,70	118,00	34,46	13,46	31,72	129,08	163	28,37	9,81	99,07	26,11	53,13	152,20
24	11,60	79,70	118,00	34,46	14,02	31,48	129,54	163	28,37	9,81	103,97	25,91	53,13	157,11
25	11,60	79,70	118,00	34,46	14,56	31,23	129,99	163	28,37	9,81	108,80	25,71	53,13	161,93
26	11,60	79,70	118,00	34,46	15,11	30,97	130,44	163	28,37	9,81	113,53	25,50	53,13	166,66
27	11,60	79,70	118,00	34,46	15,64	30,70	130,88	163	28,37	9,81	118,17	25,27	53,13	171,30
28	11,60	79,70	118,00	34,46	16,18	30,42	131,32	163	28,37	9,81	122,72	25,05	53,13	175,85
29	11,60	79,70	118,00	34,46	16,71	30,14	131,75	163	28,37	9,81	127,16	24,81	53,13	180,30
30	11,60	79,70	118,00	34,46	17,23	29,84	132,18	163	28,37	9,81	131,51	24,57	53,13	184,64
31	11,60	79,70	118,00	34,46	17,75	29,54	132,61	163	28,37	9,81	135,75	24,31	53,13	188,89
32	11,60	79,70	118,00	34,46	18,26	29,22	133,03	163	28,37	9,81	139,89	24,06	53,13	193,02
33	11,60	79,70	118,00	34,46	18,77	28,90	133,45	163	28,37	9,81	143,92	23,79	53,13	197,05
34	11,60	79,70	118,00	34,46	19,27	28,57	133,86	163	28,37	9,81	147,84	23,52	53,13	200,97
35	11,60	79,70	118,00	34,46	19,76	28,23	134,27	163	28,37	9,81	151,65	23,24	53,13	204,78
36	11,60	79,70	118,00	34,46	20,25	27,88	134,67	163	28,37	9,81	155,34	22,95	53,13	208,47
37	11,60	79,70	118,00	34,46	20,74	27,52	135,07	163	28,37	9,81	158,92	22,65	53,13	212,05
38	11,60	79,70	118,00	34,46	21,21	27,15	135,46	163	28,37	9,81	162,38	22,35	53,13	215,51
39	11,60	79,70	118,00	34,46	21,69	26,78	135,85	163	28,37	9,81	165,72	22,05	53,13	218,85
40	11,60	79,70	118,00	34,46	22,15	26,40	136,23	163	28,37	9,81	168,93	21,73	53,13	222,07
41	11,60	79,70	118,00	34,46	22,61	26,01	136,61	163	28,37	9,81	172,03	21,41	53,13	225,17
42	11,60	79,70	118,00	34,46	23,06	25,61	136,98	163	28,37	9,81	175,01	21,08	53,13	228,14



Rinnovabili Sud Tre S.r.l.
Via della Chimica 103, Potenza (PZ)
rinnovabilisudtre@pec.it
Tel: 0971 281981

Impianto Eolico San Giovanni in Galdo

Analisi degli effetti di rottura degli organi rotanti

43	11,60	79,70	118,00	34,46	23,50	25,20	137,35	163	28,37	9,81	177,86	20,75	53,13	230,99
44	11,60	79,70	118,00	34,46	23,94	24,79	137,71	163	28,37	9,81	180,59	20,41	53,13	233,72
45	11,60	79,70	118,00	34,46	24,37	24,37	138,06	163	28,37	9,81	183,19	20,06	53,13	236,33
46	11,60	79,70	118,00	34,46	24,79	23,94	138,41	163	28,37	9,81	185,67	19,71	53,13	238,81
Angolo <i>a</i>	n	L	H _{torre}	v ₀	v _{x0}	v _{y0}	H _g	D	r _g	g	Gittata teorica	X _g	L _g	Gittata Effettiva
47	11,60	79,70	118,00	34,46	25,20	23,50	138,75	163	28,37	9,81	188,03	19,35	53,13	241,16
48	11,60	79,70	118,00	34,46	25,61	23,06	139,08	163	28,37	9,81	190,26	18,98	53,13	243,39
49	11,60	79,70	118,00	34,46	26,01	22,61	139,41	163	28,37	9,81	192,36	18,61	53,13	245,49
50	11,60	79,70	118,00	34,46	26,40	22,15	139,73	163	28,37	9,81	194,34	18,23	53,13	247,47
51	11,60	79,70	118,00	34,46	26,78	21,69	140,05	163	28,37	9,81	196,20	17,85	53,13	249,33
52	11,60	79,70	118,00	34,46	27,15	21,21	140,35	163	28,37	9,81	197,93	17,46	53,13	251,06
53	11,60	79,70	118,00	34,46	27,52	20,74	140,65	163	28,37	9,81	199,54	17,07	53,13	252,67
54	11,60	79,70	118,00	34,46	27,88	20,25	140,95	163	28,37	9,81	201,02	16,67	53,13	254,16
55	11,60	79,70	118,00	34,46	28,23	19,76	141,24	163	28,37	9,81	202,39	16,27	53,13	255,52
56	11,60	79,70	118,00	34,46	28,57	19,27	141,52	163	28,37	9,81	203,63	15,86	53,13	256,77
57	11,60	79,70	118,00	34,46	28,90	18,77	141,79	163	28,37	9,81	204,76	15,45	53,13	257,89
58	11,60	79,70	118,00	34,46	29,22	18,26	142,06	163	28,37	9,81	205,77	15,03	53,13	258,90
59	11,60	79,70	118,00	34,46	29,54	17,75	142,31	163	28,37	9,81	206,66	14,61	53,13	259,79
60	11,60	79,70	118,00	34,46	29,84	17,23	142,57	163	28,37	9,81	207,43	14,18	53,13	260,57
61	11,60	79,70	118,00	34,46	30,14	16,71	142,81	163	28,37	9,81	208,10	13,75	53,13	261,23
62	11,60	79,70	118,00	34,46	30,42	16,18	143,05	163	28,37	9,81	208,65	13,32	53,13	261,78
63	11,60	79,70	118,00	34,46	30,70	15,64	143,27	163	28,37	9,81	209,09	12,88	53,13	262,22
64	11,60	79,70	118,00	34,46	30,97	15,11	143,50	163	28,37	9,81	209,43	12,44	53,13	262,56
65	11,60	79,70	118,00	34,46	31,23	14,56	143,71	163	28,37	9,81	209,66	11,99	53,13	262,79



Rinnovabili Sud Tre S.r.l.
Via della Chimica 103, Potenza (PZ)
rinnovabilisudtre@pec.it
Tel: 0971 281981

Impianto Elico San Giovanni in Galdo

Analisi degli effetti di rottura degli organi rotanti

66	11,60	79,70	118,00	34,46	31,48	14,02	143,91	163	28,37	9,81	209,78	11,54	53,13	262,91
67	11,60	79,70	118,00	34,46	31,72	13,46	144,11	163	28,37	9,81	209,81	11,08	53,13	262,94
68	11,60	79,70	118,00	34,46	31,95	12,91	144,30	163	28,37	9,81	209,73	10,63	53,13	262,86
69	11,60	79,70	118,00	34,46	32,17	12,35	144,48	163	28,37	9,81	209,56	10,17	53,13	262,69
70	11,60	79,70	118,00	34,46	32,38	11,79	144,66	163	28,37	9,81	209,30	9,70	53,13	262,43
71	11,60	79,70	118,00	34,46	32,58	11,22	144,82	163	28,37	9,81	208,94	9,24	53,13	262,07
72	11,60	79,70	118,00	34,46	32,77	10,65	144,98	163	28,37	9,81	208,49	8,77	53,13	261,63
73	11,60	79,70	118,00	34,46	32,95	10,07	145,13	163	28,37	9,81	207,96	8,29	53,13	261,09
74	11,60	79,70	118,00	34,46	33,12	9,50	145,27	163	28,37	9,81	207,34	7,82	53,13	260,48
75	11,60	79,70	118,00	34,46	33,28	8,92	145,40	163	28,37	9,81	206,64	7,34	53,13	259,78
Angolo <i>a</i>	n	L	H_{torre}	v₀	v_{x0}	v_{y0}	H_g	D	r_g	g	Gittata teorica	X_g	L_g	Gittata Effettiva
76	11,60	79,70	118,00	34,46	33,43	8,34	145,52	163	28,37	9,81	205,87	6,86	53,13	259,00
77	11,60	79,70	118,00	34,46	33,58	7,75	145,64	163	28,37	9,81	205,01	6,38	53,13	258,15
78	11,60	79,70	118,00	34,46	33,71	7,16	145,75	163	28,37	9,81	204,09	5,90	53,13	257,22
79	11,60	79,70	118,00	34,46	33,83	6,57	145,85	163	28,37	9,81	203,09	5,41	53,13	256,23
80	11,60	79,70	118,00	34,46	33,93	5,98	145,94	163	28,37	9,81	202,03	4,93	53,13	255,16
81	11,60	79,70	118,00	34,46	34,03	5,39	146,02	163	28,37	9,81	200,90	4,44	53,13	254,03
82	11,60	79,70	118,00	34,46	34,12	4,80	146,09	163	28,37	9,81	199,70	3,95	53,13	252,84
83	11,60	79,70	118,00	34,46	34,20	4,20	146,16	163	28,37	9,81	198,45	3,46	53,13	251,59
84	11,60	79,70	118,00	34,46	34,27	3,60	146,21	163	28,37	9,81	197,14	2,97	53,13	250,28
85	11,60	79,70	118,00	34,46	34,33	3,00	146,26	163	28,37	9,81	195,78	2,47	53,13	248,91
86	11,60	79,70	118,00	34,46	34,37	2,40	146,30	163	28,37	9,81	194,36	1,98	53,13	247,50
87	11,60	79,70	118,00	34,46	34,41	1,80	146,33	163	28,37	9,81	192,90	1,48	53,13	246,03



Impianto Elico San Giovanni in Galdo

Analisi degli effetti di rottura degli organi rotanti

88	11,60	79,70	118,00	34,46	34,44	1,20	146,35	163	28,37	9,81	191,39	0,99	53,13	244,52
89	11,60	79,70	118,00	34,46	34,45	0,60	146,36	163	28,37	9,81	189,83	0,50	53,13	242,96
90	11,60	79,70	118,00	34,46	34,46	0,00	146,37	163	28,37	9,81	188,23	0,00	53,13	241,37

Tabella 1 – Calcolo della gittata massima ed effettiva per angolo α compreso tra 0° e 90°



La gittata massima si ottiene per $\alpha=67^\circ$ ed il risultato numerico è pari a **209,81 m**; questo valore rappresenta il valore della gittata massima teorica per il distacco in corrispondenza del mozzo.

Noto il valore di gittata massima teorica e date le caratteristiche geometriche della pala, precedentemente valutate, si può calcolare la gittata massima effettiva.

Supponendo di prendere in considerazione l'ipotesi più gravosa, ossia quella in cui la pala cadendo si disponga con la parte più lontana dal baricentro verso l'esterno, si ottiene che la gittata massima effettiva è pari al valore massimo di gittata teorica + Lg, ovvero i 2/3 della lunghezza della pala che risulta quindi:

- Punto massima caduta: $209,81 + 53,13 = \mathbf{262,94 \text{ m}}$

4. APPLICAZIONE DELLO STUDIO AL PROGETTO IN ESAME

Nel progetto in esame si prevede la realizzazione di n.5 aerogeneratori del modello NORDEX con diametro rotore 163 m e altezza torre 118 m ubicati in Località 'Fiego' dei Comuni di **San Giovanni in Galdo (CB)** e **Campolieto (CB)** con opere di connessione nei comuni di **San Giovanni in Galdo (CB)**, **Campolieto (CB)** e **Morrone del Sannio (CB)** aventi una potenza massima unitaria pari a 6,6 MW, per una potenza installata massima dell'impianto pari a 33,00 MW.

Il calcolo della gittata massima appena descritto mostra come tale valore, nel caso maggiormente cautelativo, si attestì a 262,94 m.

È stata considerata una distanza di 263 m da ogni aerogeneratore come buffer di sicurezza da rottura, come si può osservare dalla figura seguente che mostra come tutti i fabbricati, e fra essi, anche quelli individuati come recettori, siano esterni alla fascia di rispetto indicata in caso di rottura degli organi rotanti.






Figura 2 - Ortofoto con opere di impianto, fabbricati individuati (recettori) e buffer di sicurezza degli aerogeneratori

5. CONCLUSIONI

La presente relazione descrive il calcolo eseguito al fine della valutazione della gittata massima che si verifica in caso di rottura accidentale di un aerogeneratore considerando il caso più gravoso. In base a quanto riportato, il punto di caduta più lontano, nel caso di rottura dell'intera pala corrisponde a 209,81 m per la gittata teorica e a **262,94 m** per la gittata effettiva. I valori di gittata sono stati ottenuti senza considerare le forze resistenti e l'attrito dell'aria, che avrebbero restituito una misurazione della gittata inferiore.

Dall'analisi condotta risulta verificata la *distanza minima di ogni aerogeneratore da ogni potenziale recettore* ai sensi del DM 10/09/2010 "Linee guida per l'autorizzazione degli impianti alimentati dalle Fonti Rinnovabili", *posta pari a 200 m; è inoltre verificata la distanza di sicurezza da rispettare in caso di rottura degli organi rotanti*, giacché il fabbricato che *può considerarsi come "recettore" più prossimo, in quanto appartenente alla categoria catastale "abitazione"*, così come definito dalle Linee Guida di cui al DM 10/09/2010 e dalle normative di settore di riferimento ai fini dell'analisi condotta, **dista circa 416 m dall'aerogeneratore più prossimo.**

L'altro fabbricato più prossimo all'impianto dista circa **408 m** dall'aerogeneratore più prossimo e trattasi in questo caso di fabbricato per funzioni produttive connesse alle attività agricole (tipo D). Si conclude quindi che nell'ipotesi remota di rottura di un aerogeneratore, l'impianto in progetto risulti sicuro.

Si sottolinea che dalla pratica sul campo per questo tipo di impianti, oltre che da studi specialistici pubblicati, il fenomeno della rottura dell'aerogeneratore risulta una eventualità molto remota.

Si conclude, quindi, che il progetto dell'impianto eolico, proposto dalla società Rinnovabili Sud Tre S.r.l. in Località 'Fiego' dei Comuni di **San Giovanni in Galdo (CB)** e **Campolieto (CB)** con opere di connessione nei comuni di **San Giovanni in Galdo (CB)**, **Campolieto (CB)** e **Morrone del Sannio (CB)** costituito da 5 aerogeneratori (modello NORDEX N163 da 6,6 MW, diametro rotore 163 m e altezza torre 118 m) aventi una potenza massima unitaria pari a 6,6 MW per una potenza installata massima dell'impianto pari a 33,00 MW, non ostacola la pubblica sicurezza nell'ipotesi remota di rottura di una pala.





General documentation

Technical description

Delta4000 - N163/6.X

Rev. 04 / 2022-08-05

Document no.:	2014649EN
Status:	Released
Language:	EN-English
Classification:	Nordex Internal Purpose

- Translation of the original document (2014649EN, rev. 04) -
This is a translation from German. In case of doubt, the German text shall prevail.
Document will be distributed electronically.
Signed original at Nordex Energy SE & Co. KG, Engineering Department.

This document, including any presentation of its contents in whole or in part, is the intellectual property of Nordex Energy SE & Co. KG. The information contained in this document is intended exclusively for Nordex employees and employees of trusted partners and subcontractors of Nordex Energy SE & Co. KG, Nordex SE and their affiliated companies as defined in section 15 et seq. of the German Stock Corporation Act (AktG) and must never (not even in extracts) be disclosed to third parties.

All rights reserved.

Any disclosure, duplication, translation or other use of this document or parts thereof, regardless if in printed, handwritten, electronic or other form, without the explicit approval of Nordex Energy SE & Co. KG is prohibited.

© 2022 Nordex Energy SE & Co. KG, Hamburg

Manufacturer's address as per Machinery Directive:

Nordex Energy SE & Co. KG
Langenhorner Chaussee 600
22419 Hamburg
Germany

Phone: +49 (0)40 300 30 -1000
Fax: +49 (0)40 300 30 - 1101
info@nordex-online.com
<http://www.nordex-online.com>

Validity

Turbine generation	Product series	Product
Delta	Delta4000	N163/6.X

1.	Structure.....	5
1.1	Tower	5
1.2	Rotor	6
1.3	Nacelle.....	6
1.4	Auxiliary systems	7
1.4.1	Automatic lubrication system	7
1.4.2	Heaters.....	8
1.4.3	E-chain hoist and crossbeam.....	8
1.4.4	Cooling system	8
2.	Control and electrical system	9
2.1	Safety systems.....	9
2.2	Lightning/overvoltage protection, electromagnetic compatibility (EMC).....	10
2.3	Medium-voltage system.....	10
2.4	Low-voltage grid types	11
2.5	Auxiliary power of the wind turbine	11
3.	Options	12
4.	Technical data.....	13
4.1	Technical design	13
4.2	Towers.....	13
4.3	Rotor and rotor blades.....	14
4.4	Nacelle.....	14
4.4.1	Rotor shaft	14
4.4.2	Brake and gearbox	14
4.4.3	E-chain hoist and crossbeam.....	15
4.5	Electrical system	15
4.5.1	Transformer	16
4.5.2	Medium-voltage switchgear	16
4.5.3	Generator	17
4.6	Cooling system.....	18
4.7	Pitch system	18
4.8	Yaw system	18
4.9	Corrosion protection.....	19
4.10	Automation systems	19

1. Structure

The Nordex N163/6.X wind turbine (WT) is a speed-variable wind turbine with a rotor diameter of 163 m and a nominal power of 7000 kW, which can be adapted dependent on location. The wind turbine is designed for class S in accordance with IEC 61400-1 or wind zone S in accordance with DIBt 2012 and is available in 50 Hz and 60 Hz variants.

A Nordex N163/6.X wind turbine consists of the following main components:

- Rotor with rotor hub, three rotor blades and the pitch system
- Nacelle with rotor shaft and bearing, gear, generator, Yaw system, medium voltage transformer and converter
- Tubular steel tower or hybrid tower with medium-voltage switchgear.

1.1 Tower

The wind turbine N163/6.X can be erected on a steel tower or on a hybrid tower. The tubular steel tower consists of several conical or cylindrical sections. This tower is bolted to the anchor cage embedded in the foundation. The bottom part of the hybrid tower consists of a concrete tower and the top part of a tubular steel tower with two sections.

A climbing assistance, e. g a service lift or a step ladder, the vertical ladder with fall protection system as well as resting and working platforms inside the tower allow for a weather-protected ascent to the nacelle.




Fig. 1: Overview of installations in the bottom section of the steel tube tower with a vertical ladder (in case of a step ladder different image)

- | | |
|-------------------|----------------------|
| 1 Flange platform | 4 Tower service lift |
| 2 MV switchgear | 5 Control cabinet |
| 3 Tower access | 6 Ladder path |

The foundation structure of all towers depends on the soil conditions at the intended location.

1.2 Rotor

The rotor consists of the rotor hub with three slewing bearings, the pitch system for blade adjustment and three rotor blades.

The **rotor hub** consists of a base element with support system and spinner. The base element consists of a stiff cast structure, on which the pitch bearings and the rotor blades are assembled. The rotor hub is covered with the spinner which enables the direct access from the nacelle into the rotor hub.

The **rotor blades** are made from high quality fiber glass- and carbon-fiber reinforced plastic. The rotor blade is tested statically and dynamically in accordance with the guidelines IEC 61400-23 and DNVGL-ST-0376.

The **pitch system** serves to adjust the pitch angle of the rotor blades set by the control system. For each individual rotor blade the pitch system comprises an electromechanical drive with rotary current motor, planetary gear and drive pinion, as well as a control unit with frequency converter and emergency power supply. Power supply and signal transfer are realized through a slip ring in the nacelle.

1.3 Nacelle

The nacelle contains essential mechanical and electric components of the wind turbine.

The **rotor shaft** transmits the rotary motion of the rotor to the gearbox and is mounted in the **rotor bearing** in the nacelle. A rotor lock is integrated in the rotor bearing housing, with which the rotor can be reliably locked in place mechanically.

With the mechanical **rotor brake** the rotor is locked during maintenance work. For this, a sufficient oil pressure is generated by the hydraulic pump.

The **gearbox** increases the rotor speed until it reaches the speed required for the generator. The bearings and gearings are continuously lubricated with oil. A combination filter element with coarse, fine and ultrafine filter retains solid particles. The control system monitors the contamination of the filter element. The gear oil used for lubrication also cools the gearbox. The temperatures of the gearbox bearings and the oil are continuously monitored. If the optimum operating temperature is not yet reached, a thermal bypass directs the gear oil directly back to the gearbox. Only when the gear oil temperature reaches a predetermined value is the transmission oil cooled by an oil / water cooler, which is located directly on the gearbox. As a result, the gear oil temperature is kept in a narrow temperature range during operation.

The **coupling** acts as force-transmitting connection between the gearbox and the generator.

The **generator** is a 6-pole doubly-fed induction machine. The generator has a built-on air-water heat exchanger and is connected to the cooling circuit.

The **converter** connects the electrical grid to the generator which means the generator can be operated with variable rotational speeds.

The **transformer** converts the low voltage of the generator-converter system into medium voltage of the wind farm grid. The transformer is cooled by the connection to the cooling circuit.

In the **switch cabinet**, all electrical components required for the control and supply of the turbine are located.

The cooling water is re-cooled by a **passive cooler** on the nacelle roof.

The **yaw drives** optimally rotate the nacelle into the wind. The yaw drives are located on the machine frame in the nacelle. A yaw drive consists of an electric motor, multi-stage planetary gear, and a drive pinion. The drive pinions mesh with the external teeth of the yaw bearing. In the aligned position the nacelle is held with the yaw drives.

All nacelle assemblies are protected against wind and weather conditions by means of a **nacelle housing**.




Abb. 2: Schematic diagram of the nacelle

- | | |
|-------------------|-----------------|
| 1 Passive cooler | 7 Rotor bearing |
| 2 Cabinet | 8 Yaw drives |
| 3 Generator | 9 Rotor brake |
| 4 Gearbox | 10 Coupling |
| 5 Rotor shaft | 11 Transformer |
| 6 Nacelle housing | 12 Converter |

1.4 Auxiliary systems

1.4.1 Automatic lubrication system

Generator bearing, gearing of the pitch bearings, rotor bearing and gearing of the yaw bearing are each equipped with an **automatic lubrication system**.

1.4.2 Heaters

Gearbox, generator, cooling circuit and all relevant switch cabinets are equipped with **heaters**.

1.4.3 E-chain hoist and crossbeam

An electric **chain hoist** is installed in the nacelle which is used for lifting tools, components and other work materials from the ground into the nacelle.

A crossbeam including a sliding trolley is prepared for the use of a manual chain hoist to move the materials within the nacelle.

1.4.4 Cooling system

Two separate cooling circuits ensure cooling of the large components. Converter and gearbox are cooled in one cooling circuit and generator and transformer in the other.

Both cooling circuits are connected to passive coolers on the nacelle roof, in which the water is recooled.




Abb. 3: Schematic representation of the cooling circuit

2. Control and electrical system

The WT operates automatically. A programmable logic controller (PLC) continuously monitors the operating parameters using various sensors, compares the actual values with the corresponding setpoints and issues the required control signals to the WT components. The operating parameters are specified by Nordex and are adapted to the individual location. The controller is located in a control cabinet in the tower base.

When there is no wind the WT remains in idle mode. Only various auxiliary systems are operational or activated as required: e.g., heaters, gear lubrication or PLC, which monitors the data from the wind measuring system. All other systems are switched off and do not use any energy. The rotor idles. When the cut-in wind speed is reached, the WT changes to the "ready for operation" condition. Now all systems are tested, the nacelle turns into the wind and the rotor blades turn into the wind. When a certain speed is reached, the generator is connected to the grid and the WT produces electrical energy.

At low wind speeds the WT operates at part load. The rotor blade remain turned into wind to the maximum extent. The power produced by the WT depends on the wind speed.

When the nominal wind speed is reached, the WT switches over to the nominal load range. If the wind speed continues to increase, the speed control changes the rotor blade angle so that the rotor speed and thus the power output of the WT remain constant.

The yaw system ensures that the nacelle is always optimally aligned to the wind. To this end two separate wind measuring systems on the nacelle measure the wind direction. Only one wind measuring system is used for the control system, while the second system monitors the first and takes over in case the first system fails. If the wind direction measured deviates too much from the nacelle alignment, the nacelle is yawed into the wind.

The wind energy absorbed from the rotor is converted into electrical energy using a doubly-fed induction machine with slip ring rotor. Its stator is connected directly, and the rotor via a specially controlled frequency converter, to the MV transformer which connects the turbine to the grid. Only part of the power needs to be routed via the converter, permitting low electrical system losses.

2.1 Safety systems

Nordex wind turbines are equipped with technical equipment and devices that protect people and systems and ensure permanent operation. The entire turbine is designed in accordance with the Machinery Directive 2006/42/EC and certified as per IEC 61400.

Safety-relevant parameters in the system control are monitored continuously. Here, the sensor data of the safe sensors are transmitted via a safe bus system to the safe controller for evaluation. If specified parameters are exceeded, the system is stopped via actuators and set to a safe state.

Depending on the cut-out cause, different brake programs are triggered. In event of external causes, such as excessive wind speeds or below operating temperatures, the wind turbine is gently braked by means of rotor blade adjustment. Other safety functions are used to stop drives safely for maintenance work.

2.2 Lightning/overvoltage protection, electromagnetic compatibility (EMC)

The lightning/surge protection of the wind turbine is based on the EMC-compliant lightning protection zone concept, which comprises the implementation of internal and external lightning/surge protection measures under consideration of the standard IEC 61400-24. The wind turbine is designed according to lightning protection class I.

The wind turbine with the electrical equipment, consumers, the measurement, control, protection, information and telecommunication technology meets the EMC requirements according to IEC 61400-1.

2.3 Medium-voltage system

The medium voltage components are used to connect a WT to the wind farm medium-voltage grid or the local grid operator. The tower base contains the **MV switchgear**. It consists of a transformer field with circuit breakers and at least one ring cable field as default and up to three ring cable fields as an option (dependent on the wind farm configuration). The transformer panel consists of a vacuum circuit breaker and the disconnector with ground switch. The ring cable panel consist of a switch disconnector with a ground switch. The entire MV switchgear is assembled on a support/adapter frame.

Further characteristics of the MV switchgear:

- Routine tests of each switchgear in compliance with IEC 62271-200
- Type tested, SF6 insulation
- Internal switchgear for self-contained electrical systems (min. IP2X)
- SF-6 tank: metal-clad, metal-enclosed (min. IP65), independent of environmental influences
- Switch positions shown "On - Off - Grounded"
- Test terminal strip for secondary test
- Low-maintenance in accordance with class E2 (IEC 62271-100)

In case of technical availability Nordex can as an alternative to traditional SF6 insulated switchgear also supply SF6-free switchgear. This option is to be agreed upon with Nordex in advance.

The system protection of the MV switchgear is achieved by the following items:

- Improved personal safety and system protection in case of arcing by type testing in compliance with IEC 62271-200
- Protection device supplied with converter current and stabilized for inrush current as DMT protection relay (independent maximum current protection)
- Actuating openings for switchgear are interlocked to preclude operation of more than one simultaneously, and can be locked as an option
- Corrosion protection of the switchgear cells through hot-dip galvanization and painted surfaces
- Pressure relief by pressure absorber duct in case of arcing. Alternatively, for the USA, an arc suppressor can be installed in the tank and in the cable connection compartment.

Transformer and **converter** are located in the nacelle. The transformer has been specified in accordance with IEC 60076-16.

The steel components at the transformer are dimensioned for corrosion protection class C3 (H). Additional protection measures:

- Grounded tank (Ester transformer)
- Overtemperature protection with temperature sensor and relay
- Hermetic protection (leakage) and overpressure protection for ester transformer

2.4 Low-voltage grid types

The **950 V low voltage grid** is the primary wind turbine low voltage energy system. It is insulated from the ground as an IT grid and three phase AC network. The elements of the electrical operating and measuring devices of this network are grounded directly or via separate protective equipotential bonding cables. A central insulation monitor has been installed as another protective measure for personal and turbine safety in the 950-V-IT system.

The **400 V/230 V low voltage grid** is the auxiliary wind turbine low voltage system. It has its neutral point grounded directly in the supplying grid transformers as a TN system and three-phase system. The equipment grounding conductor PE and the neutral conductor are available separately. The bodies of electrical equipment and consumers, including the additional protective equipotential bonding, are connected directly, through protective earthing conductor connections, straight to the neutral points of the supply grid transformers.

2.5 Auxiliary power of the wind turbine

The auxiliary low voltage required by the wind turbine in stand-by mode and feed-in mode is requested by the following consumers:

- System control including main converter control
- 400 V/230 V auxiliary power of the main converter
- 230 V AC UPS supply including 24 V DC supply
- Yaw system
- Pitch system
- Auxiliary drives such as pumps, fans and lubrication units
- Heating and lighting
- Auxiliary systems such as service lift, obstacle lights

Long-term measurements show that the average annual base load of the low-voltage auxiliary power plant in WT feed-in operation is approx. 15 kW in the average 10 min mean value and the maximum 10-min average value can reach up to 25 kW/32kVA. These values are already included in the power curves. For locations with an average annual wind speed of 6.5 m/s approx. 10 MWh auxiliary consumption arise, however, this value is greatly dependent on location.

Auxiliary consumption is defines as the energy consumption of the WT from the grid for a period during which the WT does not supply current to the grid.

3. Options

Various options are available upon request as additional equipment for Nordex wind turbines.

The option of optional equipment must be coordinated with Nordex in advance.

4. Technical data

4.1 Technical design

Technical design	
Survival temperature	-40 °C to +50 °C
Operating temperature range of the Normal Climate Version	-20 °C to +40 °C ¹⁾
Operating temperature range of the Cold Climate Version	-30 °C to +40 °C ¹⁾
Stop	Standard: -20 °C, restart at -18 °C CCV: -30 °C, restart at -28 °C
Max. height above MSL	2000 m ¹⁾
Certificate	In accordance with IEC 61400-22 and DIBt 2012
Type	3-blade rotor with horizontal axis Up-wind turbine
Output control	Active single blade adjustment
Nominal power	up to 7000 kW ¹⁾
Rated power at wind speed (at an air density of 1.225 kg/m ³)	Approx. 13.5 m/s
Operating speed range of the rotor	6.0 min ⁻¹ to 11.6 min ⁻¹
Nominal speed	approx. 10.0 min ⁻¹
Cut-in wind speed	3 m/s
Cut-out wind speed	26 m/s ²⁾
Cut-back-in wind speed	25.5 m/s ²⁾
Calculated service life	≥ 25 years

¹⁾ Nominal output is achieved depending on the power factor and the installation altitude up to defined temperature ranges.

²⁾ Depending on the project, the cut-out wind speed can be decreased to safeguard the structural stability.

4.2 Towers

Towers	TS118-03	TS138	TS148-01	TS159-01	TCS164
Hub height*	118.0 m	138.0 m	148.0 m	158.5 m	164.0 m
Tower type	Tubular steel tower				Hybrid tower
Wind class	IEC S DIBt S	IEC S	IEC S	IEC S	IEC S DIBt S
Surface finish	Color system coating				**

* Includes foundation height above ground level

** Steel section: Color system coating; Concrete part: Fair-faced concrete

4.3 Rotor and rotor blades

Rotor	
Rotor diameter	163.0 m
Swept area	20867 m ²
Nominal power/area	326 W/m ²
Rotor shaft inclination angle	5 °
Blade cone angle	5.5 °

Rotor blade	
Material	fiber glass and carbon fiber reinforced plastic
Total length	79.7 m

Rotor hub	
Material of the rotor hub body	Casting
Material spinner	glass-fiber reinforced plastic

4.4 Nacelle

Nacelle	
Support structure	welded steel structure
Cladding	glass-fiber reinforced plastic
Machine frame	Casting
Generator frame	welded steel construction

4.4.1 Rotor shaft

Rotor shaft/rotor bearing	
Type	Forged hollow shaft
Material	42CrMo4 or 34CrNiMo6
Bearing type	Spherical roller bearing
Lubrication	Regularly using lubricating grease

4.4.2 Brake and gearbox

Mechanical brake	
Type	Actively actuated disk brake
Location	On the high-speed shaft
Number of brake calipers	1
Brake pad material	Organic pad material

Gearbox	
Type	Multi-stage planetary gear + spur gear stage
Gear ratio	50 Hz: $i = 122.4$ 60 Hz: $i = 146.9$
Lubrication	Forced-feed lubrication
Oil quantity including cooling circuit	max. 800 l
Oil type	VG 320
Max. oil temperature	Approx. 77 °C
Oil change	Change, if required

4.4.3 E-chain hoist and crossbeam

E-chain hoist and lifting beam	
Electrical chain hoist max load	Min. 850 kg
Crossbeam max load	Sliding trolley to accommodate a manual chain hoist 1000 kg

4.5 Electrical system

Electrical system *	
Nominal power P_{nG}	7000
Nominal voltage	3 x AC 950 V ± 10 % (specific to grid code)
Nominal current during full reactive current feed-in I_{nG} at S_{nG}	4727 A
Nominal apparent power S_{nG} at P_{nG}	7778 kVA
Frequency	50 and 60 Hz

*) All data are maximum values. The values may deviate depending on the rated voltage, rated apparent power and WT active power.

4.5.1 Transformer

Transformer*	50 Hz	60 Hz
Total weight		approx. 10 t
Insulation medium		Ester
Rated voltage OV, U_r		950 V
Maximum rated voltage OS, dependent on MV grid, U_r		20 kV/30 kV/34 kV
Taps, overvoltage side	20 kV and 30 kV: + 4 x 2.5 % 34 kV: + 4 x 0.5 kV	
Grid voltage OS	20; 20.5; 21; 21.5; 22 kV 30; 30.75; 31.5; 32.25; 33 kV 34; 34.5; 35; 35.5; 36 kV	
Rated frequency, f_r	50 Hz	60 Hz
Vector group		Dy5
Installation altitude (above MSL)		Up to 2000 m
Rated apparent power, S_r		7800 kVA
Impedance voltage, U_z		9 % ± 10 % tolerance
Minimum peak efficiency index, η , (EU) 2019/1783, 548/2014	99.590%	-
Inrush current		≤ 5.5 x I_N (peak value)
Power loss ¹⁾		
No-load losses	3050 W	4300 W
Short circuit losses	80000 W	80700 W

*) The values are, if not specified otherwise, maximum values. The values may deviate depending on the rated voltage, rated apparent power and WT active power.

1) Guide values

4.5.2 Medium-voltage switchgear

Medium-voltage switchgear	
Rated voltage (dependent on MV grid)	24; 36; 38 or 40.5 kV
Rated current	50 Hz: 630 A 60 Hz: 600 A
Rated short-circuit duration	1 s
Rated short circuit current	24 kV: 16 kA (20 kA optional) 36/38/40.5 kV: 20 kA (25 kA optional)
Minimum/maximum ambient temperature during operation	NCV: -25 °C to +40 °C CCV: -30 °C to +40 °C
Connection type	External cone type C according to EN 50181 USA: External cone type E according to IEEE 386
Circuit breaker	
Number of switching cycles with rated current	E2
Number of switching cycles with short-circuit breaking current	E2
Number of mechanical switching cycles	M1
Switching of capacitive currents	Min. C1 - low
Switch disconnector	
Number of switching cycles with rated current	E3
Number of switching cycles with short-circuit breaking current	E3
Number of mechanical switching cycles	M1
Disconnector	
Number of mechanical switching cycles	M0
Ground switch	
Switching number with rated short-circuit inrush current	E2
Number of mechanical switching cycles	≥ 1000

4.5.3 Generator

Generator	
Type	6-pole doubly-fed induction machine
Degree of protection	IP 54 (slip ring box IP 23)
Nominal voltage	950 V
Frequency	50 and 60 Hz
Speed range	50 Hz: 650 to 1500 min ⁻¹ 60 Hz: 780 to 1800 min ⁻¹
Poles	6
Weight	approx. 13.5 t

4.6 Cooling system

Cooling system	
Gearbox	
Type	Oil circuit with oil/water heat exchanger and thermal bypass
Filters	Coarse filter 50 µm / fine filter 10 µm / ultrafine filter <5 µm
Generator	
Type	Water circuit with water/air heat exchanger and thermal bypass
Coolant	Water/glycol-based coolant
Converter	
Type	Water circuit with water/air heat exchanger and thermal bypass
Coolant	Water/glycol-based coolant
Transformer	
Coolant	Water/glycol-based coolant
Cooling circuit	Ester circuit with ester/water heat exchanger

4.7 Pitch system

Pitch system	
Pitch bearing	Double-row four-point contact bearing
Gearing/raceway lubrication	Regular lubrication with grease
Drive	Electric motors incl. spring-loaded brake and multi-stage planetary gear
Emergency power supply	Batteries

4.8 Yaw system

Yaw system	
Yaw bearing	Double-row four-point contact bearing
Gearing/raceway lubrication	Regular lubrication with grease
Drive	Electric motors incl. spring-loaded brake and four-stage planetary gear
Number of drives	5-6
Yaw speed	Approx. 0.4 °/s

4.9 Corrosion protection

Corrosion protection*	Inside	Outside
Nacelle	C3	C4
Hub, including material spinner	C3	C4
Tower	C3	C4
Steel sections	Color system coating	Color system coating
Concrete components	Fair-faced concrete	Fair-faced concrete

* Categories of corrosion protection according to ISO 12944-2

4.10 Automation systems

Automation system	
Field bus system	Profinet
Safe fieldbus system	Profisafe via Profinet
Turbine control	Profinet system control
Safety control	Integrated safety control

