

IMPIANTO FOTOVOLTAICO EG LAGO SRL E OPERE CONNESSE

POTENZA IMPIANTO 12,67 MWp - COMUNE DI ARGENTA (FE)

Proponente

EG LAGO S.R.L.

VIA DEI PELLEGRINI 22 · 20122 MILANO (MI) · P.IVA: 12084550966 · PEC: eglago@pec.it

Progettazione



TECNOSTUDIO S.R.L. Arch. Diego Zanaica

Via Aquileia, 56 - 35035 Mestrino (PD)
tel.: +39 0499000684 · email: info@tecnostudio-pd.it
PEC: tecnostudio@legalmail.com



QUATTROE S.R.L. Ing. Luigi De Santi

Via Primo Maggio, 12A - 35035 Mestrino (PD)
cell.: 340 3309775 email: info@quattroe.eu

Coordinamento progettuale



SOLAR IT S.R.L.

VIA ILARIA ALPI, 4 · 46100 MANTOVA (MN) · P.IVA: 02627240209 · email: solarit@lamiapec.it

Titolo Elaborato

STIMA DI PRODUCIBILITA' DELL'IMPIANTO

| LIVELLO PROGETTAZIONE | CODICE ELABORATO | FILENAME | RIFERIMENTO | DATA | SCALA |
|-----------------------|------------------|----------|-------------|----------|-------|
| DEFINITIVO | REL20 | - | - | 30/11/23 | |

Revisioni

| REV. | DATA | DESCRIZIONE | ESEGUITO | VERIFICATO | APPROVATO |
|------|----------|-------------|--------------|------------|-----------|
| 0 | 30/11/23 | | FB - GB - SC | EF | DZ |



COMUNE DI ARGENTA (FE)
REGIONE EMILIA ROMAGNA



STIMA PRODUCIBILITA'

INDICE

| | |
|-------------------------------|---|
| 1. STIMA PRODUCIBILITA' | 1 |
|-------------------------------|---|

1. STIMA PRODUCIBILITA'

Project summary

| | | | | | |
|---|--|------------------|----------|-------------------------|------|
| Geographical Site | | Situation | | Project settings | |
| Boccaleone, Argenta | | Latitude | 44.65 °N | Albedo | 0.20 |
| Italy | | Longitude | 11.83 °E | | |
| | | Altitude | -3 m | | |
| | | Time zone | UTC | | |
| Meteo data | | | | | |
| Boccaleone, Argenta | | | | | |
| SolarGIS Monthly aver. , period not spec. - Synthetic | | | | | |

System summary

| | | | | | |
|------------------------------|-------------|--------------------------------|--|-----------------------|--|
| Grid-Connected System | | Sheds system | | User's needs | |
| PV Field Orientation | | Near Shadings | | Unlimited load (grid) | |
| Fixed plane | | Linear shadings : Fast (table) | | | |
| Tilt/Azimuth | 20 / 0.2 ° | | | | |
| System information | | | | | |
| PV Array | | | | | |
| Nb. of modules | 18228 units | Inverters | | 9 units | |
| Pnom total | 12.67 MWp | Nb. of units | | 9900 kVA | |
| | | Pnom total | | 10.50 MVA | |
| | | Grid power limit | | 1.206 | |
| | | Grid lim. Pnom ratio | | | |

Results summary

| | | | | | |
|-----------------|--------------------|---------------------|-------------------|----------------|--------|
| Produced Energy | 18359259 kWh/year | Specific production | 1434 kWh/kWp/year | Perf. Ratio PR | 88.3 % |
| Apparent energy | 18359259 kVAh/year | | | | |

Table of contents

| | |
|---|----|
| Project and results summary | 2 |
| General parameters, PV Array Characteristics, System losses | 3 |
| Near shading definition - Iso-shadings diagram | 5 |
| Main results | 6 |
| Loss diagram | 7 |
| Predef. graphs | 8 |
| P50 - P90 evaluation | 9 |
| Single-line diagram | 10 |

General parameters

| | | | | | | | | | | | | |
|-------------------------------------|-----------------------------------|-----------------------------------|-----------|------|------|------|------|------|------|------|------|------|
| Grid-Connected System | | Sheds system | | | | | | | | | | |
| PV Field Orientation | | Sheds configuration | | | | | | | | | | |
| Orientation | | Nb. of sheds | 362 units | | | | | | | | | |
| Fixed plane | | Sizes | | | | | | | | | | |
| Tilt/Azimuth | 20 / 0.2 ° | Sheds spacing | 8.10 m | | | | | | | | | |
| | | Collector width | 4.82 m | | | | | | | | | |
| | | Ground Cov. Ratio (GCR) | 59.5 % | | | | | | | | | |
| | | Shading limit angle | | | | | | | | | | |
| | | Limit profile angle | 24.8 ° | | | | | | | | | |
| Horizon | | Near Shadings | | | | | | | | | | |
| Free Horizon | | Linear shadings : Fast (table) | | | | | | | | | | |
| Bifacial system | | User's needs | | | | | | | | | | |
| Model | 2D Calculation unlimited sheds | Unlimited load (grid) | | | | | | | | | | |
| Bifacial model geometry | | Bifacial model definitions | | | | | | | | | | |
| Sheds spacing | 8.10 m | Ground albedo average | 0.16 | | | | | | | | | |
| Sheds width | 4.82 m | Bifaciality factor | 80 % | | | | | | | | | |
| Limit profile angle | 24.8 ° | Rear shading factor | 7.0 % | | | | | | | | | |
| GCR | 59.5 % | Rear mismatch loss | 5.0 % | | | | | | | | | |
| Height above ground | 0.50 m | Shed transparent fraction | 4.0 % | | | | | | | | | |
| Monthly ground albedo values | | | | | | | | | | | | |
| Jan. | Feb. | Mar. | Apr. | May | June | July | Aug. | Sep. | Oct. | Nov. | Dec. | Year |
| 0.13 | 0.16 | 0.17 | 0.19 | 0.19 | 0.20 | 0.19 | 0.17 | 0.16 | 0.14 | 0.13 | 0.13 | 0.16 |
| Grid injection point | | Power factor | | | | | | | | | | |
| Grid power limitation | | Cos(phi) (lagging) | | | | | | | | | | |
| Apparent power | 10.50 MVA | | 1.000 | | | | | | | | | |
| Pnom ratio | 1.206 | | | | | | | | | | | |

PV Array Characteristics

| | | | |
|----------------------------------|----------------------------|--------------------------------|------------|
| PV module | | Inverter | |
| Manufacturer | CSI Solar Co., Ltd. | Manufacturer | Sungrow |
| Model | CS7N-695TB-AG 1500V | Model | SG1100UD |
| (Custom parameters definition) | | (Custom parameters definition) | |
| Unit Nom. Power | 695 Wp | Unit Nom. Power | 1100 kVA |
| Number of PV modules | 18228 units | Number of inverters | 9 units |
| Nominal (STC) | 12.67 MWp | Total power | 9900 kVA |
| Modules | 651 Strings x 28 In series | Operating voltage | 895-1500 V |
| At operating cond. (50°C) | | Max. power (=>22°C) | 1265 kVA |
| Pmpp | 11.72 MWp | Pnom ratio (DC:AC) | 1.29 |
| U mpp | 1045 V | | |
| I mpp | 11215 A | | |
| Total PV power | | Total inverter power | |
| Nominal (STC) | 12668 kWp | Total power | 9900 kVA |
| Total | 18228 modules | Max. power | 11385 kVA |
| Module area | 56623 m ² | Number of inverters | 9 units |
| | | Pnom ratio | 1.29 |

Array losses

| | | | | | | | | |
|--|--------------|--|---------------|----------------------------|--------------|-------|-------|-------|
| Array Soiling Losses | | Thermal Loss factor | | DC wiring losses | | | | |
| Loss Fraction | 1.5 % | Module temperature according to irradiance | | Global array res. | 1.4 mΩ | | | |
| | | Uc (const) | 29.0 W/m²K | Loss Fraction | 1.5 % at STC | | | |
| | | Uv (wind) | 0.0 W/m²K/m/s | | | | | |
| Serie Diode Loss | | LID - Light Induced Degradation | | Module Quality Loss | | | | |
| Voltage drop | 0.7 V | Loss Fraction | 0.5 % | Loss Fraction | -0.4 % | | | |
| Loss Fraction | 0.1 % at STC | | | | | | | |
| Module mismatch losses | | Strings Mismatch loss | | | | | | |
| Loss Fraction | 2.0 % at MPP | Loss Fraction | 0.1 % | | | | | |
| IAM loss factor | | | | | | | | |
| Incidence effect (IAM): User defined profile | | | | | | | | |
| 20° | 40° | 60° | 65° | 70° | 75° | 80° | 85° | 90° |
| 1.000 | 1.000 | 1.000 | 0.990 | 0.960 | 0.920 | 0.840 | 0.720 | 0.000 |

System losses

| | |
|----------------------------|----------|
| Auxiliaries loss | |
| Proportionnal to Power | 4.0 W/kW |
| 20.0 kW from Power thresh. | |
| Night aux. cons. | 5.00 kW |


AC wiring losses

| | |
|--|----------------------|
| Inv. output line up to MV transfo | |
| Inverter voltage | 630 Vac tri |
| Loss Fraction | 0.50 % at STC |
| Inverter: SG1100UD | |
| Wire section (9 Inv.) | Alu 9 x 3 x 3000 mm² |
| Average wires length | 135 m |
| MV line up to Injection | |
| MV Voltage | 30 kV |
| Wires | Copper 3 x 95 mm² |
| Length | 3619 m |
| Loss Fraction | 1.00 % at STC |


AC losses in transformers

| | |
|-------------------------------|---------------|
| MV transfo | |
| Medium voltage | 30 kV |
| Transformer parameters | |
| Nominal power at STC | 12.57 MVA |
| Iron Loss (night disconnect) | 12.57 kVA |
| Iron loss fraction | 0.10 % at STC |
| Copper loss | 138.22 kVA |
| Copper loss fraction | 1.10 % at STC |
| Coils equivalent resistance | 3 x 0.35 mΩ |

Near shadings parameter



Iso-shadings diagram




Main results


System Production

| | | | | | |
|-----------------------|--------------------|---------------------------|-------------------|----------------|--------|
| Produced Energy (P50) | 8359259 kWh/year | Specific production (P50) | 1434 kWh/kWp/year | Perf. Ratio PR | 88.3 % |
| Produced Energy (P75) | 7904660 kWh/year | Specific production (P75) | 1398 kWh/kWp/year | | |
| Produced Energy (P90) | 7494597 kWh/year | Specific production (P90) | 1366 kWh/kWp/year | | |
| Apparent energy | 18359259 kVAh/year | | | | |

Normalized productions (per installed kWp)



Performance Ratio PR




Balances and main results

| | GlobHor kWh/m ² | DiffHor kWh/m ² | T_Amb °C | GlobInc kWh/m ² | GlobEff kWh/m ² | EArray kWh | E_Grid kWh | PR ratio |
|-----------|-------------------------------|-------------------------------|-------------|-------------------------------|-------------------------------|---------------|---------------|-------------|
| January | 43.0 | 23.20 | 4.60 | 63.3 | 57.1 | 727211 | 702039 | 0.875 |
| February | 65.8 | 30.30 | 6.10 | 89.3 | 85.2 | 1077903 | 1039943 | 0.919 |
| March | 116.4 | 49.50 | 10.30 | 143.3 | 138.3 | 1722469 | 1659365 | 0.914 |
| April | 143.8 | 62.70 | 14.30 | 159.7 | 154.3 | 1893631 | 1823407 | 0.901 |
| May | 185.3 | 77.90 | 19.40 | 192.0 | 185.5 | 2235214 | 2151988 | 0.885 |
| June | 201.7 | 80.50 | 24.10 | 203.9 | 197.2 | 2349836 | 2261777 | 0.876 |
| July | 214.9 | 76.80 | 26.40 | 220.6 | 213.7 | 2520579 | 2425328 | 0.868 |
| August | 181.2 | 69.60 | 25.70 | 197.4 | 191.0 | 2254614 | 2171229 | 0.868 |
| September | 128.5 | 54.90 | 20.80 | 150.2 | 145.0 | 1738813 | 1675417 | 0.881 |
| October | 81.5 | 41.30 | 15.80 | 103.5 | 99.2 | 1216526 | 1173800 | 0.895 |
| November | 44.4 | 24.50 | 10.40 | 62.9 | 57.6 | 722488 | 697123 | 0.875 |
| December | 35.4 | 19.10 | 5.29 | 54.0 | 47.1 | 599673 | 577844 | 0.845 |
| Year | 1441.9 | 610.30 | 15.32 | 1640.0 | 1571.1 | 19058958 | 18359261 | 0.883 |

Legends


| | | | |
|---------|--|--------|---|
| GlobHor | Global horizontal irradiation | EArray | Effective energy at the output of the array |
| DiffHor | Horizontal diffuse irradiation | E_Grid | Energy injected into grid |
| T_Amb | Ambient Temperature | PR | Performance Ratio |
| GlobInc | Global incident in coll. plane | | |
| GlobEff | Effective Global, corr. for IAM and shadings | | |

Loss diagram




Predef. graphs

Daily Input/Output diagram



System Output Power Distribution



P50 - P90 evaluation

Meteo data

| | |
|------------------------------------|---|
| Source | SolarGIS Monthly aver. , period not spec. |
| Kind | TMY, multi-year |
| Year-to-year variability(Variance) | 3.2 % |
| Specified Deviation | |
| Climate change | 0.0 % |

Simulation and parameters uncertainties

| | |
|------------------------------------|-------|
| PV module modelling/parameters | 1.0 % |
| Inverter efficiency uncertainty | 0.5 % |
| Soiling and mismatch uncertainties | 1.0 % |
| Degradation uncertainty | 1.0 % |

Global variability (meteo + system)

| | |
|-----------------------------|-------|
| Variability (Quadratic sum) | 3.7 % |
|-----------------------------|-------|

Annual production probability

| | |
|-------------|-----------|
| Variability | 674 MWh |
| P50 | 18360 MWh |
| P75 | 17904 MWh |
| P90 | 17495 MWh |

Probability distribution

