



Regione Emilia Romagna
Comune di Alfonsine (RA)
**IMPIANTO FOTOVOLTAICO
E OPERE CONNESSE**
Potenza Impianto 37,492 MWp



PROPONENTE


LIGHTSOURCE RENEWABLE ENERGY ITALY SPV 8 S.R.L.

VIA G. LEOPARDI, 7 - 20123 MILANO (MI) - P.IVA: 12593780963 – PEC: lightsourcespv_8@legalmail.it

PROGETTAZIONE

Ing. Antonello Rutilio 

Via R. Zandonai, 4 – 44124 – FERRARA IT - P.IVA: 00522150382 – PEC: incico@pec.it
Tel.: +39 0532 202613 – email: a.rutilio@incico.com

Ing. Lorenzo Stocchino 

Via R. Zandonai, 4 – 44124 – FERRARA IT - P.IVA: 00522150382 – PEC: incico@pec.it
Tel.: +39 0532 202613 – email: l.stocchino@incico.com

COORDINAMENTO PROGETTUALE

SOLAR IT S.R.L. 

VIA I. ALPI 4 – 46100 - MANTOVA IT - P.IVA: 02627240209 – PEC: solarit@lamiappec.it
Tel.: +390425 072 257 – email: info@solaritglobal.com

TITOLO ELABORATO

Relazione Calcoli Producibilità

LIVELLO DI PROGETTAZIONE	CODICE ELABORATO	FILE NAME	DATA
DEFINITIVO	PI-R04	LS15781-PI-R04_1	21/12/2022

REVISIONI

REV.	DATA	DESCRIZIONE	ESEGUITO	VERIFICATO	APPROVATO
0	21/12/2022	PERMITTING	MCA	MLA	ARI
1	15/11/2023	INTEGRAZIONE VOLONTARIA	MCA	LST	ARU
2	12/12/2023	RICHIESTA INTEGRAZIONI	MCA	LST	ARU

RELAZIONE CALCOLI DI PRODUCIBILITA'

INDICE

Contenuto del documento

1. PREMESSA	2
2. CALCOLI DI PRODUCIBILITA'	2
2.1. SITO DI SANT'ANNA.....	3
2.2. SITO DI CAMPEGGIA	15
3. EMISSIONI EVITATE.....	27

1. PREMESSA

La società proponente nell'ambito del proprio piano di sviluppo delle fonti energetiche rinnovabili prevede di realizzare un impianto di produzione da fonte rinnovabile - fotovoltaica - nel Comune di Alfonsine (RA) (nel seguito "Impianto FV").

2. CALCOLI DI PRODUCIBILITA'

Nel seguito si riportano i calcoli relativi alla producibilità del sito fotovoltaico di cui il presente progetto, per i quali ci si è avvalsi del software PVSyst il quale calcolerà l'energia prodotta, su base mensile ed annuale.

2.1. SITO DI SANT'ANNA

Project summary

Geographical Site Chiesa Nuova Italy	Situation Latitude 44.55 °N Longitude 11.96 °E Altitude 10 m Time zone UTC+1	Project settings Albedo 0.20
Meteo data Chiesa Nuova Meteonorm 8.1 (1991-2012), Sat=100% - Sintetico		

System summary

Grid-Connected System PV Field Orientation Orientation Tracking plane, horizontal N-S axis Axis azimuth 0 °	Tracking system with backtracking Tracking algorithm Irradiance optimization Backtracking activated	Near Shadings Linear shadings : Slow (simul.) Diffuse shading Automatic
System information PV Array Nb. of modules 25272 units Pnom total 17.69 MWp	Inverters Nb. of units 5 units Pnom total 17.19 MWac Pnom ratio 1.029	
User's needs Unlimited load (grid)		

Results summary

Produced Energy	26998968 kWh/year	Specific production	1526 kWh/kWp/year	Perf. Ratio PR	90.82 %
-----------------	-------------------	---------------------	-------------------	----------------	---------

General parameters

Grid-Connected System		Tracking system with backtracking	
PV Field Orientation		Tracking algorithm	Backtracking array
Orientation		Irradiance optimization	Nb. of trackers 987 units
Tracking plane, horizontal N-S axis		Backtracking activated	Sizes
Axis azimuth	0 °		Tracker Spacing 8.70 m
			Collector width 4.79 m
			Ground Cov. Ratio (GCR) 55.0 %
			Phi min / max. -/+ 60.0 °
			Backtracking strategy
			Phi limits for BT -/+ 56.5 °
			Backtracking pitch 8.70 m
			Backtracking width 4.79 m
			Mode Automatic
Models used		Near Shadings	User's needs
Transposition	Perez	Linear shadings : Slow (simul.)	Unlimited load (grid)
Diffuse	Perez, Meteonorm	Diffuse shading Automatic	
Circumsolar	separate		
Horizon			
Free Horizon			
Bifacial system			
Model	2D Calculation unlimited trackers		
Bifacial model geometry		Bifacial model definitions	
Tracker Spacing	8.70 m	Ground albedo	0.30
Tracker width	4.79 m	Bifaciality factor	80 %
GCR	55.0 %	Rear shading factor	5.0 %
Axis height above ground	2.10 m	Rear mismatch loss	10.0 %
		Shed transparent fraction	0.0 %

PV Array Characteristics

PV module		Inverter	
Manufacturer	Risen Solar	Manufacturer	Sungrow
Model	RSM132-8-700BHDG	Model	SG3400-HV-20
(Custom parameters definition)		(Custom parameters definition)	
Unit Nom. Power	700 Wp	Unit Nom. Power	3437 kWac
Number of PV modules	25272 units	Number of inverters	10 * MPPT 50% 5 units
Nominal (STC)	17.69 MWp	Total power	17185 kWac
Modules	972 string x 26 ln series	Operating voltage	875-1300 V
At operating cond. (50°C)		Max. power (=>25°C)	3593 kWac
Pmpp	16.73 MWp	Pnom ratio (DC:AC)	1.03
U mpp	1023 V	No power sharing between MPPTs	
I mpp	16361 A		
Total PV power		Total inverter power	
Nominal (STC)	17690 kWp	Total power	17185 kWac
Total	25272 modules	Number of inverters	5 units
Module area	78504 m ²	Pnom ratio	1.03

Array losses

Thermal Loss factor		DC wiring losses		LID - Light Induced Degradation	
Module temperature according to irradiance		Global array res.	1.0 mΩ	Loss Fraction	1.4 %
Uc (const)	29.0 W/m ² K	Loss Fraction	1.5 % at STC		
Uv (wind)	0.0 W/m ² K/m/s				
Module Quality Loss		Module mismatch losses		Strings Mismatch loss	
Loss Fraction	-0.4 %	Loss Fraction	2.0 % at MPP	Loss Fraction	0.2 %

IAM loss factor

Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

AC wiring losses

Inv. output line up to MV transfo

Inverter voltage	600 Vac tri
Loss Fraction	0.11 % at STC

Inverter: SG3400-HV-20

Wire section (5 Inv.)	Copper 5 x 3 x 2500 mm ²
Average wires length	15 m

MV line up to Injection

MV Voltage	20 kV
Average each inverter	
Wires	Copper 3 x 120 mm ²
Length	3700 m
Loss Fraction	0.51 % at STC

AC losses in transformers

MV transfo



Medium voltage	20 kV
----------------	-------

One transfo parameters

Nominal power at STC	3.50 MVA
Iron Loss (24/24 Connexion)	3.56 kVA
Iron loss fraction	0.10 % at STC
Copper loss	34.53 kVA
Copper loss fraction	0.99 % at STC
Coils equivalent resistance	3 x 1.01 mΩ

Operating losses at STC (full system)

Nb. identical MV transfos	5
Nominal power at STC	17.51 MVA
Iron loss (24/24 Connexion)	17.78 kVA
Copper loss	172.65 kVA



Main results


System Production

Produced Energy 26998968 kWh/year


Specific production
Perf. Ratio PR

1526 kWh/kWp/year
90.82 %

Normalized productions (per installed kWp)



Performance Ratio PR




Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray kWh	E_Grid kWh	PR ratio
January	41.3	22.44	2.92	50.3	47.1	844964	813359	0.914
February	55.9	33.19	5.13	66.6	63.6	1136679	1101291	0.935
March	108.1	51.97	10.02	134.8	130.1	2280250	2220530	0.931
April	136.0	67.92	14.40	166.5	161.5	2792428	2720843	0.924
May	180.7	82.30	19.65	221.2	215.3	3660289	3567796	0.912
June	196.8	85.26	24.33	243.0	236.9	3972348	3872199	0.901
July	199.7	79.00	26.67	249.7	243.4	4046036	3943738	0.893
August	173.2	70.77	25.98	216.8	211.1	3521148	3432585	0.895
September	120.2	54.88	20.36	148.1	143.4	2444497	2380983	0.909
October	78.8	44.10	15.85	95.8	91.6	1594406	1549391	0.914
November	41.4	24.25	10.01	50.9	48.1	845352	813301	0.903
December	31.2	21.02	4.26	36.7	34.0	610633	582951	0.899
Year	1363.2	637.12	15.02	1680.5	1626.3	27749030	26998968	0.908

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		

Loss diagram




Predef. graphs

Energia incidente di riferimento su piano collettori




Fattori normalizzati di produzione e di perdita




Predef. graphs

Distribuzione irraggiamento incidente



Coda della distribuzione di irradiazione incidente



Predef. graphs

Temperatura del campo vs. irradiazione efficace






Diagramma giornaliero entrata/uscita




Predef. graphs

Energia giornaliera in uscita sistema




Distribuzione potenza dell'impianto




Predef. graphs

Distribuzione potenza in uscita sistema




Coda della distribuzione della potenza in uscita




Predef. graphs

Distribuzione tensione impianto



Distribuzione temperatura impianto



2.2. SITO DI CAMPEGGIA

Project summary

Geographical Site Chiesa Nuova Italia	Situation Latitude 44.55 °N Longitude 11.96 °E Altitude 10 m Time zone UTC+1	Project settings Albedo 0.20
Meteo data Chiesa Nuova Meteonorm 8.1 (1991-2012), Sat=100% - Sintetico		

System summary

Grid-Connected System	Tracking system with backtracking	
PV Field Orientation Orientation Tracking plane, horizontal N-S axis Axis azimuth 0 °	Tracking algorithm Astronomic calculation Backtracking activated	Near Shadings Linear shadings : Fast (table) Diffuse shading Automatic
System information PV Array Nb. of modules 28288 units Pnom total 19.80 MWp	Inverters Nb. of units 5 units Pnom total 17.19 MWac Pnom ratio 1.152	
User's needs Unlimited load (grid)		

Results summary

Produced Energy	29858009 kWh/year	Specific production	1508 kWh/kWp/year	Perf. Ratio PR	90.19 %
-----------------	-------------------	---------------------	-------------------	----------------	---------

General parameters

Grid-Connected System		Tracking system with backtracking	
PV Field Orientation		Tracking algorithm	Backtracking array
Orientation		Astronomic calculation	Nb. of trackers 1115 units
Tracking plane, horizontal N-S axis		Backtracking activated	Sizes
Axis azimuth	0 °		Tracker Spacing 8.70 m
			Collector width 4.79 m
			Ground Cov. Ratio (GCR) 55.0 %
			Phi min / max. -/+ 60.0 °
			Backtracking strategy
			Phi limits for BT -/+ 56.5 °
			Backtracking pitch 8.70 m
			Backtracking width 4.79 m
			Mode Automatic
Models used		Near Shadings	User's needs
Transposition	Perez	Linear shadings : Fast (table)	Unlimited load (grid)
Diffuse	Perez, Meteororm	Diffuse shading Automatic	
Circumsolar	separate		
Horizon			
Free Horizon			
Bifacial system			
Model	2D Calculation unlimited trackers		
Bifacial model geometry		Bifacial model definitions	
Tracker Spacing	8.70 m	Ground albedo	0.30
Tracker width	4.79 m	Bifaciality factor	80 %
GCR	55.0 %	Rear shading factor	5.0 %
Axis height above ground	2.10 m	Rear mismatch loss	10.0 %
		Shed transparent fraction	0.0 %

PV Array Characteristics

PV module		Inverter	
Manufacturer	Risen Solar	Manufacturer	Sungrow
Model	RSM132-8-700BHDG	Model	SG3400-HV-20
(Custom parameters definition)		(Custom parameters definition)	
Unit Nom. Power	700 Wp	Unit Nom. Power	3437 kWac
Number of PV modules	28288 units	Number of inverters	10 * MPPT 50% 5 units
Nominal (STC)	19.80 MWp	Total power	17185 kWac
Modules	1088 string x 26 In series	Operating voltage	875-1300 V
At operating cond. (50°C)		Max. power (=>25°C)	3593 kWac
Pmpp	18.73 MWp	Pnom ratio (DC:AC)	1.15
U mpp	1023 V	No power sharing between MPPTs	
I mpp	18314 A		
Total PV power		Total inverter power	
Nominal (STC)	19802 kWp	Total power	17185 kWac
Total	28288 modules	Number of inverters	5 units
Module area	87872 m ²	Pnom ratio	1.15

Array losses

Thermal Loss factor

Module temperature according to irradiance
 U_c (const) 29.0 W/m²K
 U_v (wind) 0.0 W/m²K/m/s

DC wiring losses

Global array res. 0.90 mΩ
 Loss Fraction 1.5 % at STC

LID - Light Induced Degradation

Loss Fraction 1.4 %

Module Quality Loss

Loss Fraction -0.4 %

Module mismatch losses

Loss Fraction 2.0 % at MPP

Strings Mismatch loss

Loss Fraction 0.2 %

IAM loss factor

Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

AC wiring losses

Inv. output line up to MV transfo

Inverter voltage 600 Vac tri
 Loss Fraction 0.12 % at STC

Inverter: SG3400-HV-20

Wire section (5 Inv.) Copper 5 x 3 x 2500 mm²
 Average wires length 15 m

MV line up to Injection

MV Voltage 20 kV
 Average each inverter
 Wires Copper 3 x 120 mm²
 Length 5700 m
 Loss Fraction 0.88 % at STC

AC losses in transformers

MV transfo

Medium voltage 20 kV

One transfo parameters


Nominal power at STC 3.92 MVA
 Iron Loss (24/24 Connexion) 3.58 kVA
 Iron loss fraction 0.09 % at STC
 Copper loss 43.27 kVA
 Copper loss fraction 1.10 % at STC
 Coils equivalent resistance 3 x 1.01 mΩ

Operating losses at STC (full system)

Nb. identical MV transfos 5
 Nominal power at STC 19.60 MVA
 Iron loss (24/24 Connexion) 17.88 kVA
 Copper loss 216.35 kVA


Near shadings parameter

Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

Orientation #1



Main results

System Production

Produced Energy 29858009 kWh/year


Specific production

1508 kWh/kWp/year


Perf. Ratio PR

90.19 %

Normalized productions (per installed kWp)



Performance Ratio PR




Balances and main results

	GlobHor kWh/m ²	DiffHor kWh/m ²	T_Amb °C	GlobInc kWh/m ²	GlobEff kWh/m ²	EArray kWh	E_Grid kWh	PR ratio
January	41.3	22.44	2.92	49.6	45.9	926476	892577	0.908
February	55.9	33.19	5.13	65.8	62.2	1248745	1209575	0.928
March	108.1	51.97	10.02	134.1	128.5	2526893	2456536	0.925
April	136.0	67.92	14.40	165.6	159.4	3092908	3006944	0.917
May	180.7	82.30	19.65	220.3	213.1	4060468	3946998	0.905
June	196.8	85.26	24.33	242.4	235.2	4418705	4294962	0.895
July	199.7	79.00	26.67	249.1	241.7	4494952	4368846	0.886
August	173.2	70.77	25.98	216.2	209.5	3917490	3809029	0.890
September	120.2	54.88	20.36	147.4	141.8	2711148	2635637	0.903
October	78.8	44.10	15.85	95.0	89.9	1758678	1707816	0.908
November	41.4	24.25	10.01	50.3	46.9	927791	893350	0.897
December	31.2	21.02	4.26	36.0	32.9	664773	635740	0.891
Year	1363.2	637.12	15.02	1671.8	1606.9	30749028	29858009	0.902

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_Grid	Energy injected into grid
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane		
GlobEff	Effective Global, corr. for IAM and shadings		

Loss diagram




Predef. graphs

Energia incidente di riferimento su piano collettori




Fattori normalizzati di produzione e di perdita




Predef. graphs

Distribuzione irraggiamento incidente



Coda della distribuzione di irradiazione incidente



Predef. graphs

Temperatura del campo vs. irradiazione efficace






Diagramma giornaliero entrata/uscita




Predef. graphs

Energia giornaliera in uscita sistema




Distribuzione potenza dell'impianto




Predef. graphs

Distribuzione potenza in uscita sistema




Coda della distribuzione della potenza in uscita




Predef. graphs

Distribuzione tensione impianto



Distribuzione temperatura impianto



3. EMISSIONI EVITATE

L'impianto fotovoltaico, per sua natura, non comporta emissioni in atmosfera in quanto si basa, per definizione, sulla produzione di energia elettrica per mezzo della radiazione luminosa non impattando in alcun modo su quella che è la qualità dell'aria. La produzione di energia per mezzo di fonti rinnovabili consente una minor dipendenza da fonti fossili la cui combustione è responsabile dell'immissione di inquinanti in atmosfera.

Grazie ai calcoli sopra riportati si è in grado di determinare per ogni sito l'energia prodotta annualmente.

In base ai dati più aggiornati in termini di emissioni specifiche in atmosfera e di fattore di conversione di energia primaria, forniti dal Rapporto ISPRA si è determinata una stima di inquinanti non emessi in atmosfera e di risparmi in termini di energia primaria (TEP) ottenibili grazie alla realizzazione dell'impianto in studio:

Emissioni specifiche in atmosfera (Rapporto ISPRA 2018)	Inquinante [g/kWh]			
	CO ₂	SO ₂	NO _x	Polveri
	492	0,0636	0,227	0,0054

Tabella 1 - Fattori di emissione

Periodo di tempo considerato	Inquinante [ton]			
	CO ₂	SO ₂	NO _x	Polveri
Emissioni evitate in 1 anno	27 973,63	3,62	12,91	0,31
Emissioni evitate in 30 anni	839 208,98	108,48	387,20	9,21

Tabella 2 - Emissioni evitate

Valore di Energia primaria risparmiata per ogni MWh prodotto dall'impianto FTV	TEP/MWh
	0,187

Tabella 3 - Fattore di conversione dell'energia primaria

Periodo di tempo considerato	TEP
Emissioni evitate in 1 anno	10 632,25
Emissioni evitate in 30 anni	318 968

Tabella 4 - Energia primaria risparmiata