

REGIONE
CALABRIA



PROVINCIA DI
COSENZA



Committente: **Kosmo Wind s.r.l.**
via Sardegna 40
00187 Roma(RM)
P.IVA/C.F. 16799741000

Documento:

PROGETTO DEFINITIVO

Titolo del Progetto:

PARCO EOLICO "SAN COSMO"

Elaborato:

Studio anemologico

| ID PROGETTO: | DISCIPLINA: | CAPITOLO: | TIPO: | REVISIONE: | SCALA: | FORMATO: |
|---------------|-------------|-----------|-------|------------|--------|----------|
| IT-VesScO-Gem | CW | AN | TR | 0 | - | A4 |

NOME FILE:

IT-VesScO-Gem-CW-AN-TR-01-Rev.0_Studio anemologico

Progettazione:



Ing. Saverio Pagliuso

Ing. Mario Francesco Perri

Ing. Giorgio Salatino

| Rev: | Data Revisione | Descrizione Revisione | Redatto | Controllato | Approvato |
|------|----------------|-----------------------|---------|-------------|-------------------|
| 00 | Giugno 2023 | PRIMA EMISSIONE | GEMSA | GEMSA | Kosmo Wind S.r.l. |
| | | | | | |
| | | | | | |
| | | | | | |



PRELIMINARY WIND
RESOURCE ASSESSMENT
San Cosmo

August 2023

Details

A.1.1 Prepared for:

Client: Kosmo Wind S.r.l. (Vestas Wind System A/S)

Contact: Francesco Conte

Reference: VRIT23143 Framework Agreement

A.1.2 Prepared by:

Vector Renewables Italia S.r.l.

Via Alberto Falck, 4/16, Sesto San Giovanni, Milano • +39 02 87 36 68 56

Contact details

| Contact Name | Position | Email |
|------------------|------------------------------------|---------------------------------|
| Marco Guarneroli | Country Manager - Italy | mguarneroli@vectorenewables.com |
| Chiara Pavani | Head of Technical Advisory - Italy | cpavani@vectorenewables.com |
| Nell Franchi | Technical Advisory - Italy | nfranchi@vectorenewables.com |
| Martina Baratto | Technical Advisory - Italy | mbaratto@vectorenewables.com |
| Gianmarco Palma | Technical Advisory - Italy | gpalma@vectorenewables.com |

Version control

| Version | Description | Date | Drafted | Reviewed | Approved |
|---------|-----------------|----------|---------|----------|----------|
| V00 | Initial version | 10/08/23 | GP | NF, MB | CP |
| V01 | First review | 29/08/23 | GP | NF, MB | CP |



Disclaimer

The contents of this document have been prepared by Vector Renewables Italia S.r.l. (hereinafter, "Vector Renewables") based on its knowledge, the present project information, as well as the current legislation and wind and photovoltaic market according to its experience in the renewable energy sector and, particularly, in the auditing and consultancy of wind and photovoltaic facilities. Therefore, the results, analysis and comments included in this document shall be solely interpreted under such considerations.

Estimates, conclusions, and recommendations included in this document are based on information which has been considered correct, provided by reliable and verified databases as well as the best practice standards and estimates by Vector Renewables. Notwithstanding the above, it is not possible to guarantee the integrity and accuracy of such information, especially in relation to forecasts or future projections as long as the whole information needed or required for its production has not been received or its accuracy not verified. In this sense, Vector Renewables, its partners, affiliates, directors, or employees are not responsible for the accuracy, completeness or veracity of the information contained herein or conclusions or decisions made, based on false, incomplete or inaccurate information.

The content of this document is strictly limited to the matters that are addressed herein. In this sense, in no case should be understood that the content can be applied by analogy to other issues that it does not make explicit reference. The content of this document does not necessarily cover every matter of the topics dealt herein.

Vector Renewables, its partners, affiliates, directors or employees accept no responsibility for the results that any interested third party may produce, either for direct damages or for any damages which, directly or indirectly, could be derived from decisions or considerations based on this document, or any use that the recipient may make of this document.

With regards to the liability Vector Renewables may be made responsible for as an independent Technical Advisor, this will not exceed, under any circumstance, the fees agreed to carry out the services for which Vector Renewables has been hired, and in any case, will exclude indirect or consequential damages, lost profits, damages or opportunity costs. Vector Renewables will respond solely and exclusively to the recipient or the petitioner of the service excluding any liability towards any third party involved directly or indirectly in the project.

This document has an informative and confidential nature and does not represent a report for qualified expert opinion purposes to be used in a court or at a trial, nor is it a legal or a fiscal report. It is therefore, intended solely and exclusively for such purposes to the recipient or borrower, with its exhibition, distribution, or reproduction without the prior written consent of Vector Renewables being prohibited. The use of this document for others than those uses agreed will need prior written consent by Vector Renewables.

In case of using this document for other purposes not agreed or without prior written consent by Vector Renewables will lead to Vector Renewables to be entitled to claim an additional 20% to the fees received for the elaboration of this document, all without prejudice to legal action under the applicable law that may correspond for any damages that were caused.

The reception of this document by its recipient implies the full acceptance of this "Disclaimer".



Contents

| | |
|---|----|
| 1. Foreword | 4 |
| 2. Layout and turbine model | 5 |
| 2.1. Wind farm layout | 7 |
| 2.2. Wind turbine models | 9 |
| 3. Wind resource assessment | 10 |
| 4. Preliminary expected energy yield assessment | 12 |



1. FOREWORD

Kosmo Wind S.r.l., a company of Vestas Wind System A/S, (the “**Client**”) engaged Vector Renewables Italia S.r.l. as “**Technical Advisor**” (or “**TA**”) to perform a preliminary analysis for the definition of the wind resource and energy assessment of the San Cosmo wind farm (the “**Project**”) in development in Italy.

The **Project** includes n. 8 turbines with the following configuration:

| Turbine model | Rotor Diameter [m] | Hub height [m] | Tip height [m] | Number of turbines | Wind farm capacity [MW] |
|--------------------|--------------------|----------------|----------------|--------------------|-------------------------|
| Vestas V162-6.2 MW | 162.0 | 125.0 | 206.0 | 8 | 49.6 |

Tab. 1 - Configuration of San Cosmo wind farm

The activity consisted in the preliminary estimation of the expected annual energy production of the wind farm, according to the **Technical Advisor**’s analysis on the long-term wind regime representative of the area at the desired hub height.

Being the assessment based on re-analysis data characterized by a higher level of uncertainty compared to a measurement on site, the presented energy figures shall be considered as preliminary, and they should be updated when a full year measurement campaign onsite is available.






Fig. 2 - Roughness map

No information has been provided regarding other neighbouring turbines in operation or even in development phase and no site inspection has been carried out at this stage in order to verify this or the presence of any other obstacle that might affect the **Project**.

To be noted that from public database and aerial pictures publicly available online no operating turbines in the area within a radius of approximately 20 times the proposed rotor diameter are identified.

directions perpendicular to the prevailing. The next table shows the distances separating the wind turbines in diameters of 162 m rotor.

| RD=162m\Meter | SC01 | SC02 | SC03 | SC04 | SC05 | SC06 | SC07 | SC08 |
|---------------|------|------|------|------|------|------|------|------|
| SC01 | - | 2103 | 573 | 1068 | 1530 | 1913 | 2354 | 2778 |
| SC02 | 12.9 | - | 1543 | 1082 | 913 | 1287 | 762 | 3739 |
| SC03 | 3.5 | 9.5 | - | 495 | 1096 | 1423 | 1788 | 2823 |
| SC04 | 6.5 | 6.6 | 3.1 | - | 892 | 1048 | 1300 | 2926 |
| SC05 | 9.4 | 5.6 | 6.7 | 5.5 | - | 1748 | 1576 | 3814 |
| SC06 | 11.7 | 7.9 | 8.7 | 6.4 | 10.7 | - | 808 | 2530 |
| SC07 | 14.4 | 4.7 | 11.0 | 8.0 | 9.7 | 5.0 | - | 3330 |
| SC08 | 17.0 | 22.9 | 17.3 | 18.0 | 23.4 | 15.5 | 20.4 | - |

Tab. 3 - Spacings in rotor diameter and meters of San Cosmo wind farm

The above requirements are broadly met being the minimum distance of 3.0 rotor diameters between the turbines. In addition, according to the prevailing energy sectors (WSW or 240°), the spacing within turbines is higher than the recommended 5 rotor diameters between turbines.


To be noted that the site suitability analysis is outside of the current scope of work. In spite of the minimum distances between turbines are met, it is recommended to obtain the turbine manufacturer’s Mechanical Load assessment and site suitability Analysis (MLA), in order to ensure that the desired wind turbine model and the proposed layout will be suitable for the site according to IEC 61400-1 Standard Ed.3 and that the fatigue loads, resulting from the wind conditions onsite and acting on the turbine main components, are within the design load envelope.



2.2. Wind turbine models

The expected energy production of the wind farm is estimated considering the following turbine model requested by the Client, whose power curve has been adjusted at the site air density of 1.17 kg/m³ according to the IEC 61400-12 method correction. The temperature recorded by the nearest climate station available in the WindPro database has been considered in order to evaluate site proper air density; the average temperature recorded by the station Calopezzati V3 (1952-2078) at 215 m. a.s.l. is 17.1 °C and the respective one on the VMM position at the hub height (113 m) is 16.4°C.

| Turbine type | | V162-6.2 MW | Diameter [m] | 162.0 |
|---------------------------------|------------|------------------------|----------------------------------|-------|
| Rated power [MW] | | 6.2 | Hub height [m] | 125.0 |
| Rated wind speed [m/s] | | 13.0 | IEC class | S |
| Cut-in/Cut-out wind speed [m/s] | | 3.0/24.0 | Air density [kg/m ³] | 1.175 |
| Bin wind speed [m/s] | Power [kW] | Thrust coefficient [-] | | |
| 0 | 0 | 0 | | |
| 1 | 0 | 0 | | |
| 2 | 0 | 0 | | |
| 3 | 29 | 0.909 | | |
| 4 | 277 | 0.854 | | |
| 5 | 645 | 0.819 | | |
| 6 | 1176 | 0.812 | | |
| 7 | 1916 | 0.808 | | |
| 8 | 2893 | 0.801 | | |
| 9 | 4117 | 0.781 | | |
| 10 | 5325 | 0.672 | | |
| 11 | 6062 | 0.527 | | |
| 12 | 6191 | 0.389 | | |
| 13 | 6200 | 0.296 | | |
| 14 | 6200 | 0.233 | | |
| 15 | 6200 | 0.188 | | |
| 16 | 6200 | 0.154 | | |
| 17 | 6180 | 0.129 | | |
| 18 | 5826 | 0.104 | | |
| 19 | 5325 | 0.081 | | |
| 20 | 4802 | 0.064 | | |
| 21 | 4231 | 0.050 | | |
| 22 | 3649 | 0.038 | | |
| 23 | 3049 | 0.029 | | |
| 24 | 2437 | 0.022 | | |
| 25 | 0 | 0 | | |



Tab. 4 - Vestas V162-6.2 MW, power and C_t curves

3. WIND RESOURCE ASSESSMENT

Considering that a measurement campaign recorded onsite is not yet available, the preliminary estimation of the expected annual energy production of the Project is extrapolated from a Virtual Met Mast downscaled to a representative location of the San Cosmo wind farm at a height representative of the desired hub heights. The Virtual Met Mast statistics are usually obtained by using the sources available in the area deemed as representative, such as land-based wind data and mesoscale data. For the Project, 10-year hourly Vortex Series ERA-5 time series has been acquired and a pragmatical adjustment was applied to the wind data on the basis of the TA analysis of the wind regime of the area.

It is necessary to emphasize that the Virtual Met Mast does not replace a traditional on-site measurement mast and therefore any assessment of the energy production will have a high uncertainty. **The results shall be intended as a preliminary estimation only.** It is recommended to install at least one met mast onsite, in a position representative of the wind farm and characterized by a good exposure, whose structure should be high at least 2/3 of the proposed hub height, in order to reduce the vertical extrapolation uncertainties, and to update the analysis accordingly. Considering the proposed hub heights, a Lidar measurement should also be taken into account.

The long-term wind regime expected onsite has been assessed using the Virtual Met Mast characterized by a long-term wind speed at 125 m of 6.26 m/s, whose Weibull distribution, energy and wind roses split into five wind speed classes and 12 sectors are reported below.

It is observed that the prevailing winds, for both frequency and energy point of views, are from the west-southwestern sector – 240°.






Fig. 4 - Wind conditions at the Virtual Met Mast at 125 m



4. PRELIMINARY EXPECTED ENERGY YIELD ASSESSMENT

The expected energy production of the San Cosmo wind farm has been estimated with the wind turbine configuration requested, using the long-term wind statistics of the Virtual Met Mast and adopting the WAsP 12 model propagation as embedded in WindPRO 3.6. The wake model implemented in the analysis is the N.O. Jensen (RISO/EMD) Park2 2018 wake model with DTU default onshore wake decay constant of 0.090.

The energy production accounts for the losses due to wake effects and to the site air density.

The tables hereunder contain the following information for each wind turbine:

Site ID: ID number of the wind turbine in the table

X [m]: longitude in **UTM WGS84 ZONE 33** coordinates

Y [m]: latitude in **UTM WGS84 ZONE 33** coordinates

Elev. [m]: elevation above sea level (ASL)

HH [m]: hub height

V [m/s]: average wind speed estimated by the model at hub height

Gross Production [GWh]: expected gross output, gross and net of wake losses

Loss [%]: percent of production lost due to wake losses

Equivalent Hours [h]: equivalent annual hours of gross production, net of wake losses



| ID | X [m] | Y [m] | Elev. [m] | HH [m] | V [m/s] | Gross Production [GWh] | | Loss [%] | Net Hours [h] | |
|------|--------|---------|-----------|--------|----------------|------------------------|---------------|---------------|---------------|-------------|
| | | | | | | Gross of wakes | Net of wakes | | | |
| SC01 | 622531 | 4386715 | 177 | 125.0 | 6.39 | 18.43 | 18.37 | 0.29 | 2963 | |
| SC02 | 622696 | 4384618 | 230 | 125.0 | 6.10 | 17.26 | 16.94 | 1.88 | 2732 | |
| SC03 | 622679 | 4386161 | 177 | 125.0 | 6.38 | 18.41 | 17.90 | 2.80 | 2887 | |
| SC04 | 622833 | 4385691 | 215 | 125.0 | 6.26 | 17.86 | 16.94 | 5.12 | 2732 | |
| SC05 | 622050 | 4385263 | 204 | 125.0 | 6.23 | 17.81 | 17.38 | 2.41 | 2803 | |
| SC06 | 623798 | 4385282 | 192 | 125.0 | 5.90 | 16.38 | 15.69 | 4.21 | 2530 | |
| SC07 | 623455 | 4384550 | 226 | 125.0 | 5.96 | 16.68 | 16.61 | 0.42 | 2679 | |
| SC08 | 625232 | 4387366 | 130 | 125.0 | 6.10 | 17.36 | 16.66 | 4.07 | 2687 | |
| | | | | | Average | 6.17 | 17.52 | 17.06 | 2.65 | 2752 |
| | | | | | Total | | 140.18 | 136.48 | | |

Tab. 5 – San Cosmo energy production – Vestas V162-6.2 MW

It should be noted that the energy production presented above accounts only for the losses due to wake effects and air density and no other losses are included.

Overall, the wake losses are quite low (less than 3.0%), due to the good exposition to the prevalent wind directions for all turbines that are not affected by the mutual wake effects, except for turbines SC04, SC06 and SC08, which show wake losses greater than 4%.

The next step in the analysis is to assess the energy losses (electrical, production and power losses) to determine the energy that will be available for input into the power grid. The following is a list of the loss factors considered for a **10-year period**: at this stage no supply or O&M agreement are in place or even at a discussion phase, hence standard assumptions have been taken into account.

Each loss factor shall be reviewed as soon as the corresponding calculated or contractually agreed values are available.



| Loss Factor | Losses |
|--------------------------------------|--------------|
| | [%] |
| Turbine Availability | -3.0% |
| Non-contractual turbine availability | -0.5% |
| B.O.P. availability | -1.0% |
| Electrical grid availability | -0.3% |
| Electrical losses | -3.0% |
| Environment | -0.4% |
| Turbine Performance | -2.3% |
| Curtailment | - |
| Total losses | -10.1 |

Tab. 6 – Wind farm energy losses

The following table summarizes the results obtained for the Project:

| Configuration | Wind farm capacity [MW] | Gross production (net of wakes) | | Net production (deliverable to grid) | |
|--------------------|-------------------------|---------------------------------|----------|--------------------------------------|----------|
| | | [GWh/year] | [h/year] | [GWh/year] | [h/year] |
| Vestas V162-6.2 MW | 49.6 | 136.48 | 2752 | 122.72 | 2474 |

Tab. 7 – Gross and Net energy production

The expected net production estimates (deliverable to grid) shown in the table above, represent the so-called $P_{50\%}$, i.e. the production calculated with the average wind conditions, also called central estimate.

Without measurements on site, it is not possible to provide an accurate evaluation of the uncertainty of the wind and energy assessment.

In any case, following the Client request, an exercise has been undertaken evaluating the main uncertainty sources according as far as possible to IEC WG15 outcoming standards in order to provide an indicative average uncertainty value was carried out. In this context, the uncertainty of a parameter is defined as the estimate of the standard deviation of the corresponding statistical distribution.

A sensitivity factor of 1.30 has been estimated to convert the uncertainty related to the wind speed into energy uncertainty. Based on the uncertainty estimation, it is possible to compute the values of $P_{75\%}(1)$, $P_{90\%}(1)$ and $P_{75\%}(10)$, $P_{90\%}(10)$. Specifically, the $P_{75\%}$ and $P_{90\%}$ values represent, respectively, the average energy production that has a 75% and 90% probability of being exceeded in a given period. In this case, the average value of a 10-year period or of 1 year within 10 years.

Under these assumptions, considering such sensitivity factor, the assessment of an indicative uncertainty for the 1-year and 10-year period provides values of about



20.6% and 20.0% respectively. The results of the sensitivity analysis are shown in the table below.

| Configuration | Expected annual production in any period of 1 year (GWh/year) | | | Expected annual production in any period of 10 year (GWh/year) | | |
|--------------------|---|--------|-------|--|--------|-------|
| | P50% | P75% | P90% | P50% | P75% | P90% |
| Vestas V162-6.2 MW | 122.72 | 105.70 | 90.38 | 122.72 | 106.19 | 91.32 |


Tab. 8 - Confidence interval for net energy production



Vector Renewables



Expertise and insights gained as Asset Manager of more than **3.5 GW**



70 GW of experience including solar PV and wind power services



Experience in more than **40** countries worldwide



Multidisciplinary team composed of over **200** employees



Offices in **10** countries



15 years in the renewable energy industry

